

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Jan-22

System Name: **Glide Water Association** ID#: **4100326** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.049	P/O	P/O	0.027	0.023	0.022	0.066
2	0.036	P/O	P/O	0.024	0.021	0.020	0.027
3	0.019	P/O	0.044	0.036	P/O	P/O	0.053
4	P/O	P/O	P/O	P/O	0.033	0.048	0.147
5	0.043	P/O	0.075	P/O	P/O	P/O	0.176
6	0.072	0.050	0.048	0.042	0.054	0.055	0.137
7	P/O	P/O	0.095	0.039	0.042	0.035	0.162
8	P/O	P/O	P/O	0.055	0.033	0.031	0.199
9	0.037	0.025	0.039	0.026	0.028	0.037	0.084
10	0.023	0.021	0.020	0.037	0.025	0.020	0.084
11	0.033	0.029	P/O	0.023	0.019	0.039	0.055
12	0.025	P/O	0.020	0.019	0.028	0.025	0.062
13	0.022	P/O	0.020	0.018	0.031	0.022	0.051
14	P/O	P/O	0.019	0.023	0.027	0.020	0.060
15	P/O	P/O	P/O	0.017	0.027	0.019	0.056
16	0.015	P/O	0.017	0.023	0.022	P/O	0.052
17	0.017	P/O	0.016	0.027	0.020	0.017	0.051
18	0.015	P/O	0.015	0.026	0.017	0.017	0.047
19	0.032	P/O	0.040	0.018	0.016	0.016	0.120
20	0.024	P/O	P/O	0.017	0.016	0.015	0.068
21	0.026	P/O	P/O	0.018	0.019	0.017	0.060
22	0.019	P/O	0.024	0.019	0.018	0.017	0.029
23	P/O	0.015	0.031	0.023	0.019	0.018	0.047
24	0.016	P/O	0.016	0.024	0.019	0.017	0.045
25	0.026	0.020	0.018	0.017	0.016	0.015	0.021
26	0.014	0.015	P/O	0.024	0.018	0.017	0.036
27	0.015	0.029	P/O	0.020	0.018	0.018	0.040
28	0.025	0.020	P/O	0.017	0.017	0.016	0.036
29	0.025	0.020	P/O	0.018	0.018	0.022	0.036
30	0.022	P/O	0.019	0.017	0.017	0.025	0.030
31	0.020	P/O	0.017	0.018	0.016	0.016	0.019

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="checkbox"/> Yes / No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 2/8/22
		PHONE #: (541) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

Disinfection  
Gardis Log  
Inactive: **1.0**

System Name: **Gilde Water Association** ID#: **4100326** Month/Year:

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1/2022 7:58	0.9	150	129	5	7.2	55	Yes	175
1/2/2022 8:16	0.9	150	137	5	7.2	59	Yes	175
1/3/2022 7:55	1.0	150	147	6	7.3	57	Yes	175
1/4/2022 17:03	0.7	150	104	6	7.1	48	Yes	175
1/5/2022 6:47	0.8	150	117	8	7.0	44	Yes	175
1/6/2022 7:40	0.7	150	109	8	6.9	40	Yes	175
1/7/2022 7:46	0.7	150	110	9	6.9	40	Yes	175
1/8/2022 8:50	1.0	150	152	8	6.9	43	Yes	175
1/9/2022 6:44	1.1	150	166	7	6.9	46	Yes	175
1/10/2022 20:29	0.8	150	122	7	7.0	46	Yes	175
1/11/2022 1:09	0.8	150	124	8	7.0	45	Yes	175
1/12/2022 21:23	0.8	150	115	8	7.1	45	Yes	175
1/13/2022 5:42	0.7	150	109	7	7.0	45	Yes	175
1/14/2022 7:38	0.7	150	98	8	7.0	44	Yes	175
1/15/2022 8:39	0.6	150	95	7	7.0	45	Yes	175
1/16/2022 7:21	0.7	150	100	7	7.1	47	Yes	175
1/17/2022 6:16	0.7	150	101	7	7.1	48	Yes	175
1/18/2022 8:55	0.7	150	106	7	7.1	48	Yes	175
1/19/2022 5:25	0.8	150	113	8	7.1	44	Yes	175
1/20/2022 9:56	0.8	150	119	8	7.1	46	Yes	175
1/21/2022 21:22	1.0	150	143	7	7.1	49	Yes	175
1/22/2022 11:58	0.9	150	137	6	7.1	51	Yes	175
1/23/2022 5:03	0.9	150	135	6	7.1	52	Yes	175
1/24/2022 22:49	0.9	150	128	6	7.2	52	Yes	175
1/25/2022 8:12	0.8	150	123	6	7.1	52	Yes	175
1/26/2022 8:34	0.9	150	131	5	7.1	54	Yes	175
1/27/2022 23:48	0.9	150	128	5	7.1	56	Yes	175
1/28/2022 8:29	0.8	150	123	5	7.2	56	Yes	175
1/29/2022 9:15	0.8	150	125	5	7.2	56	Yes	175
1/30/2022 5:06	0.8	150	126	5	7.2	55	Yes	175
1/31/2022 20:26	0.7	150	106	6	7.2	53	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwo.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350