

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: Feb-22

System Name Glide Water Association

ID#: 4100326

WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.016	P/O	0.026	0.020	0.018	0.018	0.047
2	0.022	P/O	P/O	0.020	0.018	0.018	0.039
3	0.022	0.024	P/O	0.023	0.019	0.018	0.114
4	0.021	P/O	0.023	0.020	0.019	0.019	0.025
5	P/O	0.031	0.025	0.021	0.020	0.019	0.034
6	0.019	0.027	P/O	0.021	0.021	0.020	0.040
7	0.027	P/O	0.023	0.023	0.021	0.021	0.042
8	0.027	P/O	0.023	0.023	0.023	P/O	0.045
9	0.026	P/O	0.028	0.025	0.025	0.024	0.030
10	0.024	P/O	0.032	0.027	0.026	0.025	0.041
11	0.025	P/O	0.025	0.032	P/O	0.029	0.051
12	P/O	0.028	P/O	0.028	0.035	P/O	0.056
13	0.031	P/O	0.030	0.031	0.030	0.033	0.047
14	0.037	P/O	0.034	0.033	0.032	0.032	0.058
15	0.037	0.038	P/O	0.036	0.036	0.036	0.043
16	0.036	P/O	0.054	0.043	P/O	0.039	0.062
17	0.039	0.038	0.040	0.038	P/O	0.028	0.085
18	0.022	P/O	0.021	0.021	0.026	P/O	0.047
19	0.022	P/O	0.020	0.021	0.020	0.025	0.043
20	P/O	P/O	P/O	0.022	0.021	0.025	0.045
21	0.026	0.021	0.023	0.023	0.023	0.025	0.069
22	0.047	0.033	0.029	0.028	0.025	0.024	0.060
23	0.031	P/O	0.028	0.027	0.024	0.022	0.032
24	0.023	P/O	0.035	0.028	0.025	0.024	0.040
25	0.025	0.023	0.023	0.032	0.028	P/O	0.051
26	0.025	P/O	0.024	0.038	0.029	P/O	0.043
27	0.026	P/O	P/O	0.026	0.033	0.028	0.047
28	0.029	P/O	0.028	0.027	0.034	0.030	0.053
29	No Data	No Data	No Data	No Data	No Data	No Data	0.000
30	No Data	No Data	No Data	No Data	No Data	No Data	0.000
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ²

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Notes: P/O = PLANT OFF

DV = DIVERTED

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

Yes / No

PRINTED NAME: Jonathan Woody

SIGNATURE:

PHONE #: (541) 643-6137

DATE: 3/9/22

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

Disinfection

Giardia Log

Inactive:

1.0

System Name: Glide Water Association

ID#:4100326

Month/Year: Feb-22

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (n) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
2/1/2022 7:33	0.7	150	100	6	7.2	51	Yes	175
2/2/2022 7:56	0.9	150	128	6	7.2	53	Yes	175
2/3/2022 8:01	0.9	150	134	6	7.2	54	Yes	175
2/4/2022 4:35	0.9	150	130	6	7.2	54	Yes	175
2/5/2022 10:23	0.8	150	126	6	7.3	55	Yes	175
2/6/2022 10:16	0.8	150	123	6	7.2	55	Yes	175
2/7/2022 22:29	0.7	150	106	5	7.2	55	Yes	175
2/8/2022 7:34	0.7	150	101	6	7.2	54	Yes	175
2/9/2022 10:32	0.9	150	131	6	7.3	56	Yes	175
2/10/2022 7:34	0.8	150	125	6	7.3	54	Yes	175
2/11/2022 7:09	0.9	150	128	7	7.3	52	Yes	175
2/12/2022 9:48	0.9	150	128	6	7.2	52	Yes	175
2/13/2022 7:50	0.8	150	125	6	7.3	53	Yes	175
2/14/2022 21:42	0.7	150	109	7	7.3	50	Yes	175
2/15/2022 0:32	0.7	150	107	7	7.2	49	Yes	175
2/16/2022 23:44	0.7	150	108	7	7.2	49	Yes	175
2/17/2022 7:45	0.7	150	105	7	7.2	50	Yes	175
2/18/2022 5:09	0.7	150	107	7	7.2	51	Yes	175
2/19/2022 7:29	0.7	150	110	7	7.3	50	Yes	175
2/20/2022 8:10	0.8	150	116	7	7.3	52	Yes	175
2/21/2022 22:53	0.7	150	103	6	7.3	54	Yes	175
2/22/2022 7:27	0.7	150	104	5	7.3	58	Yes	175
2/23/2022 6:54	0.8	150	114	4	7.2	60	Yes	175
2/24/2022 6:31	0.8	150	123	4	7.2	60	Yes	175
2/25/2022 21:51	0.8	150	117	4	7.2	61	Yes	175
2/26/2022 5:34	0.7	150	111	4	7.3	61	Yes	175
2/27/2022 10:07	0.8	150	117	6	7.3	57	Yes	175
2/28/2022 21:35	0.7	150	112	7	7.3	52	Yes	175
29	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
30	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350