

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Apr-22**
 WTP: **TP - A**

System Name **Glide Water Association**

ID#: **4100326**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.021	0.033	0.026	0.023	0.023	0.023	0.043
2	P/O	P/O	0.030	0.025	0.025	0.025	0.043
3	0.025	0.035	0.031	0.029	0.029	0.030	0.053
4	0.032	0.036	P/O	0.027	P/O	0.039	0.217
5	P/O	P/O	P/O	P/O	0.039	0.035	0.082
6	0.026	0.039	P/O	0.025	0.023	0.020	0.073
7	0.019	0.018	0.018	0.023	0.026	P/O	0.062
8	0.020	P/O	0.018	0.029	0.022	0.020	0.055
9	0.020	P/O	0.041	0.026	0.021	0.020	0.049
10	0.019	0.031	0.024	0.022	0.021	0.019	0.049
11	0.028	0.025	P/O	0.028	0.033	0.046	0.160
12	P/O	P/O	0.028	0.035	0.027	0.039	0.077
13	P/O	P/O	0.026	0.020	0.017	0.044	0.088
14	P/O	P/O	0.045	0.035	0.023	0.019	0.088
15	0.018	0.017	0.056	0.054	0.038	0.037	0.265
16	0.029	0.025	P/O	0.036	0.035	P/O	0.080
17	0.022	P/O	P/O	0.040	0.024	0.020	0.073
18	0.041	P/O	0.027	0.023	0.021	0.039	0.080
19	0.026	P/O	0.021	0.045	0.033	0.032	0.095
20	0.056	P/O	0.033	0.041	0.059	0.026	0.141
21	0.036	P/O	0.025	0.039	0.027	0.023	0.086
22	0.046	P/O	0.029	0.025	0.052	0.029	0.075
23	0.022	P/O	0.019	0.033	0.025	0.021	0.071
24	0.020	P/O	0.045	0.027	0.023	0.026	0.067
25	0.030	P/O	0.025	0.023	0.021	0.035	0.062
26	P/O	P/O	0.025	0.021	0.031	0.025	0.059
27	0.023	P/O	0.021	0.029	0.027	0.022	0.056
28	0.022	P/O	0.021	0.031	0.025	0.023	0.055
29	0.021	P/O	0.030	0.027	0.023	0.030	0.053
30	0.028	P/O	0.026	0.025	0.031	0.031	0.056
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? ² <input checked="" type="radio"/> Yes / No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (641) 643-6137	
		DATE: 5/9/22 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**
 Disinfection
 Giardia Log
 Inactive: **1.0**

System Name: **Glide Water Association** ID#: **4100326** Month/Year: **April / 22**

Date / Time	Minimum Cl ₂ Residual at 1st User (c) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
4/1/2022 5:33	0.4	150	59	9	7.2	41	Yes	175
4/2/2022 4:28	0.7	150	108	10	7.3	43	Yes	175
4/3/2022 5:00	0.9	150	130	10	7.4	43	Yes	175
4/4/2022 17:11	0.9	150	133	10	7.3	41	Yes	175
4/5/2022 13:45	0.7	150	107	9	7.1	41	Yes	175
4/6/2022 9:11	0.8	150	113	8	7.1	44	Yes	175
4/7/2022 23:06	0.9	150	128	10	7.2	41	Yes	175
4/8/2022 10:28	0.7	150	112	11	7.1	37	Yes	175
4/9/2022 7:30	0.7	150	107	10	7.2	40	Yes	175
4/10/2022 4:16	0.8	150	113	9	7.3	44	Yes	175
4/11/2022 18:11	0.7	150	112	8	7.2	45	Yes	175
4/12/2022 8:07	0.7	150	98	7	7.1	47	Yes	175
4/13/2022 7:41	0.8	150	122	7	7.1	49	Yes	175
4/14/2022 7:32	0.8	150	123	7	7.1	47	Yes	175
4/15/2022 9:37	0.8	150	119	8	7.2	48	Yes	175
4/16/2022 10:53	0.7	150	112	8	7.2	46	Yes	175
4/17/2022 8:02	0.7	150	109	8	7.2	47	Yes	175
4/18/2022 22:33	0.7	150	112	9	7.1	43	Yes	175
4/19/2022 7:42	0.7	150	101	8	7.0	42	Yes	175
4/20/2022 5:52	0.7	150	107	8	7.0	42	Yes	175
4/21/2022 5:36	0.8	150	117	9	7.1	42	Yes	175
4/22/2022 7:53	0.7	150	103	9	7.1	42	Yes	175
4/23/2022 7:42	0.7	150	112	9	7.1	41	Yes	175
4/24/2022 6:52	0.8	150	116	9	7.2	42	Yes	175
4/25/2022 15:56	0.7	150	112	9	7.1	40	Yes	175
4/26/2022 5:15	0.7	150	100	9	7.1	40	Yes	175
4/27/2022 7:41	0.7	150	109	10	7.2	42	Yes	175
4/28/2022 7:02	0.8	150	113	10	7.1	40	Yes	175
4/29/2022 6:36	0.8	150	116	9	7.2	43	Yes	175
4/30/2022 6:17	0.8	150	119	10	7.1	39	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
 OHA Director, OR 971-673-0304, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018