

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: May-22

System Name		Glide Water Association		ID#: 4100326		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	P/O	0.033	P/O	0.051	0.038	0.033	0.088
2	0.053	0.036	P/O	0.033	0.032	0.046	0.080
3	0.038	P/O	0.037	0.057	0.051	0.043	0.106
4	0.039	P/O	0.068	0.043	0.037	0.036	0.112
5	0.053	P/O	0.041	0.038	0.041	0.050	0.077
6	P/O	P/O	0.074	0.027	0.020	0.024	0.493
7	0.033	0.029	P/O	0.030	0.071	P/O	0.125
8	0.043	P/O	P/O	0.030	0.037	0.026	0.086
9	0.022	P/O	0.045	0.025	0.031	P/O	0.078
10	0.022	P/O	0.029	0.031	0.021	0.039	0.064
11	0.026	P/O	0.022	0.030	0.021	0.032	0.055
12	0.024	P/O	P/O	0.019	0.027	0.022	0.047
13	0.029	P/O	0.021	0.017	0.026	0.021	0.047
14	0.021	P/O	0.028	0.022	0.035	0.034	0.084
15	0.033	P/O	0.038	0.023	0.027	0.018	0.056
16	0.020	P/O	0.038	0.023	0.018	0.027	0.056
17	0.020	P/O	0.017	0.024	0.020	0.017	0.040
18	0.024	P/O	0.020	0.020	0.017	0.024	0.036
19	0.018	0.019	P/O	0.025	0.023	0.018	0.042
20	0.020	P/O	0.020	0.035	0.022	0.019	0.066
21	0.033	0.031	P/O	0.028	0.039	0.022	0.066
22	0.024	P/O	0.050	0.053	0.031	0.046	0.089
23	0.031	P/O	0.030	0.037	0.033	0.033	0.080
24	0.039	P/O	0.037	0.041	0.044	0.042	0.055
25	0.042	0.051	P/O	0.026	0.022	0.020	0.053
26	0.018	P/O	0.026	0.021	0.019	0.028	0.036
27	0.022	P/O	0.019	0.022	0.022	0.020	0.031
28	P/O	0.023	0.024	0.023	0.021	0.023	0.033
29	0.026	P/O	0.051	0.041	P/O	0.049	0.114
30	0.044	0.036	0.059	0.044	0.039	0.046	0.162
31	0.049	P/O	0.035	0.025	0.029	0.021	0.045

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: P/O = PLANT OFF      DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (541) 643-6137	
		DATE: 6-10-22 CERT #: 7232	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: **Glide Water Association**

ID#: **4100326**

Month/Year: *May 2022*

Disinfection  
Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (c) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
5/1/2022 8:13	0.8	150	113	9	7.2	43	Yes	175
5/2/2022 10:01	0.7	150	112	10	7.1	39	Yes	175
5/3/2022 5:55	0.7	150	108	9	7.1	42	Yes	175
5/4/2022 6:27	0.7	150	112	10	7.1	40	Yes	175
5/5/2022 7:22	0.7	150	112	11	7.1	37	Yes	175
5/6/2022 21:57	0.8	150	116	10	7.0	38	Yes	175
5/7/2022 22:00	0.7	150	109	10	6.8	36	Yes	175
5/8/2022 8:41	0.7	150	102	9	6.9	39	Yes	175
5/9/2022 21:06	0.7	150	101	8	6.9	41	Yes	175
5/10/2022 5:18	0.6	150	93	9	7.0	41	Yes	175
5/11/2022 8:20	0.8	150	116	9	7.1	41	Yes	175
5/12/2022 10:49	0.6	150	95	10	7.0	38	Yes	175
5/13/2022 7:10	0.7	150	103	9	7.1	40	Yes	175
5/14/2022 6:56	0.7	150	107	10	7.0	37	Yes	175
5/15/2022 5:47	0.7	150	101	11	7.1	37	Yes	175
5/16/2022 7:14	0.7	150	107	11	7.0	36	Yes	175
5/17/2022 8:59	0.7	150	103	11	7.1	37	Yes	175
5/18/2022 7:13	0.8	150	116	11	7.0	35	Yes	175
5/19/2022 8:38	0.8	150	116	10	7.0	38	Yes	175
5/20/2022 7:30	0.8	150	113	10	7.2	39	Yes	175
5/21/2022 8:42	0.8	150	124	11	7.2	37	Yes	175
5/22/2022 7:19	0.8	150	127	12	7.2	35	Yes	175
5/23/2022 22:44	0.8	150	118	13	7.2	33	Yes	175
5/24/2022 7:11	0.7	150	107	13	7.1	32	Yes	175
5/25/2022 8:26	0.9	150	128	13	7.2	33	Yes	175
5/26/2022 5:21	0.8	150	127	14	7.1	31	Yes	175
5/27/2022 7:17	0.8	150	121	13	7.0	31	Yes	175
5/28/2022 20:55	0.8	150	120	12	7.2	36	Yes	175
5/29/2022 17:43	0.8	150	118	11	7.1	36	Yes	175
5/30/2022 23:34	0.7	150	110	10	7.0	37	Yes	175
5/31/2022 7:17	0.7	150	104	10	7.2	39	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350