

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Douglas**  
Month/Year: **Jun-22**

System Name **Gilde Water Association** ID#: **4100326** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.021	P/O	0.029	0.021	0.027	0.020	0.038
2	0.019	P/O	0.034	0.023	0.020	0.022	0.036
3	P/O	0.018	P/O	0.025	0.018	0.018	0.034
4	0.019	P/O	0.025	0.029	0.062	0.019	0.084
5	0.018	P/O	P/O	0.026	0.024	0.024	0.069
6	0.048	P/O	0.030	0.026	0.040	0.024	0.066
7	0.021	0.020	P/O	0.028	0.023	0.021	0.049
8	0.032	P/O	0.028	0.026	0.025	0.036	0.044
9	0.030	P/O	0.018	0.019	0.019	0.019	0.049
10	0.039	0.064	P/O	0.035	0.024	0.018	0.138
11	0.017	P/O	P/O	0.022	0.019	0.023	0.117
12	0.079	P/O	P/O	0.076	0.130	0.032	0.241
13	0.031	0.049	P/O	0.083	0.100	0.046	0.147
14	0.023	0.026	P/O	0.021	P/O	0.031	0.053
15	0.022	0.027	0.108	0.039	0.019	P/O	0.162
16	0.026	0.022	P/O	0.019	0.026	0.022	0.034
17	P/O	0.019	P/O	0.028	0.022	0.019	0.036
18	0.019	P/O	0.029	0.023	0.021	0.021	0.036
19	0.026	0.023	P/O	0.023	0.023	0.029	0.040
20	0.026	P/O	0.027	0.030	0.033	0.029	0.047
21	0.035	0.038	P/O	0.025	0.017	0.022	0.557
22	0.018	P/O	0.020	0.024	0.018	0.020	0.038
23	0.021	0.019	0.023	0.025	0.023	0.021	0.036
24	0.026	0.028	0.026	0.027	0.031	0.029	0.042
25	0.031	0.037	0.034	0.028	0.021	0.018	0.047
26	0.022	0.027	0.022	0.024	0.025	0.023	0.034
27	0.027	0.029	0.029	0.032	0.030	0.031	0.046
28	0.034	0.036	0.033	0.022	0.016	0.018	0.129
29	0.018	P/O	0.029	0.020	0.019	0.017	0.036
30	0.017	0.024	0.020	0.021	0.020	0.016	0.033
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<b>PRINTED NAME: Jonathan Woody</b>	
<b>Notes: P/O = PLANT OFF DV = DIVERTED</b>		<b>SIGNATURE: <i>John Woody</i></b>	<b>DATE: 7-10-22</b>
		<b>PHONE #: ( 541 ) 643-6137</b>	<b>CERT #: 7232</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

**System Name:** **Gilde Water Association**      **ID#:4100326**      **Month/Year:** Jun-22      **Disinfection**  
*Giardia* Log Inactive: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
6/1/2022 5:40	0.7	150	107	12	7.2	36	Yes	175
6/2/2022 7:03	0.8	150	119	13	7.3	34	Yes	175
6/3/2022 9:03	0.8	150	121	13	7.2	33	Yes	175
6/4/2022 6:35	0.8	150	122	12	7.1	35	Yes	175
6/5/2022 9:33	0.8	150	125	12	7.2	36	Yes	175
6/6/2022 22:59	0.6	150	95	12	7.2	35	Yes	175
6/7/2022 7:47	0.6	150	91	12	7.2	35	Yes	175
6/8/2022 6:09	0.8	150	118	12	7.2	35	Yes	175
6/9/2022 7:15	0.8	150	116	13	7.3	33	Yes	175
6/10/2022 7:52	0.8	150	122	14	7.2	31	Yes	175
6/11/2022 8:17	0.8	150	121	14	7.1	30	Yes	175
6/12/2022 15:34	0.7	150	102	12	7.1	33	Yes	175
6/13/2022 15:27	0.7	150	110	12	6.9	33	Yes	175
6/14/2022 21:00	0.8	150	124	11	7.1	36	Yes	175
6/15/2022 7:48	0.7	150	112	12	7.2	37	Yes	175
6/16/2022 8:26	0.8	150	113	13	7.1	32	Yes	175
6/17/2022 10:56	0.8	150	115	12	7.2	35	Yes	175
6/18/2022 6:02	0.8	150	113	12	7.1	34	Yes	175
6/19/2022 9:18	0.7	150	112	12	7.1	34	Yes	175
6/20/2022 7:02	0.7	150	110	14	7.3	33	Yes	175
6/21/2022 9:35	0.7	150	104	15	7.2	29	Yes	175
6/22/2022 6:44	0.8	150	122	16	7.2	27	Yes	175
6/23/2022 4:21	0.8	150	127	16	7.3	28	Yes	175
6/24/2022 7:05	0.8	150	124	16	7.4	29	Yes	175
6/25/2022 23:47	0.8	150	118	16	7.3	28	Yes	175
6/26/2022 7:37	0.7	150	110	17	7.4	26	Yes	175
6/27/2022 23:35	0.7	150	109	18	7.3	25	Yes	175
6/28/2022 7:23	0.7	150	103	18	7.3	24	Yes	175
6/29/2022 5:55	0.7	150	101	17	7.3	25	Yes	175
6/30/2022 6:40	0.8	150	119	17	7.4	27	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dnce@state.or.us; 971-673-0894; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350