

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Douglas**  
Month/Year: **Jul-22**

System Name **Glide Water Association** ID#: **4100326** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.020	0.024	0.020	0.024	0.018	0.017	0.064
2	0.018	P/O	0.020	0.022	0.018	0.020	0.031
3	0.018	0.018	0.018	0.022	0.018	0.019	0.029
4	0.019	0.019	0.021	0.025	0.018	0.020	0.034
5	0.019	0.020	0.020	0.026	0.018	0.018	0.049
6	0.022	P/O	0.022	0.025	0.020	0.018	0.036
7	0.018	0.018	P/O	0.024	0.019	0.024	0.038
8	0.020	0.020	0.021	0.024	0.020	0.020	0.034
9	0.022	0.022	0.022	0.027	0.022	0.022	0.034
10	0.023	0.024	0.023	0.031	0.023	0.026	0.047
11	0.025	0.033	0.028	0.030	0.028	0.029	0.036
12	0.029	0.031	0.032	0.042	0.023	0.018	0.306
13	0.018	0.022	0.023	0.021	0.018	0.016	0.041
14	0.020	0.019	0.020	0.032	0.017	0.018	0.062
15	0.018	0.021	0.026	0.021	0.020	0.018	0.038
16	0.020	0.021	0.024	0.031	0.019	0.018	0.055
17	0.018	0.021	0.059	0.032	0.021	0.023	0.491
18	0.024	0.031	0.028	0.025	0.030	0.020	0.049
19	0.021	0.020	0.021	0.022	0.020	0.019	0.031
20	0.022	0.021	0.021	0.023	0.020	0.021	0.064
21	0.022	0.021	P/O	0.023	0.019	0.020	0.031
22	0.020	0.020	0.026	0.022	0.019	0.020	0.070
23	0.022	0.021	0.023	0.023	0.020	0.021	0.030
24	0.021	0.020	0.025	0.021	0.021	0.020	0.033
25	0.022	0.021	0.021	0.024	0.021	0.021	0.204
26	0.024	0.023	0.023	0.028	0.023	0.026	0.034
27	0.029	0.028	0.032	0.041	0.029	0.033	0.077
28	0.034	0.036	0.036	0.020	0.020	0.019	0.038
29	0.018	0.017	0.016	0.030	0.077	0.021	0.420
30	0.020	P/O	0.021	0.022	0.018	0.020	0.034
31	0.019	P/O	0.021	0.022	0.018	0.020	0.034

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes <input type="radio"/> No	PRINTED NAME: <b>Jonathan Woody</b>	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: <b>8-9-22</b>
		PHONE #: <b>( 541 ) 643-6137</b>	CERT #: <b>7232</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#: **4100326** Month/Year: \_\_\_\_\_  
 Disinfection  
 Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (m) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
7/1/2022 7:24	0.9	150	128	17	7.4	27	Yes	175
7/2/2022 6:40	0.9	150	128	17	7.3	26	Yes	175
7/3/2022 9:14	0.9	150	128	17	7.4	28	Yes	175
7/4/2022 23:13	0.8	150	122	18	7.4	26	Yes	175
7/5/2022 7:52	0.8	150	113	17	7.3	26	Yes	175
7/6/2022 7:25	0.8	150	124	17	7.3	27	Yes	175
7/7/2022 9:13	0.8	150	116	17	7.3	26	Yes	175
7/8/2022 6:54	0.7	150	112	18	7.4	26	Yes	175
7/9/2022 6:50	0.8	150	116	19	7.5	25	Yes	175
7/10/2022 7:05	0.8	150	115	19	6.3	16	Yes	175
7/11/2022 9:11	0.8	150	119	19	7.4	24	Yes	175
7/12/2022 23:40	0.7	150	105	20	7.6	25	Yes	175
7/13/2022 5:48	0.7	150	106	20	7.4	22	Yes	175
7/14/2022 3:35	0.7	150	110	19	7.4	23	Yes	175
7/15/2022 3:47	0.7	150	107	19	7.4	23	Yes	175
7/16/2022 6:23	0.7	150	110	19	7.4	24	Yes	175
7/17/2022 8:37	0.7	150	112	19	7.4	23	Yes	175
7/18/2022 22:54	0.7	150	110	18	7.4	25	Yes	175
7/19/2022 6:37	0.7	150	106	19	7.3	22	Yes	175
7/20/2022 7:12	0.7	150	109	20	7.3	22	Yes	175
7/21/2022 9:10	0.7	150	110	19	7.4	23	Yes	175
7/22/2022 3:25	0.7	150	112	19	7.7	26	Yes	175
7/23/2022 10:01	0.8	150	118	19	7.6	26	Yes	175
7/24/2022 1:59	0.7	150	112	19	7.6	26	Yes	175
7/25/2022 23:06	0.7	150	106	19	7.6	25	Yes	175
7/26/2022 6:33	0.7	150	107	20	7.5	23	Yes	175
7/27/2022 23:29	0.8	150	115	20	7.6	23	Yes	175
7/28/2022 8:54	0.7	150	106	20	7.7	23	Yes	175
7/29/2022 23:47	0.8	150	119	21	7.6	22	Yes	175
7/30/2022 5:56	0.7	150	110	22	7.4	19	Yes	175
7/31/2022 5:59	0.7	150	112	21	7.5	21	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dnce@state.or.us; 971-673-0894; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350