

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Aug-22**
 WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.019	0.018	0.031	0.021	0.018	0.019	0.045
2	0.018	0.019	0.024	0.021	0.019	0.018	0.042
3	0.021	0.021	0.045	0.022	0.018	0.020	0.084
4	0.019	0.019	0.030	0.024	0.019	0.022	0.042
5	0.021	0.021	0.029	0.028	0.023	0.025	0.045
6	0.025	P/O	0.032	0.039	0.029	0.030	0.056
7	0.032	0.034	0.041	0.047	0.037	0.039	0.058
8	0.043	0.046	0.033	0.028	0.017	0.018	0.051
9	0.018	0.019	0.022	0.023	0.017	0.018	0.034
10	0.018	P/O	0.020	0.026	0.018	0.018	0.038
11	0.019	0.019	0.025	0.025	0.018	0.020	0.031
12	0.019	0.019	0.026	0.027	0.019	0.019	0.052
13	0.019	0.026	0.027	0.023	0.019	0.020	0.034
14	0.019	P/O	0.027	0.030	0.020	0.019	0.040
15	0.021	0.024	0.028	0.027	0.023	0.022	0.043
16	0.022	P/O	0.028	0.030	0.018	0.018	0.044
17	0.019	0.023	0.029	0.027	0.019	0.019	0.040
18	0.019	P/O	0.025	0.038	0.022	0.021	0.056
19	0.022	0.023	0.026	0.025	0.021	0.024	0.036
20	0.024	0.025	0.027	0.031	0.027	0.027	0.040
21	0.029	0.029	0.041	0.038	0.032	0.036	0.049
22	0.037	P/O	0.044	0.044	0.037	0.018	0.110
23	0.016	0.016	0.028	0.023	0.016	0.017	0.033
24	0.018	0.018	0.022	0.021	0.016	0.017	0.031
25	0.018	P/O	0.018	0.019	0.017	0.018	0.029
26	0.017	0.016	0.017	0.024	0.016	0.016	0.033
27	0.018	P/O	0.021	0.019	0.016	0.018	0.029
28	0.018	0.018	0.022	0.025	0.018	0.018	0.034
29	0.018	P/O	0.034	0.030	0.018	0.020	0.049
30	0.021	0.023	0.024	0.037	0.023	0.023	0.053
31	0.026	0.030	0.036	0.037	0.030	0.031	0.049

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? ² <input checked="" type="radio"/> Yes / No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody	
		SIGNATURE: <i>Jonathan Woody</i>	DATE: 9/9/22
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**
 Disinfection
 Giardia Log
 Inactive **1.0**

System Name: **Glide Water Association** **ID#:4100326** **Month/Year:**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
8/1/2022 22:18	0.8	150	116	21	7.6	22	Yes	175
8/2/2022 7:29	0.7	150	110	21	7.7	23	Yes	175
8/3/2022 6:42	0.7	150	106	21	7.7	24	Yes	175
8/4/2022 6:47	0.8	150	113	20	7.7	24	Yes	175
8/5/2022 23:49	0.7	150	108	20	7.6	24	Yes	175
8/6/2022 5:13	0.7	150	101	19	7.6	25	Yes	175
8/7/2022 6:39	0.7	150	104	19	7.7	26	Yes	175
8/8/2022 6:45	0.7	150	107	20	7.7	26	Yes	175
8/9/2022 6:33	0.7	150	107	19	7.6	25	Yes	175
8/10/2022 22:10	0.8	150	116	20	7.6	24	Yes	175
8/11/2022 6:24	0.7	150	109	19	7.7	26	Yes	175
8/12/2022 6:10	0.8	150	127	19	7.6	26	Yes	175
8/13/2022 4:37	0.9	150	130	19	7.8	28	Yes	175
8/14/2022 5:57	0.9	150	131	19	7.7	27	Yes	175
8/15/2022 21:44	0.8	150	124	19	7.8	28	Yes	175
8/16/2022 6:13	0.8	150	115	19	7.7	26	Yes	175
8/17/2022 6:48	0.8	150	121	19	7.7	26	Yes	175
8/18/2022 8:41	0.8	150	122	20	7.7	26	Yes	175
8/19/2022 22:23	0.8	150	114	19	7.7	26	Yes	175
8/20/2022 6:27	0.7	150	109	19	7.8	27	Yes	175
8/21/2022 23:19	0.4	150	57	19	7.7	25	Yes	175
8/22/2022 4:37	0.3	150	45	19	7.8	25	Yes	175
8/23/2022 21:58	0.8	150	119	19	7.8	27	Yes	175
8/24/2022 6:30	0.8	150	113	19	7.8	26	Yes	175
8/25/2022 8:28	0.8	150	121	19	7.8	27	Yes	175
8/26/2022 6:14	0.8	150	118	20	7.8	26	Yes	175
8/27/2022 5:46	0.9	150	130	20	7.8	27	Yes	175
8/28/2022 23:00	0.8	150	122	19	7.8	28	Yes	175
8/29/2022 7:09	0.7	150	104	18	7.8	28	Yes	175
8/30/2022 7:55	0.8	150	119	18	7.7	28	Yes	175
8/31/2022 6:51	0.7	150	112	19	7.8	28	Yes	175

Revised July 2018

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmc@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350