

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: **Douglas**  
 Month/Year: **Sep-22**  
 WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.033	0.035	0.040	0.037	0.024	0.023	0.051
2	0.024	0.032	0.033	0.028	0.016	0.018	0.055
3	0.017	P/O	0.022	0.027	0.017	0.016	0.036
4	0.016	P/O	0.028	0.024	0.017	0.019	0.034
5	0.018	P/O	0.025	0.026	0.019	0.017	0.034
6	0.017	0.026	0.031	0.028	0.019	0.020	0.038
7	0.019	P/O	0.025	0.029	0.023	0.020	0.036
8	0.019	P/O	0.022	0.030	0.022	0.020	0.042
9	0.021	P/O	0.034	0.031	0.022	0.023	0.040
10	0.022	P/O	0.028	0.031	0.026	0.023	0.036
11	0.023	0.023	0.031	0.051	0.027	0.024	0.058
12	0.030	0.035	0.031	0.039	0.027	0.018	0.045
13	0.018	P/O	0.020	0.031	0.019	0.018	0.044
14	0.018	0.018	0.032	0.028	0.019	0.018	0.042
15	0.020	P/O	0.032	0.029	0.020	0.020	0.042
16	0.018	0.021	0.030	0.039	0.024	0.020	0.047
17	0.019	0.023	0.042	0.043	0.021	0.020	0.071
18	0.026	P/O	0.041	0.039	0.028	0.023	0.055
19	0.024	0.023	0.033	0.044	0.031	0.022	0.056
20	0.021	0.025	0.029	0.055	0.029	0.025	0.064
21	0.027	0.047	0.044	0.043	0.033	0.028	0.071
22	0.027	0.037	0.036	0.044	0.031	0.029	0.055
23	0.033	P/O	0.032	0.042	0.028	0.025	0.047
24	0.028	P/O	0.039	0.039	0.029	0.023	0.049
25	0.021	0.030	P/O	0.043	0.036	0.020	0.056
26	0.019	P/O	0.038	0.056	0.030	0.017	0.075
27	0.016	P/O	0.051	0.067	0.020	0.020	0.103
28	0.023	P/O	0.022	0.021	0.021	0.021	0.027
29	0.021	P/O	0.023	0.024	0.021	0.021	0.042
30	0.021	P/O	0.021	0.021	0.022	0.023	0.029
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF      DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 10-7-22
		PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

Disinfection  
Giardia Log  
Inactive: 1.0

System Name: Glide Water Association ID#:4100326 Month/Year:

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
	[ppm or mg/L]							
9/1/2022 6:19	0.8	150	115	18	7.7	28	Yes	175
9/2/2022 7:55	0.8	150	113	18	7.7	27	Yes	175
9/3/2022 6:16	0.8	150	118	19	7.7	27	Yes	175
9/4/2022 5:23	0.8	150	116	18	7.7	28	Yes	175
9/5/2022 21:51	0.8	150	116	18	7.8	28	Yes	175
9/6/2022 4:14	0.7	150	110	18	7.6	28	Yes	175
9/7/2022 6:43	0.8	150	116	18	7.6	27	Yes	175
9/8/2022 7:44	0.8	150	127	17	7.6	28	Yes	175
9/9/2022 5:55	0.8	150	118	17	7.7	30	Yes	175
9/10/2022 4:26	0.8	150	122	17	7.6	30	Yes	175
9/11/2022 3:29	0.8	150	123	17	7.5	28	Yes	175
9/12/2022 12:09	0.8	150	122	17	7.5	29	Yes	175
9/13/2022 4:20	0.8	150	121	17	7.7	31	Yes	175
9/14/2022 4:39	0.8	150	118	16	7.6	31	Yes	175
9/15/2022 6:50	0.8	150	119	16	7.6	31	Yes	175
9/16/2022 6:26	0.8	150	115	16	7.6	31	Yes	175
9/17/2022 5:48	0.8	150	122	15	7.6	32	Yes	175
9/18/2022 6:30	0.9	150	128	15	7.6	34	Yes	175
9/19/2022 17:18	0.5	150	79	14	7.5	33	Yes	175
9/20/2022 0:38	0.7	150	104	15	7.5	32	Yes	175
9/21/2022 23:21	0.8	150	119	14	7.5	33	Yes	175
9/22/2022 0:40	0.8	150	118	14	7.5	34	Yes	175
9/23/2022 7:14	0.8	150	113	14	7.5	34	Yes	175
9/24/2022 23:18	0.7	150	103	14	7.5	34	Yes	175
9/25/2022 8:39	0.6	150	95	14	7.6	34	Yes	175
9/26/2022 6:33	0.6	150	92	15	7.5	32	Yes	175
9/27/2022 5:33	0.7	150	100	15	7.4	32	Yes	175
9/28/2022 7:00	0.7	150	109	15	7.5	32	Yes	175
9/29/2022 13:15	0.9	150	131	15	7.5	33	Yes	175
9/30/2022 4:25	0.9	150	133	14	7.6	35	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp.dmce@state.or.us: 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350