

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Douglas**  
Month/Year: **Oct-22**  
WTP : TP - **A**

System Name **Glide Water Association** ID#: **4100326**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.023	0.019	0.019	0.019	0.018	0.018	0.021
2	0.018	0.023	0.021	0.019	0.018	0.018	0.044
3	0.018	0.018	0.025	0.020	0.018	0.019	0.044
4	0.018	0.018	0.019	0.023	0.020	0.020	0.044
5	0.020	P/O	0.021	0.023	0.020	0.021	0.058
6	0.020	0.020	0.020	0.023	0.021	0.020	0.056
7	0.021	0.020	0.021	0.021	0.023	0.018	0.049
8	0.018	0.018	0.017	0.017	0.019	0.018	0.042
9	0.018	0.018	0.017	0.017	0.020	0.018	0.045
10	0.018	0.018	0.018	0.018	0.017	0.020	0.044
11	0.018	0.018	0.018	0.018	0.018	0.018	0.042
12	0.020	P/O	0.019	0.019	0.018	0.018	0.020
13	0.018	0.021	0.020	0.020	0.018	0.018	0.025
14	0.018	0.018	0.022	0.022	0.019	0.019	0.042
15	0.019	0.019	P/O	0.023	0.021	0.019	0.044
16	0.019	0.020	0.021	0.025	0.022	0.021	0.045
17	0.021	0.021	0.025	0.031	0.030	0.029	0.049
18	0.029	P/O	0.029	0.028	0.031	0.030	0.049
19	0.029	0.029	0.029	0.030	0.030	0.030	0.049
20	0.031	0.030	0.029	0.031	0.030	0.029	0.034
21	P/O	0.029	P/O	P/O	0.070	0.031	0.212
22	0.030	P/O	P/O	0.035	0.054	0.031	0.156
23	0.032	P/O	0.034	0.035	0.039	0.042	0.055
24	0.037	P/O	0.038	0.041	0.055	P/O	0.369
25	0.126	0.211	0.118	0.040	0.043	0.046	0.271
26	P/O	P/O	P/O	0.082	0.060	0.042	0.152
27	0.071	P/O	0.110	0.132	0.044	0.051	0.202
28	0.099	P/O	0.053	0.046	0.054	0.060	0.149
29	0.054	P/O	0.065	0.082	0.085	0.064	0.105
30	0.065	0.079	P/O	0.146	0.141	0.048	0.210
31	0.101	P/O	0.079	0.065	P/O	0.043	0.103

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: <b>Jonathan Woody</b>	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>John Woody</i>	DATE: <b>11-4-22</b>
		PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

**System Name:** **Glide Water Association**      **ID#:4100326**      **Month/Year:** *Oct. 2022*      **Disinfection**  
Giardia Log Inactive: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
10/1/2022 7:50	0.9	150	130	14	7.6	35	Yes	175
10/2/2022 2:50	0.9	150	133	14	7.5	35	Yes	175
10/3/2022 22:07	0.8	150	116	14	7.5	35	Yes	175
10/4/2022 3:25	0.8	150	113	14	7.6	35	Yes	175
10/5/2022 4:16	0.8	150	116	14	7.6	36	Yes	175
10/6/2022 7:42	0.8	150	119	14	7.5	35	Yes	175
10/7/2022 7:31	0.8	150	121	14	7.6	36	Yes	175
10/8/2022 4:05	0.8	150	124	14	7.6	37	Yes	175
10/9/2022 7:18	0.8	150	125	13	7.6	38	Yes	175
10/10/2022 21:36	0.8	150	122	13	7.6	37	Yes	175
10/11/2022 7:16	0.8	150	118	13	7.5	36	Yes	175
10/12/2022 23:09	0.8	150	115	13	7.5	38	Yes	175
10/13/2022 20:45	0.7	150	98	12	7.5	38	Yes	175
10/14/2022 6:12	0.6	150	94	12	7.6	40	Yes	175
10/15/2022 8:16	0.8	150	124	12	7.5	39	Yes	175
10/16/2022 6:53	0.8	150	127	12	7.5	39	Yes	175
10/17/2022 21:40	0.8	150	119	12	7.6	41	Yes	175
10/18/2022 5:08	0.8	150	115	12	7.5	40	Yes	175
10/19/2022 7:21	0.8	150	119	12	7.5	39	Yes	175
10/20/2022 7:45	0.8	150	122	12	7.4	39	Yes	175
10/21/2022 16:05	0.8	150	122	12	7.5	40	Yes	175
10/22/2022 23:04	0.8	150	115	11	7.2	37	Yes	175
10/23/2022 6:58	0.7	150	109	11	7.1	37	Yes	175
10/24/2022 6:42	0.7	150	106	11	7.1	36	Yes	175
10/25/2022 8:20	0.6	150	97	10	7.1	37	Yes	175
10/26/2022 21:52	0.7	150	100	11	7.2	38	Yes	175
10/27/2022 7:18	0.6	150	89	10	7.3	41	Yes	175
10/28/2022 6:31	0.7	150	98	10	7.2	41	Yes	175
10/29/2022 17:20	0.7	150	98	10	7.2	41	Yes	175
10/30/2022 20:44	0.6	150	83	10	7.4	42	Yes	175
10/31/2022 6:50	0.5	150	79	10	7.3	40	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

**Return by 10th of following month by email, fax, or mail to:**

Revised July 2018

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350