

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Dec-22

System Name		Glide Water Association					ID#: 4100326	WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.061	P/O	P/O	0.149	0.138	0.094	0.417	
2	0.106	0.127	0.053	0.080	0.062	0.105	0.304	
3	0.049	0.080	0.174	0.103	0.034	0.045	0.232	
4	0.078	0.045	0.049	0.060	0.035	0.046	0.138	
5	0.037	0.124	0.070	0.139	0.024	0.023	0.291	
6	0.028	0.024	0.025	0.022	0.028	0.022	0.040	
7	0.021	0.021	0.033	0.034	0.023	0.022	0.043	
8	0.025	P/O	0.029	0.035	0.024	0.023	0.047	
9	0.024	P/O	0.030	0.026	0.023	0.024	0.058	
10	0.028	0.034	0.034	0.027	0.031	0.052	0.225	
11	0.108	0.032	0.028	0.038	0.078	0.111	0.132	
12	P/O	P/O	P/O	0.133	0.038	0.102	0.223	
13	0.041	0.061	0.039	0.047	0.068	0.063	0.238	
14	P/O	P/O	P/O	0.031	0.025	0.027	0.084	
15	0.037	0.051	0.054	0.028	0.019	0.019	0.078	
16	0.019	0.020	0.020	0.029	0.019	0.017	0.124	
17	0.018	0.019	P/O	0.029	0.031	0.028	0.041	
18	0.030	0.042	0.040	0.101	0.027	0.021	0.249	
19	0.021	0.024	0.024	0.029	0.034	0.023	0.062	
20	0.029	P/O	0.029	0.098	0.019	0.019	0.225	
21	0.018	P/O	0.018	0.021	0.035	0.026	0.060	
22	0.027	P/O	0.042	0.035	0.043	0.042	0.078	
23	0.030	0.042	0.060	0.034	0.034	0.050	0.082	
24	0.031	P/O	0.046	0.041	0.051	0.045	0.097	
25	0.044	0.032	P/O	0.046	0.055	0.045	0.112	
26	0.085	0.048	0.033	0.043	0.057	0.037	0.143	
27	0.057	P/O	0.067	0.044	0.069	0.099	0.225	
28	P/O	P/O	0.064	0.099	0.099	0.075	0.223	
29	0.087	0.074	0.060	0.059	0.074	0.116	0.202	
30	0.046	P/O	0.066	0.084	0.081	0.088	0.204	
31	0.091	0.055	P/O	0.095	0.074	0.059	0.202	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 1-9-23
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

System Name: Gilde Water Association	ID#: 4100326	Month/Year: Dec-22	Disinfection Giardia Log Inactive: 1.0
---	---------------------	---------------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
12/1/2022 10:39	0.8	150	119	7	7.3	52	Yes	175
12/2/2022 9:40	0.7	150	104	6	7.2	50	Yes	175
12/3/2022 1:47	0.7	150	108	6	7.1	51	Yes	175
12/4/2022 7:31	0.8	150	114	6	7.2	52	Yes	175
12/5/2022 6:33	0.8	150	117	6	7.5	59	Yes	175
12/6/2022 21:08	0.8	150	125	6	7.5	58	Yes	175
12/7/2022 6:59	0.8	150	119	6	7.5	61	Yes	175
12/8/2022 5:48	0.9	150	131	6	7.3	56	Yes	175
12/9/2022 22:55	0.8	150	113	6	7.3	55	Yes	175
12/10/2022 0:31	0.8	150	113	6	7.2	51	Yes	175
12/11/2022 16:15	0.6	150	97	7	8.0	65	Yes	175
12/12/2022 7:50	0.6	150	91	7	7.7	57	Yes	175
12/13/2022 18:44	0.6	150	88	7	7.1	47	Yes	175
12/14/2022 8:20	0.5	150	77	6	7.4	55	Yes	175
12/15/2022 22:52	0.7	150	110	5	7.4	59	Yes	175
12/16/2022 1:04	0.7	150	108	5	7.5	64	Yes	175
12/17/2022 21:25	0.8	150	113	4	7.3	62	Yes	175
12/18/2022 23:44	0.7	150	105	4	7.2	61	Yes	175
12/19/2022 5:25	0.7	150	104	4	7.3	60	Yes	175
12/20/2022 7:28	0.8	150	123	5	7.3	58	Yes	175
12/21/2022 19:39	0.8	150	126	7	7.3	53	Yes	175
12/22/2022 7:21	0.8	150	119	7	7.4	53	Yes	175
12/23/2022 2:02	0.8	150	119	8	7.3	49	Yes	175
12/24/2022 9:33	0.8	150	122	8	7.3	49	Yes	175
12/25/2022 9:54	0.8	150	125	8	7.2	46	Yes	175
12/26/2022 1:37	0.8	150	125	9	7.2	44	Yes	175
12/27/2022 8:41	0.8	150	119	9	7.2	43	Yes	175
12/28/2022 10:15	0.7	150	110	9	7.0	41	Yes	175
12/29/2022 23:04	0.8	150	126	8	7.3	48	Yes	175
12/30/2022 23:34	0.7	150	109	8	7.1	43	Yes	175
12/31/2022 9:35	0.7	150	101	9	7.0	40	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350