

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: **Douglas**  
 Month/Year: **Feb-23**

System Name **Glide Water Association** ID#: **4100326** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.023	0.020	0.018	0.019	0.017	0.018	0.023
2	0.017	0.018	0.028	0.024	0.019	0.017	0.034
3	0.017	0.017	0.017	0.026	0.019	0.018	0.047
4	0.018	0.018	P/O	0.018	0.018	0.018	0.018
5	0.017	P/O	0.018	0.023	0.019	0.018	0.045
6	0.018	0.018	0.018	0.018	0.029	0.025	0.154
7	0.024	P/O	0.024	0.024	0.023	0.023	0.027
8	0.023	P/O	0.024	0.031	0.026	0.024	0.060
9	0.024	0.024	0.024	0.025	0.028	0.029	0.058
10	0.027	0.025	0.026	0.025	0.024	0.031	0.058
11	0.026	0.027	0.027	0.027	0.025	0.032	0.040
12	0.028	P/O	0.025	0.025	0.024	0.023	0.042
13	0.030	0.027	0.026	0.027	0.026	0.027	0.049
14	0.026	P/O	0.025	0.027	0.032	0.041	0.064
15	0.037	0.035	0.033	0.034	0.032	0.040	0.066
16	0.035	0.035	0.034	0.034	0.033	0.032	0.040
17	0.032	0.031	0.032	0.032	0.041	0.034	0.067
18	0.034	P/O	0.033	0.033	0.032	0.031	0.036
19	0.032	0.032	P/O	0.044	0.035	0.033	0.080
20	0.033	P/O	0.033	0.033	0.035	0.037	0.062
21	0.036	P/O	0.025	0.017	0.028	0.021	0.049
22	0.018	P/O	0.017	0.017	0.018	0.017	0.019
23	0.018	0.019	0.019	0.025	0.028	0.021	0.045
24	0.026	P/O	0.026	0.041	0.030	0.026	0.084
25	0.022	0.037	0.024	0.033	0.043	0.021	0.075
26	0.028	0.025	P/O	0.023	0.039	0.028	0.084
27	0.025	P/O	0.022	0.027	0.027	0.026	0.086
28	0.044	P/O	0.022	0.024	0.023	0.026	0.030
29	No Data	No Data	No Data	No Data	No Data	No Data	0.000
30	No Data	No Data	No Data	No Data	No Data	No Data	0.000
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

<b>Conventional or Direct Filtration</b> 95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: <b>Jonathan Woody</b>	
		SIGNATURE: <i>Jonathan Woody</i>	DATE: <b>3-3-23</b>
		PHONE #: <b>( 541 ) 643-6137</b>	CERT #: <b>7232</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#: **4100326** Month/Year: **Feb-23** Disinfection Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/2023 7:37	0.8	150	116	4	7.5	70	Yes	175
2/2/2023 9:55	0.8	150	120	4	7.6	69	Yes	175
2/3/2023 8:13	0.8	150	120	4	7.5	66	Yes	175
2/4/2023 18:37	0.8	150	117	6	7.6	61	Yes	175
2/5/2023 14:24	0.8	150	117	6	7.6	58	Yes	175
2/6/2023 15:29	0.7	150	99	7	7.6	56	Yes	175
2/7/2023 6:57	0.7	150	111	7	7.5	56	Yes	175
2/8/2023 21:10	0.8	150	119	6	7.5	57	Yes	175
2/9/2023 7:25	0.8	150	114	7	7.5	56	Yes	175
2/10/2023 8:53	0.8	150	120	7	7.5	56	Yes	175
2/11/2023 6:48	0.9	150	131	7	7.5	55	Yes	175
2/12/2023 9:49	0.9	150	131	7	7.5	55	Yes	175
2/13/2023 9:34	0.9	150	130	7	7.5	56	Yes	175
2/14/2023 21:10	0.8	150	120	6	7.5	59	Yes	175
2/15/2023 7:53	0.8	150	117	5	7.6	64	Yes	175
2/16/2023 7:16	0.9	150	129	5	7.6	67	Yes	175
2/17/2023 4:32	0.9	150	137	5	7.6	66	Yes	175
2/18/2023 5:26	0.9	150	138	5	7.6	66	Yes	175
2/19/2023 1:16	0.9	150	141	5	7.6	64	Yes	175
2/20/2023 21:11	0.9	150	129	6	7.6	60	Yes	175
2/21/2023 8:41	0.8	150	117	6	7.5	61	Yes	175
2/22/2023 6:38	0.8	150	117	5	7.5	62	Yes	175
2/23/2023 19:51	0.8	150	116	5	7.6	65	Yes	175
2/24/2023 8:11	0.8	150	116	5	7.5	64	Yes	175
2/25/2023 0:31	0.8	150	123	5	7.5	65	Yes	175
2/26/2023 1:40	0.9	150	129	5	7.5	64	Yes	175
2/27/2023 22:07	0.8	150	121	5	7.5	64	Yes	175
2/28/2023 7:28	0.8	150	117	5	7.6	66	Yes	175
29	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
30	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350