

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
Month/Year: **Mar-23**
WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.030	0.044	0.027	0.044	0.031	0.025	0.091
2	0.028	P/O	0.026	0.037	0.032	0.023	0.106
3	0.022	0.023	0.025	0.023	0.025	0.036	0.078
4	0.026	P/O	P/O	0.025	0.023	0.023	0.027
5	P/O	0.063	P/O	0.043	0.024	0.023	0.088
6	0.042	0.041	0.032	0.032	0.026	0.021	0.053
7	0.024	P/O	0.049	0.025	0.023	0.021	0.071
8	0.023	0.022	0.031	0.040	0.027	0.021	0.089
9	0.022	P/O	0.022	0.024	0.032	0.028	0.073
10	0.024	P/O	0.024	0.028	0.029	0.031	0.093
11	0.048	0.031	0.037	0.063	0.135	0.049	0.188
12	0.061	P/O	P/O	0.074	0.052	0.063	0.195
13	0.107	0.048	0.051	0.074	0.097	0.102	0.193
14	P/O	P/O	0.157	0.119	0.112	0.072	0.206
15	0.107	0.058	0.076	0.111	0.043	0.038	0.201
16	0.051	0.071	0.085	0.096	0.033	0.029	0.201
17	0.029	0.032	0.029	0.040	0.059	0.037	0.073
18	0.029	0.102	P/O	0.062	0.025	0.022	0.894
19	0.020	0.021	0.025	0.035	0.063	0.161	0.249
20	0.035	0.029	P/O	0.027	0.033	0.038	0.073
21	0.030	P/O	0.035	0.047	0.070	0.031	0.097
22	0.025	0.025	0.023	0.024	0.025	0.027	0.034
23	0.032	0.034	0.039	0.033	0.025	0.022	0.075
24	0.022	0.022	0.023	0.028	0.032	0.023	0.067
25	0.025	0.026	P/O	0.030	0.038	0.031	0.078
26	0.024	0.025	0.022	0.023	0.024	0.024	0.034
27	0.030	0.034	0.030	0.039	0.026	0.023	0.080
28	0.023	P/O	0.022	0.023	0.036	0.028	0.077
29	0.023	P/O	P/O	0.024	0.029	0.040	0.055
30	0.045	0.069	0.074	0.074	0.041	0.029	0.088
31	0.037	P/O	0.057	0.028	0.024	0.023	0.195

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 4-8-23
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

System Name: **Glide Water Association** **ID#:4100326** **Month/Year:** _____

Disinfection
Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (m)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
3/1/2023 0:37	0.8	150	123	4	7.6	67	Yes	175
3/2/2023 20:20	0.7	150	104	5	7.6	65	Yes	175
3/3/2023 7:18	0.7	150	104	5	7.8	69	Yes	175
3/4/2023 8:59	0.8	150	126	5	7.8	68	Yes	175
3/5/2023 8:58	0.9	150	128	5	7.8	71	Yes	175
3/6/2023 22:33	0.8	150	123	5	7.9	72	Yes	175
3/7/2023 18:19	0.8	150	120	5	7.9	70	Yes	175
3/8/2023 16:47	0.8	150	120	5	7.9	72	Yes	175
3/9/2023 16:40	0.8	150	117	5	7.8	70	Yes	175
3/10/2023 20:35	0.7	150	111	6	7.7	64	Yes	175
3/11/2023 9:27	0.7	150	110	6	7.7	64	Yes	175
3/12/2023 8:55	0.7	150	108	6	7.7	60	Yes	175
3/13/2023 10:23	0.7	150	104	7	7.6	56	Yes	175
3/14/2023 7:57	0.6	150	89	6	7.4	55	Yes	175
3/15/2023 8:35	0.7	150	98	7	7.5	55	Yes	175
3/16/2023 7:23	0.7	150	98	6	7.5	58	Yes	175
3/17/2023 13:31	0.7	150	112	7	7.6	55	Yes	175
3/18/2023 9:13	0.7	150	105	7	8.4	73	Yes	175
3/19/2023 10:42	0.7	150	104	8	8.0	62	Yes	175
3/20/2023 23:39	0.7	150	103	7	8.0	64	Yes	175
3/21/2023 9:17	0.6	150	94	7	8.1	64	Yes	175
3/22/2023 7:13	0.8	150	119	8	7.6	54	Yes	175
3/23/2023 22:36	0.8	150	114	6	7.5	58	Yes	175
3/24/2023 13:28	0.7	150	110	6	8.0	71	Yes	175
3/25/2023 9:56	0.8	150	113	6	7.9	68	Yes	175
3/26/2023 8:30	0.8	150	114	6	8.0	71	Yes	175
3/27/2023 7:08	0.8	150	122	6	7.8	66	Yes	175
3/28/2023 11:50	0.8	150	122	6	7.6	60	Yes	175
3/29/2023 8:09	0.8	150	116	7	7.6	58	Yes	175
3/30/2023 8:10	0.8	150	114	7	7.5	55	Yes	175
3/31/2023 6:33	0.8	150	116	7	7.8	59	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@state.or.us; 971-673-0684; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350