

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Aug-23

System Name		Glide Water Association					ID#: 4100326	WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.023	0.021	0.022	0.021	0.021	0.022	0.051	
2	0.023	0.022	0.021	0.020	0.021	0.022	0.047	
3	0.023	0.022	0.022	0.020	0.022	0.022	0.033	
4	0.022	0.022	0.022	0.021	0.022	0.023	0.060	
5	0.024	P/O	0.024	0.023	0.023	0.028	0.053	
6	0.026	0.026	0.028	0.029	0.031	0.035	0.064	
7	0.038	0.039	0.038	0.023	0.023	0.025	0.059	
8	0.026	0.023	0.024	0.025	0.026	0.026	0.046	
9	0.025	0.025	0.025	0.021	0.020	0.023	0.026	
10	0.022	0.020	0.024	0.021	0.020	0.024	0.042	
11	0.023	P/O	0.021	0.022	0.021	0.023	0.047	
12	0.024	0.022	0.021	0.022	0.022	0.024	0.048	
13	0.025	0.022	0.022	0.023	0.023	0.026	0.051	
14	0.027	0.025	0.026	0.027	0.030	0.034	0.083	
15	0.036	0.037	0.039	0.024	0.024	0.026	0.065	
16	0.024	0.022	0.025	0.023	0.021	0.024	0.042	
17	0.022	0.023	0.023	0.022	0.021	0.023	0.038	
18	0.022	0.023	0.022	0.023	0.022	0.024	0.044	
19	0.025	0.023	0.023	0.025	0.026	0.028	0.051	
20	0.030	0.030	0.031	0.034	0.035	0.040	0.060	
21	0.045	0.047	0.044	0.025	0.025	0.028	0.056	
22	0.028	0.027	0.027	0.027	0.027	0.027	0.028	
23	0.027	0.027	0.027	0.027	0.027	0.027	0.027	
24	0.027	0.027	0.027	0.022	0.021	0.024	0.047	
25	0.022	0.020	0.021	0.023	0.021	0.022	0.047	
26	0.023	0.022	0.021	0.020	0.022	0.022	0.038	
27	0.022	0.021	0.023	0.022	0.022	0.025	0.046	
28	0.023	0.022	0.022	0.022	0.022	0.023	0.046	
29	0.023	0.022	0.021	0.022	0.024	0.025	0.038	
30	0.024	0.025	0.027	0.026	0.026	0.030	0.048	
31	0.030	0.031	0.032	0.022	0.022	0.021	0.044	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes/No	Yes/No	Yes/No
All turbidity readings < IFE ² triggers	Yes/No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 9-5-23
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#: **4100326** Month/Year: _____
 Disinfection
 Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
8/1/2023 9:24	0.4	150	63	20	8.6	35	Yes	175
8/2/2023 10:23	0.6	150	93	20	8.7	35	Yes	175
8/3/2023 6:53	0.8	150	119	20	8.7	36	Yes	175
8/4/2023 21:28	0.8	150	121	20	8.6	35	Yes	175
8/5/2023 10:27	0.7	150	107	20	8.5	33	Yes	175
8/6/2023 9:36	0.7	150	109	20	8.6	35	Yes	175
8/7/2023 8:51	0.7	150	110	20	8.6	35	Yes	175
8/8/2023 22:23	0.8	150	119	20	8.5	34	Yes	175
8/9/2023 8:47	0.7	150	107	20	8.6	35	Yes	175
8/10/2023 9:25	0.8	150	116	20	8.5	34	Yes	175
8/11/2023 11:03	0.7	150	105	20	8.5	33	Yes	175
8/12/2023 9:07	0.7	150	101	20	8.6	35	Yes	175
8/13/2023 10:11	0.6	150	90	20	8.6	34	Yes	175
8/14/2023 9:19	0.6	150	90	21	8.6	33	Yes	175
8/15/2023 8:59	0.6	150	85	21	8.6	31	Yes	175
8/16/2023 9:01	0.8	150	116	21	8.6	32	Yes	175
8/17/2023 8:14	0.9	150	130	20	8.3	30	Yes	175
8/18/2023 10:49	0.9	150	130	19	8.6	36	Yes	175
8/19/2023 10:27	0.9	150	130	19	8.6	38	Yes	175
8/20/2023 14:58	0.9	150	134	19	8.6	38	Yes	175
8/21/2023 15:49	0.8	150	121	18	8.5	37	Yes	175
8/22/2023 6:59	0.8	150	122	18	8.4	37	Yes	175
8/23/2023 11:12	0.9	150	133	18	8.5	38	Yes	175
8/24/2023 11:43	0.9	150	131	18	8.4	38	Yes	175
8/25/2023 14:01	0.8	150	119	19	8.4	35	Yes	175
8/26/2023 11:14	0.8	150	115	19	8.3	34	Yes	175
8/27/2023 13:49	0.8	150	116	19	8.4	35	Yes	175
8/28/2023 10:44	0.8	150	119	18	8.4	35	Yes	175
8/29/2023 11:38	0.8	150	121	18	8.5	38	Yes	175
8/30/2023 10:58	0.8	150	119	18	8.4	37	Yes	175
8/31/2023 9:12	0.8	150	125	17	8.1	34	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350