

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Dec-23

System Name Glide Water Association ID#: 4100326 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.021	0.030	0.030	0.020	P/O	P/O	0.300
2	0.030	0.030	0.030	0.030	P/O	P/O	0.030
3	0.036	0.040	0.030	0.030	0.030	P/O	0.057
4	0.041	0.030	0.040	0.030	0.020	0.030	0.107
5	0.041	0.039	0.032	0.048	0.030	0.028	0.107
6	0.034	0.112	0.040	0.031	0.027	0.047	0.243
7	P/O	P/O	P/O	0.036	0.048	0.036	0.107
8	0.053	0.036	P/O	0.058	0.036	0.047	0.109
9	0.051	0.042	P/O	0.064	0.035	0.031	0.105
10	0.052	P/O	0.071	0.036	0.031	0.031	0.105
11	0.052	0.055	0.041	0.054	0.085	0.101	0.808
12	0.122	0.041	0.081	0.048	0.034	0.049	0.234
13	0.043	0.094	P/O	0.026	0.041	0.053	0.243
14	0.025	P/O	0.021	0.030	0.062	0.026	0.085
15	0.021	0.025	0.022	0.025	0.034	0.027	0.070
16	0.020	P/O	0.019	0.020	0.024	0.033	0.075
17	0.051	P/O	0.045	0.024	0.020	0.018	0.075
18	0.020	P/O	0.021	0.027	0.029	0.020	0.062
19	0.018	0.018	P/O	0.018	0.018	0.020	0.023
20	0.023	P/O	P/O	0.023	0.018	0.018	0.057
21	0.017	P/O	0.018	0.021	0.035	0.027	0.051
22	0.019	0.018	P/O	0.018	0.018	0.021	0.036
23	0.026	0.034	0.041	0.051	0.025	0.018	0.066
24	0.018	P/O	P/O	0.019	0.025	0.030	0.059
25	0.020	0.018	P/O	0.018	0.018	0.019	0.021
26	0.020	P/O	P/O	0.029	0.037	0.020	0.055
27	P/O	P/O	0.018	0.018	0.018	0.019	0.027
28	0.023	0.025	0.033	0.031	0.020	0.018	0.049
29	0.018	P/O	0.018	0.018	0.019	0.020	0.025
30	0.022	0.026	P/O	0.028	0.024	0.018	0.046
31	0.018	0.018	0.018	0.018	0.025	0.025	0.042

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 11/01/24
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#:4100326 Month/Year: Dec-23

Disinfection
Giardia Log Inactive: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
12/1/2023 0:46	0.9	150	141	4	7.8	74	Yes	175
12/2/2023 0:30	0.9	150	135	10	7.8	51	Yes	175
12/3/2023 0:31	0.8	150	113	10	8.3	59	Yes	175
12/4/2023 0:32	0.8	150	119	11	8.4	59	Yes	175
12/5/2023 3:06	0.8	150	115	10	8.4	60	Yes	175
12/6/2023 2:52	0.8	150	121	10	8.3	59	Yes	175
12/7/2023 23:45	0.8	150	123	9	8.2	62	Yes	175
12/8/2023 12:22	0.8	150	116	9	8.8	79	Yes	175
12/9/2023 0:32	0.8	150	117	8	8.8	82	Yes	175
12/10/2023 7:54	0.9	150	128	8	8.5	73	Yes	175
12/11/2023 21:08	0.8	150	121	9	8.5	69	Yes	175
12/12/2023 7:58	0.8	150	113	9	7.9	56	Yes	175
12/13/2023 9:30	0.8	150	116	8	7.9	59	Yes	175
12/14/2023 7:39	0.8	150	120	8	7.9	59	Yes	175
12/15/2023 21:37	0.8	150	120	8	7.9	62	Yes	175
12/16/2023 8:12	0.8	150	117	7	8.0	64	Yes	175
12/17/2023 7:41	0.8	150	117	7	8.0	67	Yes	175
12/18/2023 7:31	0.8	150	126	7	8.0	66	Yes	175
12/19/2023 9:34	0.8	150	119	9	8.0	59	Yes	175
12/20/2023 8:13	0.8	150	115	8	8.0	63	Yes	175
12/21/2023 8:04	0.8	150	126	7	8.0	63	Yes	175
12/22/2023 23:32	0.8	150	122	7	7.9	66	Yes	175
12/23/2023 8:02	0.8	150	117	6	7.6	61	Yes	175
12/24/2023 9:46	0.8	150	117	6	7.6	61	Yes	175
12/25/2023 23:33	0.8	150	121	6	7.7	61	Yes	175
12/26/2023 8:04	0.8	150	119	7	7.7	58	Yes	175
12/27/2023 8:35	0.8	150	119	8	7.7	56	Yes	175
12/28/2023 10:27	0.8	150	115	8	7.7	54	Yes	175
12/29/2023 7:23	0.8	150	116	8	7.7	55	Yes	175
12/30/2023 11:29	0.8	150	118	9	7.7	53	Yes	175
12/31/2023 8:14	0.8	150	113	9	7.7	53	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmo@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350