

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **Douglas**  
 Month/Year: **Feb-24**

Conventional or Direct Filtration

System Name **Glide Water Association** ID#: **4100326** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.030	P/O	0.040	0.060	0.030	P/O	0.060
2	P/O	P/O	P/O	P/O	0.060	0.030	0.060
3	P/O	0.026	P/O	P/O	0.030	0.030	0.030
4	P/O	P/O	P/O	0.030	0.020	P/O	0.030
5	P/O	P/O	P/O	P/O	0.048	0.040	0.048
6	P/O	P/O	P/O	0.024	0.024	P/O	0.024
7	0.030	0.030	P/O	P/O	P/O	0.035	0.035
8	0.041	P/O	0.072	0.047	0.027	0.025	0.105
9	0.025	0.025	P/O	P/O	0.028	0.045	0.073
10	0.030	0.025	P/O	0.025	0.026	0.029	0.034
11	0.032	0.042	P/O	0.040	0.026	0.025	0.066
12	0.023	P/O	0.023	0.025	0.029	0.032	0.047
13	0.039	0.047	P/O	0.031	0.025	0.024	0.070
14	0.024	0.024	P/O	0.025	0.027	0.034	0.059
15	0.048	P/O	0.056	0.033	0.026	0.032	0.245
16	0.106	P/O	P/O	0.082	0.064	0.050	0.190
17	0.046	P/O	0.040	0.055	0.031	0.037	0.090
18	0.040	P/O	0.028	0.030	0.044	0.041	0.068
19	0.025	0.025	0.026	0.033	0.047	0.027	0.062
20	0.025	0.023	0.025	0.033	0.046	0.064	0.118
21	0.026	0.025	0.024	0.023	0.024	0.028	0.042
22	0.033	0.041	0.068	0.042	0.025	0.022	0.103
23	0.023	0.024	P/O	0.029	0.036	0.046	0.059
24	0.026	P/O	0.023	0.021	0.021	0.021	0.023
25	0.022	0.025	0.027	0.032	0.053	0.041	0.072
26	0.027	P/O	0.023	0.023	0.023	0.023	0.027
27	0.025	0.029	P/O	0.033	0.025	0.025	0.059
28	0.028	0.038	0.043	0.031	0.025	0.025	0.055
29	0.026	P/O	0.026	0.057	0.033	0.065	0.138
30	No Data	No Data	No Data	No Data	No Data	No Data	0.000
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

<b>Conventional or Direct Filtration</b> 95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No Notes: P/O = PLANT OFF      DV = DIVERTED		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No      All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No PRINTED NAME: <b>Jonathan Woody</b> SIGNATURE: <i>Jonathan Woody</i> DATE: <b>3-8-24</b> PHONE #: ( 541 ) 643-6137      CERT #: 7232	
---	--	---	--

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#:4100326 Month/Year: **Feb 2024**  
 Disinfection: Giardia Log Inactive: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	0.9	150	135	8	7.9	60	Yes	175
2	0.9	150	140	8	8.0	64	Yes	175
3	0.9	150	128	9	7.9	56	Yes	175
4	0.9	150	131	7	8.0	65	Yes	175
5	0.9	150	128	7	7.9	63	Yes	175
6	0.9	150	129	8	7.9	59	Yes	175
7	0.9	150	137	8	7.9	60	Yes	175
2/8/2024 4:56	0.9	150	141	8	8.1	66	Yes	175
2/9/2024 16:25	0.8	150	119	8	8.1	64	Yes	175
2/10/2024 9:27	0.8	150	122	7	7.8	61	Yes	175
2/11/2024 9:00	0.8	150	121	7	7.9	62	Yes	175
2/12/2024 20:51	0.8	150	118	8	8.0	61	Yes	175
2/13/2024 10:51	0.8	150	113	8	7.9	60	Yes	175
2/14/2024 10:39	0.8	150	118	7	7.8	60	Yes	175
2/15/2024 18:44	0.8	150	115	7	7.8	59	Yes	175
2/16/2024 8:55	0.6	150	94	8	8.1	60	Yes	175
2/17/2024 7:58	0.8	150	125	9	8.1	61	Yes	175
2/18/2024 7:14	0.9	150	135	9	8.2	62	Yes	175
2/19/2024 21:00	0.8	150	127	9	8.3	66	Yes	175
2/20/2024 7:18	0.8	150	120	9	8.4	67	Yes	175
2/21/2024 7:43	0.8	150	126	9	8.4	67	Yes	175
2/22/2024 8:59	0.8	150	123	8	8.3	66	Yes	175
2/23/2024 9:48	0.8	150	122	8	8.3	68	Yes	175
2/24/2024 5:31	0.8	150	125	8	8.2	67	Yes	175
2/25/2024 7:50	0.9	150	132	8	8.3	68	Yes	175
2/26/2024 7:51	0.9	150	132	8	7.7	54	Yes	175
2/27/2024 0:44	0.9	150	140	7	7.6	56	Yes	175
2/28/2024 7:22	1.0	150	146	7	7.7	58	Yes	175
2/29/2024 20:29	0.9	150	128	7	8.0	65	Yes	175
30	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmwce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350