

**OHA - Drinking Water Program - Turbidity Monitoring Report Form. County: Polk
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ROCK CREEK WATER DISTRICT ID #: OR4100337 WTP: WTP-A Month/Year: 10-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.15			0.15
2				0.16			0.16
3				0.14			0.14
4				0.13			0.13
5				0.15			0.15
6				0.16			0.16
7				0.18			0.18
8				0.22			0.22
9				0.25			0.25
10				0.27			0.27
11				0.25			0.25
12				0.22			0.22
13				0.20			0.20
14				0.18			0.18
15				0.16			0.16
16				0.17			0.17
17				0.14			0.14
18				0.13			0.13
19				0.11			0.11
20				0.10			0.10
21				0.20			0.20
22				0.16			0.16
23				0.16			0.16
24			0.08				0.08
25			0.21				0.21
26				0.15			0.15
27				0.16			0.16
28				0.12			0.12
29				0.09			0.09
30				0.11			0.11
31				0.13			0.13

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: Sick all month still recovering from surgery		PRINTED NAME: Leonard A. Fischer	DATE: 11-16-23
		SIGNATURE: Leonard A. Fischer	CERT #: 6302
		PHONE #: (503) 879-5497	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR408337 WTP: WTP-A Month/Year: 10-23

Date/Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
OCT	[ppm or mg/L]	[minutes]	GMT	[°C]		Use tables	Yes/No	[GPM]
11/100	0.6	226	136	9	7.5	57	Yes	28
21/030	0.5		113	9	7.5	57		26
31/100	0.4		90	9	7.5	55		29
41/330	0.3		68	9	7.4	55		25
51/000	0.3		68	9	7.5	55		24
61/030	0.3		68	9	7.5	55		23
71/030	0.3		68	9	7.5	55		28
81/100	0.4		68	9	7.5	55		27
91/030	0.4		68	9	7.5	55		29
101/015	0.5		68/113	9	7.5	57		30
111/100	0.5		113	9	7.5	57		31
121/000	0.4		90	9	7.5	55		32
131/030	0.4		90	9	7.4	55		34
141/100	0.4		90	9	7.4	55		29
151/100	0.4		90	9	7.4	55		28
161/030	0.4		90	9	7.4	55		29
171/100	0.4		90	9	7.4	55		30
181/030	0.3		68	9	7.4	55		34
191/100	0.3		68	9	7.4	55		32
201/030	0.4		90	9	7.5	55		29
211/15	0.6		136	9	7.5	57/55		27
221/015	0.4		90	9	7.5	57		30
231/015	0.5		113	9	7.5	57		31
241/930	0.5		113	9	7.5	57		33
251/845	0.4		90	9	7.5	57		29
261/300	0.3		68	9	7.5	55		27
271/100	0.4		90	9	7.5	55		30
281/030	0.4		90	9	7.5	55		32
291/100	0.4		90	9	7.5	55		29
301/030	0.4		90	9	7.5	55		33
311/100	0.4		90	9	7.5	55		31

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.