

**OHA - Drinking Water Program - Turbidity monitoring Report Form. County: Polk
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ROCK CREEK WATER DISTRICT ID #: OR4100337 WTP: WTP-A Month/Year: 12-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.26			0.26
2				0.28			0.28
3				0.29			0.29
4				0.28			0.28
5				0.27			0.27
6				0.21			0.21
7				0.19			0.19
8					0.22		0.22
9					0.31		0.31
10					0.22		0.22
11					0.21		0.21
12					0.24		0.24
13					0.27		0.27
14					0.30		0.30
15					0.25		0.25
16					0.24		0.24
17					0.25		0.25
18					0.22		0.22
19					0.22		0.22
20					0.23		0.23
21					0.25		0.25
22					0.22		0.22
23					0.23		0.23
24					0.19		0.19
25					0.21		0.21
26				0.26			0.26
27					0.28		0.28
28	1				0.29		0.29
29					0.22		0.22
30					0.21		0.21
31					0.19		0.19

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:		PRINTED NAME: Leonard A. Fischer	
		SIGNATURE: <i>Leonard A. Fischer</i>	DATE: 1-9-24
		PHONE #: (503) 879-5497	CERT #: 6302

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR4409337 WTP: WTP-A Month/Year: 12-23

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CT	[°C]		Use tables	Yes / No	[GPM]
1/1/30	0.4	226	90	9	7.4	55	Yes	35
2/1/30	0.4		90	9	7.4	55		37
3/1/45	0.4		90	9	7.4	55		39
4/1/100	0.6		137	9	7.4	57		40
5/1/15	1.1		249	9	7.5	61		41
6/1/100	0.8		181	9	7.5	58		36
7/1/600	0.6		137	9	7.5	57		38
8/1/500	0.6		137	9	7.5	57		40
9/1/530	0.6		137	9	7.5	57		39
10/1/600	0.6		137	9	7.5	57		41
11/1/630	0.5		113	9	7.5	57		43
12/1/530	0.5		113	9	7.5	57		44
13/1/500	0.4		90	9	7.5	55		40
14/1/600	0.3		68	9	7.5	55		49
15/1/530	0.3		68	9	7.4	55		36
16/1/600	0.3		68	9	7.4	55		31
17/1/500	0.3		68	9	7.4	55		21
18/1/600	0.3		68	9	7.4	55		37
19/1/645	0.3		68	9	7.4	55		54
20/1/500	0.5		113	9	7.5	57		48
21/1/530	0.6		137	9	7.5	57		39
22/1/630	0.6		137	9	7.5	57		40
23/1/500	0.6		137	9	7.5	57		42
24/1/530	0.6		137	9	7.5	57		38
25/1/600	0.5		113	9	7.5	57		39
26/1/15	0.4		90	9	7.5	55		37
27/1/500	0.4		90	9	7.4	55		35
28/1/530	0.4		90	9	7.4	55		36
29/1/600	0.4		90	9	7.4	55		34
30/1/445	0.4		90	9	7.5	55		33
31/1/600	0.5		113	9	7.5	57	Y	35

*If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.