

**OHA - Drinking Water Program - Turbidity Monitoring Report Form. County: Polk  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **ROCK CREEK WATER DISTRICT** ID #: **OR4100337** WTP: **WTP-A** Month/Year: **6-24**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					0.21		0.21
2					0.22		0.22
3					0.24		0.24
4					0.19		0.19
5					0.21		0.21
6					0.23		0.23
7					0.24		0.24
8					0.22		0.22
9					0.20		0.20
10					0.18		0.18
11					0.16		0.16
12					0.15		0.15
13					0.17		0.17
14					0.14		0.14
15					0.21		0.21
16					0.18		0.18
17					0.20		0.20
18					0.17		0.17
19					0.19		0.19
20					0.21		0.21
21					0.23		0.23
22					0.22		0.22
23					0.19		0.19
24					0.21		0.21
25					0.20		0.20
26					0.22		0.22
27					0.23		0.23
28					0.21		0.21
29					0.24		0.24
30					0.23		0.23
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="checkbox"/> Yes / No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	Cl <sub>2</sub> 's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:		PRINTED NAME: <b>Leonard A. Fischer</b>	
		SIGNATURE: <i>Leonard Fischer</i>	DATE: <b>7-7-24</b>
		PHONE #: <b>(503) 879-5497</b>	CERT #: <b>6302</b>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

• OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR4409337 WTP: WTP-A Month/Year: 6-24

Date / Time	Minimum Cl <sub>2</sub> Residual at User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peel Hourly Demand Flow
	[ppm or mg/L]	[minutes]	GXT	[°C]		Use tables	Yes / No	[GPM]
11/430	0.4	226	90	9	7.5	55	Yes	49
21/430	0.3		68	9	7.4	55		56
31/600	0.3		68	9	7.4	55		52
41/530	0.4		90	9	7.4	55		49
51/530	0.4		90	9	7.4	55		51
61/600	0.5		113	9	7.4	57		50
71/630	0.5		113	9	7.4	57		48
81/530	0.5		113	9	7.5	57		49
91/500	0.4		90	9	7.5	55		52
101/600	0.4		90	9	7.5	55		54
111/630	0.5		113	9	7.5	57		51
121/600	0.5		113	9	7.5	57		50
131/500	0.4		90	9	7.5	55		49
141/600	0.4		90	9	7.5	55		55
151/630	0.3		68	9	7.4	55		46
161/600	0.3		68	9	7.4	55		48
171/530	0.3		68	9	7.4	55		47
181/500	0.4		90	9	7.4	55		49
191/600	0.4		90	9	7.4	55		50
201/500	0.4		90	9	7.5	55		53
211/430	0.5		113	9	7.5	57		57
221/500	0.5		113	9	7.5	57		55
231/530	0.5		113	9	7.5	57		52
241/600	0.4		90	9	7.5	55		49
251/630	0.4		90	9	7.5	55		47
261/430	0.5		113	9	7.4	57		44
271/500	0.5		113	9	7.4	57		45
281/430	0.5		113	9	7.4	57		44
291/600	0.5		113	9	7.4	57		42
301/630	0.4	✓	14590	9	7.4	55	✓	43
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.