

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: **Polk**
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **ROCK CREEK WATER DISTRICT** ID #: **OR4100337** WTP: **WTP-A** Month/Year: **9-24**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1				0.13			0.13
2				0.14			0.14
3				0.16			0.16
4				0.13			0.13
5				0.15			0.15
6				0.14			0.14
7				0.14			0.14
8				0.13			0.13
9				0.19			0.19
10				0.21			0.21
11				0.22			0.22
12				0.20			0.20
13				0.23			0.23
14				0.21			0.21
15				0.24			0.24
16				0.21			0.21
17				0.24			0.24
18				0.22			0.22
19				0.11			0.11
20				0.10			0.10
21				0.09			0.09
22				0.09			0.09
23				0.11			0.11
24				0.14			0.14
25				0.16			0.16
26				0.15			0.15
27				0.12			0.12
28				0.11			0.11
29				0.13			0.13
30				0.12			0.12
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes / No	Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? Yes / No
Notes:		PRINTED NAME: Leonard A. Fischer	DATE: 10-9-24
		SIGNATURE: <i>Leonard A. Fischer</i>	CERT #: 6302
		PHONE #: (503) 879-5497	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: ORW100337 WTP: WTP-A Month/Year: 9-24

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peer Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CGT	[°C]		Use tables	Yes/No	[GPM]
1/1030	0.6	226	136	9	7.4	57	Y	31
2/1100	0.6		136	9	7.4			35
3/1130	0.6		136	9	7.4			37
4/1030	0.6		136	9	7.4			34
5/1100	0.6		136	9	7.4			35
6/1015	0.6		136	9	7.4	✓		33
7/1000	0.6		136	9	7.5	57		35
8/1200	0.3		68	9	7.5	55		32
9/1115	0.3		68	9	7.5			31
10/1945	0.3		68	9	7.5			34
11/1100	0.3		68	9	7.4			37
12/1130	0.3		68	9	7.4			38
13/1045	0.3		68	9	7.4			37
14/1100	0.3		68	9	7.4			36
15/1130	0.3		68	9	7.4			37
16/1200	0.3		68	9	7.5			35
17/1500	0.3		68	9	7.5	✓		37
18/1400	0.3		68	9	7.4	55		34
19/1045	0.7		158	9	7.5	58		36
20/1100	0.5		113	9	7.5	57		35
21/1130	0.3		68	9	7.5	55		37
22/1230	0.4		90	9	7.5			34
23/1015	0.3		68	9	7.5			34
24/1945	0.3		68	9	7.4			33
25/1100	0.3		68	9	7.4			37
26/1130	0.3		68	9	7.4			35
27/1045	0.3		68	9	7.4			38
28/1100	0.3		68	9	7.4			40
29/1200	0.3		68	9	7.4			37
30/1130	0.3	✓	68	9	7.4	✓	✓	38
31/								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/furb-ali-unifcfr