

**OWA - Drinking Water Program - Turbidity monitoring Report Form. County: Polk
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ROCK CREEK WATER DISTRICT ID #: OR4100337 WTP: WTP-A Month/Year: 1-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.23			0.23
2				0.25			0.25
3				0.24			0.24
4				0.20			0.20
5				0.23			0.23
6			0.32				0.32
7				0.31			0.31
8				0.30			0.30
9				0.29			0.29
10				0.26			0.26
11				0.25			0.25
12				0.23			0.23
13				0.22			0.22
14					0.24		0.24
15				0.26			0.26
16				0.22			0.22
17				0.20			0.20
18				0.18			0.18
19				0.16			0.16
20				0.19			0.19
21				0.21			0.21
22				0.23			0.23
23				0.20			0.20
24				0.22			0.22
25				0.21			0.21
26				0.19			0.19
27				0.18			0.18
28				0.20			0.20
29				0.22			0.22
30				0.24			0.24
31				0.21			0.21

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Cl ₂ 's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: Leonard A. Fischer
SIGNATURE: <i>Leonard A. Fischer</i> DATE: 2-10-25
PHONE #: (503) 879-5497 CERT #: 6302

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

CHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR2408337 WTP: WTP-A Month/Year: 1-25

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³⁻	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CTT	[°C]		Use tables	Yes/No	[GPM]
1/1/030	0.6	97	58	9	7.5	57	No	33
2/1/100	0.6		58	9	7.5	57	No	35
3/1/200	0.6		58	9	7.5	57	No	31
4/1/130	0.7		68	9	7.5	58	Yes	29
5/1/100	0.6		58	9	7.5	57	No	32
6/1/0900	0.5		49	9	7.5	57	No	33
7/1/130	0.6		58	9	7.5	57	No	35
8/1/030	0.6		58	9	7.5	57	No	33
9/1/200	0.6		58	9	7.4	57	No	30
10/1/130	0.8		78	9	7.4	58	Yes	29
11/1/100	0.8		78	9	7.5	58	Yes	32
12/1/130	0.8		78	9	7.5	58	Yes	33
13/1/200	0.8		78	9	7.5	58	Yes	31
14/1/1600	0.6		58	9	7.5	58/7	No	29
15/1/030	0.8		78	9	7.4	58	Yes	32
16/1/100	0.8		78	9	7.4	58	Yes	34
17/1/130	0.8		78	9	7.4	58	Yes	35
18/1/160	0.8		78	9	7.5	58	Yes	33
19/1/200	0.6		58	9	7.5	58/7	No	31
20/1/1100	0.7		68	9	7.4	57	Yes	33
21/1/130	0.8		78	9	7.4	58	Yes	29
22/1/200	0.8		78	9	7.4	58	Yes	28
23/1/130	0.7		68	9	7.5	57	Yes	29
24/1/1100	0.8		78	9	7.4	58	Yes	32
25/1/030	0.8		78	9	7.5	58	Yes	34
26/1/160	0.7		68	9	7.5	57	Yes	36
27/1/130	0.7		68	9	7.5	57	Yes	37
28/1/200	0.8		78	9	7.4	58	Yes	34
29/1/130	0.8		78	9	7.4	58	Yes	32
30/1/1045	0.7		68	9	7.4	57	Yes	29
31/1/200	0.8	✓	78	9	7.4	58	Yes	33

* If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day.