

**OWA - Drinking Water Program - Turbidity monitoring Report Form. County: Polk**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: ROCK CREEK WATER DISTRICT ID #: OR4100337 WTP: WTP-A Month/Year: 2-25**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1				0.31			0.31
2				0.29			0.29
3				0.26			0.26
4				0.22			0.22
5				0.24			0.24
6				0.26			0.26
7				0.25			0.25
8				0.23			0.23
9				0.25			0.25
10				0.24			0.24
11				0.26			0.26
12				0.25			0.25
13				0.26			0.26
14				0.25			0.25
15				0.27			0.27
16				0.26			0.26
17				0.25	0.25		0.25
18				0.31			0.31
19				0.28			0.28
20				0.27			0.27
21				0.29			0.29
22				0.31			0.31
23				0.29			0.29
24				0.25			0.25
25				0.23			0.23
26				0.24			0.24
27				0.23			0.23
28				0.22			0.22
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	Yes/No	Cl <sub>2</sub> 's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes/No	Yes/No	Yes/No
Notes:		PRINTED NAME: Leonard A. Fischer	
		SIGNATURE: Leonard A. Fischer	DATE: 3-9-25
		PHONE #: (503) 877-5497	CERT #: 6302

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR2409337 WTP: WTP-A Month/Year: 2-25

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
Feb	[ppm or mg/L]	[minutes]	CGT	[°C]		Use tables	Yes/No	[GPM]
1/1/00	0.9	97	87	9	7.5	60	Yes	34
2/1/30	0.8		78	9	7.5	58		32
3/1/00	0.7		68	9	7.5	58		31
4/1/30	0.7		68	9	7.5	58		33
5/1/30	0.7		68	9	7.5	58		32
6/1/04	0.8		78	9	7.5	58		30
7/1/04	0.8		78	9	7.5	58		34
8/1/04	0.8		78	9	7.5	58		35
9/1/04	0.8		78	9	7.5	58		33
10/1/30	0.9		87	9	7.5	58		32
11/1/15	0.8		78	9	7.4	60		31
12/1/15	0.8		78	9	7.4	58		33
13/1/00	0.7		68	9	7.4	58		30
14/1/30	0.7		68	9	7.4	58		32
15/1/30	0.7		68	9	7.4	58		31
16/1/00	0.7		68	9	7.4	58		32
17/1/50	0.6		58	9	7.5	57		29
18/1/30	1.2		116	9	7.5	61		33
19/1/16	1.2		116	9	7.5	61		30
20/1/20	1.3		126	9	7.5	61		32
21/1/15	1.5		146	9	7.5	62		33
22/1/00	1.2		116	9	7.5	61		31
23/1/15	1.1		107	9	7.5	61		32
24/1/20	0.9		87	9	7.4	60		29
25/1/00	0.8		78	9	7.4	58		30
26/1/05	0.8		78	9	7.4	58		33
27/1/30	0.7		68	9	7.4	58		30
28/1/00	0.6		58	9	7.4	57		32
29/1								
30/1								
31/1								

\*If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.