

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: **Polk**
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **ROCK CREEK WATER DISTRICT** ID #: **OR4400337** WTP: **WTP-A** Month/Year: **4-25**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.17	0.17			0.17
2			0.18	0.18			0.18
3				0.17			0.17
4				0.14			0.14
5				0.12			0.12
6				0.13			0.13
7				0.14			0.14
8				0.14			0.14
9				0.16			0.16
10				0.18			0.18
11						0.21	0.21
12				0.22			0.22
13				0.23			0.23
14				0.20			0.20
15				0.17			0.17
16				0.15			0.15
17				0.14			0.14
18				0.14			0.14
19				0.15			0.15
20				0.16			0.16
21				0.17			0.17
22				0.16			0.16
23				0.17			0.17
24				0.18			0.18
25				0	0.19		0.19
26						0.12	0.12
27				0.11			0.11
28				0.11			0.11
29				0.12			0.12
30						0.10	0.10
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	Cl's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/L?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		PRINTED NAME: Leonard A. Fischer	
		SIGNATURE: <i>Leonard A. Fischer</i>	DATE: 5-8-25
		PHONE #: (503) 879-5497	CERT #: 6302

¹including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR2100337 WTP: WTP-A Month/Year: 4-25

Date/ Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Pear Hourly Demand Flow
Apr	[ppm or mg/L]	[minutes]	CXT	F C		Use tables	Yes/No	[GPM]
1/1/30	0.6	97	58	9	7.5	57	Yes	30
2/1/20	0.6		58	9	7.5	57		32
3/1/10	0.7		68	9	7.5	57		31
4/1/00	0.6		58	9	7.5	57		33
5/1/00	1.4		136	9	7.5	62		35
6/1/30	1.3		126	9	7.4	62		39
7/1/20	1.3		126	9	7.4	62		31
8/1/10	1.2		116	9	7.4	61		30
9/1/30	1.1		107	9	7.4	62		28
10/1/00	1.0		107	10	7.4	60		30
11/1/30	0.1.0		97	9	7.4	60		33
12/1/30	1.1		107	9	7.5	60		35
13/1/00	1.0		97	9	7.5	60		34
14/1/60	0.9		87	9	7.5	58		29
15/1/15	0.8		78	9	7.5	58		32
16/1/10	0.8		78	9	7.5	58		33
17/1/40	0.9		87	9	7.5	58		30
18/1/55	1.3		126	9	7.5	61		32
19/1/10	1.2		116	9	7.5	61		29
20/1/30	1.2		116	9	7.4	61		31
21/1/30	1.1		107	9	7.4	60		33
22/1/20	1.0		97	9	7.4	60		29
23/1/30	1.1		107	9	7.4	60		32
24/1/20	1.0		97	9	7.4	60		35
25/1/00	1.0		97	9	7.4	60		32
26/1/30	0.6		58	9	7.5	57		29
27/1/20	1.5		146	9	7.5	62		33
28/1/25	1.5		146	9	7.5	62		30
29/1/30	1.3		126	9	7.5	61		29
30/1/00	1.1	Y	107	9	7.5	60	Y	33
31/1								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.