

OWA - Drinking Water Program - Turbidity Monitoring Report Form. County: Polk
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ROCK CREEK WATER DISTRICT ID # GR4100337 WTP: WTP-A Month/Year: 5-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1				0.19			0.19
2						0.21	0.21
3				0.10			0.10
4				0.10			0.10
5				0.09			0.09
6				0.10	0.09		0.09
7				0.10			0.10
8				0.21			0.21
9				0.19			0.19
10				0.17			0.17
11				0.21			0.21
12				0.22			0.22
13				0.19			0.19
14				0.22			0.22
15				0.20			0.20
16					0.22		0.22
17					0.25		0.25
18				0.19			0.19
19				0.10			0.10
20				0.09			0.09
21				0.13			0.13
22				0.10			0.10
23				0.12			0.12
24					0.17		0.17
25				0.16			0.16
26				0.11			0.11
27				0.09			0.09
28					0.09		0.09
29				0.08			0.08
30				0.08			0.08
31				0.07			0.07

Slow Sand/Membrane/DE Filtration/Unfiltered

95% of daily turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / ☐ No

Monthly Summary (Answer Yes or No)

Cl₂ met everyday?
 (see back)
☒ Yes / ☐ No

All Cl₂ residual at entry point $\geq$ 0.2 mg/L?
☒ Yes / ☐ No

Notes:

PRINTED NAME: Leonard A. Fischer

SIGNATURE: Leonard A. Fischer

DATE: 6-6-25

PHONE #: (503) 879-5497

CERT #: 6302

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

CHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: OR2409337 WTP: WTP-A Month/Year: 5-25

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Pear Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CTT	[°C]		Use tables	Yes/No	[GPM]
1/1/00	0.8	97	78	9	7.4	58	Yes	34
2/1/00	1.0		97	9	7.5	60		33
3/1/00	0.9		87	9	7.5	60		35
4/1/00	0.8		78	9	7.5	58		32
5/1/00	1.2		116	9	7.5	61		31
6/1/00	1.2		116	9	7.5	61		33
7/1/00	1.3		126	9	7.5	62		31
8/1/00	1.2		116	9	7.5	61		34
9/1/00	1.0		97	9	7.4	60		32
10/1/00	1.0		97	9	7.4	60		30
11/1/00	0.9		87	9	7.4	60		33
12/1/00	0.9		87	9	7.4	60		35
13/1/00	0.9		87	9	7.4	60		36
14/1/00	0.9		87	9	7.4	60		33
15/1/00	0.9		87	9	7.4	60		31
16/1/00	0.8		78	9	7.5	58		32
17/1/00	0.8		78	9	7.5	58		34
18/1/00	0.8		78	9	7.5	58		30
19/1/00	0.8		78	9	7.5	58		32
20/1/00	0.9		87	9	7.5	60		29
21/1/00	0.9		87	9	7.4	60		28
22/1/00	0.9		87	9	7.4	60		32
23/1/00	0.9		87	9	7.4	60		34
24/1/00	0.9		87	9	7.5	60		36
25/1/00	1.5		145	9	7.5	64		34
26/1/00	1.3		126	9	7.5	62		30
27/1/00	0.9		87	9	7.5	60		29
28/1/00	0.7		68	9	7.5	58		33
29/1/00	1.3		126	9	7.5	58		34
30/1/00	1.2		116	9	7.5	62		30
31/1/00	1.1	✓	107	9	7.5	62	✓	32

*If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/Health/Environments/DrinkingWater/Monitoring/Documents/furb-att-unfiltered.pdf