

CHA - Drinking Water Program - Turbidity Monitoring Report Form. County: Polk
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ROCK CREEK WATER DISTRICT ID # GR490337 WTP: WTP-A Month/Year: 8-25

DAY	12 AM NTU	4 AM NTU	8 AM NTU	NOON NTU	4 PM NTU	8 PM NTU	Highest Reading of the Day NTU
1					0.12		0.12
2					0.11		0.11
3					0.10		0.10
4						0.28	0.28
5					0.22		0.22
6					0.20		0.20
7					0.15		0.15
8						0.12	0.12
9						0.24	0.24
10					0.25		0.25
11						0.12	0.12
12					0.11		0.11
13				0.10			0.10
14				0.09			0.09
15					0.11		0.11
16					0.12		0.12
17					0.15		0.15
18					0.09		0.09
19				0.10			0.10
20				0.21			0.21
21						0.28	0.28
22						0.20	0.20
23					0.22		0.22
24					0.25		0.25
25				0.15			0.15
26				0.10			0.10
27				0.08			0.08
28				0.09			0.09
29				0.09			0.09
30						0.07	0.07
31					0.08		0.08

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / ☐ No

Cl₂ met everyday?
 (see back)
☒ Yes / ☐ No

All Cl₂ residual at entry point $\geq$ 0.2 mg/L?
☒ Yes / ☐ No

Notes:

PRINTED NAME: Leonard A. Fischer

SIGNATURE: Leonard A. Fischer DATE: 9-9-25

PHONE: (503) 879-5497 CERT: 6302

*including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID# OR4400837 WTP: WTP-A Month/Year: 8-25

Date/Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
# of P	[ppm or mg/L]	[minutes]	GXT	[°C]		Use tables	Yes/No	[GPM]
11/600	1.0	97	97	10	7.5	45	Yes	35
21/630	1.0		97	10	7.5	45		36
31/600	1.1		1.07	10	7.5	45		33
41/815	1.1		1.07	10	7.5	45		31
51/600	1.6		97	10	7.4	45		29
61/630	1.0		97	10	7.4	45		30
71/600	0.9		87	10	7.4	44		32
81/800	0.9		87	10	7.4	44		34
91/2000	0.7		68	10	7.5	43		33
101/700	0.8		78	10	7.5	44		35
111/845	0.7		68	10	7.5	44		30
121/900	0.8		78	10	7.5	44		29
131/330	0.7		68	10	7.5	43		32
141/315	0.9		87	10	7.5	44		34
151/600	0.8		78	10	7.5	44		33
161/800	0.9		87	10	7.5	44		31
171/600	0.9		87	10	7.5	44		29
181/430	0.9		87	10	7.5	44		34
191/230	0.9		87	10	7.5	44		35
201/200	0.8		78	10	7.5	44		33
211/200	0.8		78	10	7.5	44		31
221/815	0.8		78	10	7.5	44		30
231/700	0.8		78	10	7.5	44		29
241/630	0.8		78	10	7.5	44		32
251/130	0.8		78	10	7.4	44		35
261/200	0.8		7.8	10	7.4	44		34
271/100	0.9		87	10	7.4	44		32
281/800	0.8		78	10	7.4	44		33
291/230	0.8		78	10	7.4	44		31
301/900	0.8		78	10	7.4	44		30
311/600	0.8		78	10	7.5	44		32

*If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/Health/Environmental/DrinkingWater/Monitoring/Documents/fish-all-unfiltered.pdf