

**OHIA - Drinking Water Program - Turbidity Monitoring Report Form. County: Polk**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: ROCK CREEK WATER DISTRICT ID #: CR4100337 WTP: WTP-A Month/Year: 10-25**

| DAY | 12 AM<br>[NTU] | 4 AM<br>[NTU] | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU] | Highest Reading of<br>the Day <sup>1</sup><br>[NTU] |
|-----|----------------|---------------|---------------|---------------|---------------|---------------|-----------------------------------------------------|
| 1   |                |               |               | 0.20          |               |               | 0.20                                                |
| 2   |                |               | 0.21          |               |               |               | 0.21                                                |
| 3   |                |               |               | 0.26          |               |               | 0.26                                                |
| 4   |                |               |               |               | 0.10          |               | 0.10                                                |
| 5   |                |               |               |               | 0.09          |               | 0.09                                                |
| 6   |                |               |               |               | 0.09          |               | 0.09                                                |
| 7   |                |               |               | 0.09          |               |               | 0.09                                                |
| 8   |                |               | 0.08          |               |               |               | 0.08                                                |
| 9   |                |               | 0.08          |               |               |               | 0.08                                                |
| 10  |                |               |               |               | 0.17          |               | 0.17                                                |
| 11  |                |               |               |               | 0.20          |               | 0.20                                                |
| 12  |                |               |               |               | 0.20          |               | 0.20                                                |
| 13  |                |               |               |               | 0.19          |               | 0.19                                                |
| 14  |                |               |               | 0.20          |               |               | 0.20                                                |
| 15  |                |               |               | 0.20          |               |               | 0.20                                                |
| 16  |                |               |               |               | 0.21          |               | 0.21                                                |
| 17  |                |               |               | 0.26          |               |               | 0.26                                                |
| 18  |                |               |               | 0.31          |               |               | 0.31                                                |
| 19  |                |               |               | 0.26          |               |               | 0.26                                                |
| 20  |                |               |               | 0.23          |               |               | 0.23                                                |
| 21  |                |               |               |               | 0.24          |               | 0.24                                                |
| 22  |                |               |               | 0.26          |               |               | 0.26                                                |
| 23  |                |               |               | 0.21          |               |               | 0.21                                                |
| 24  |                |               |               | 0.22          |               |               | 0.22                                                |
| 25  |                |               |               |               | 0.23          |               | 0.23                                                |
| 26  |                |               |               |               | 0.24          |               | 0.24                                                |
| 27  |                |               |               |               | 0.22          |               | 0.22                                                |
| 28  |                |               |               | 0.23          |               |               | 0.23                                                |
| 29  |                |               |               | 0.31          |               |               | 0.31                                                |
| 30  |                |               |               |               | 0.30          |               | 0.30                                                |
| 31  |                |               |               |               | 0.28          |               | 0.28                                                |

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup> ☒ Yes / No  
 All daily turbidity readings  $\leq$  5 NTU? ☒ Yes / No

CT's met everyday?  
 (see back)  
☒ Yes / No

All Cl<sub>2</sub> residual at entry point  $\geq$  0.2 mg/l?  
☒ Yes / No

Notes: Rain & Storms

PRINTED NAME: Leonard A. Fischer

SIGNATURE: Leonard A. Fischer DATE: 11-4-25

PHONE #: (503) 879-5497

CERT #: 6302

<sup>1</sup>including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>Filtered systems only.

## CHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT ID #: 0R2409337 WTP: WTP-A Month/Year: 10-25

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp | pH  | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow [GPM] |
|-------------|---------------------------------------------------------------------------|------------------|-----------|------|-----|-------------|----------------------|-------------------------------|
| 80          | [ppm or mg/L]                                                             | [minutes]        | CT        | [°C] |     | Use tables  | Yes/No               |                               |
| 1/10/30     | 0.7                                                                       | 97               | 68        | 9    | 7.4 | 57          | Yes                  | 30                            |
| 2/10/00     | 0.7                                                                       |                  | 68        | 9    | 7.4 | 57          |                      | 29                            |
| 3/11/30     | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 31                            |
| 4/11/00     | 0.9                                                                       |                  | 87        | 9    | 7.5 | 58          |                      | 32                            |
| 5/11/30     | 1.1                                                                       |                  | 107       | 9    | 7.5 | 60          |                      | 29                            |
| 6/11/30     | 1.1                                                                       |                  | 107       | 9    | 7.5 | 60          |                      | 30                            |
| 7/11/30     | 1.1                                                                       |                  | 107       | 9    | 7.5 | 60          |                      | 29                            |
| 8/10/00     | 0.9                                                                       |                  | 87        | 9    | 7.5 | 58          |                      | 28                            |
| 9/10/00     | 1.0                                                                       |                  | 97        | 9    | 7.5 | 60          |                      | 27                            |
| 10/11/00    | 0.9                                                                       |                  | 87        | 9    | 7.4 | 58          |                      | 29                            |
| 11/11/00    | 0.8                                                                       |                  | 78        | 9    | 7.4 | 58          |                      | 31                            |
| 12/11/30    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 32                            |
| 13/11/30    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 30                            |
| 14/12/30    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 28                            |
| 15/11/00    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 29                            |
| 16/11/30    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 31                            |
| 17/12/00    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 32                            |
| 18/11/30    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 29                            |
| 19/12/00    | 0.8                                                                       |                  | 78        | 9    | 7.4 | 58          |                      | 30                            |
| 20/13/00    | 0.7                                                                       |                  | 68        | 9    | 7.4 | 57          |                      | 28                            |
| 21/11/30    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 29                            |
| 22/11/30    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 31                            |
| 23/13/15    | 0.9                                                                       |                  | 87        | 9    | 7.5 | 58          |                      | 33                            |
| 24/12/00    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 30                            |
| 25/11/30    | 0.8                                                                       |                  | 78        | 9    | 7.4 | 58          |                      | 28                            |
| 26/11/00    | 0.8                                                                       |                  | 78        | 9    | 7.4 | 58          |                      | 29                            |
| 27/11/30    | 0.7                                                                       |                  | 68        | 9    | 7.4 | 57          |                      | 31                            |
| 28/13/15    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 32                            |
| 29/13/00    | 0.8                                                                       |                  | 78        | 9    | 7.5 | 58          |                      | 29                            |
| 30/11/00    | 0.7                                                                       |                  | 68        | 9    | 7.5 | 57          |                      | 33                            |
| 31/11/45    | 0.7                                                                       | ✓                | 68        | 9    | 7.5 | 57          | ✓                    | 31                            |

\*If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/Forms-all-unfiltered.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/Forms-all-unfiltered.pdf)