

CHA - Drinking Water Program - Turbidity monitoring Report Form. County: Polk
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **ROCK CREEK WATER DISTRICT** ID #: **0R4700337** WTP: **WTP-A** Month/Year: **11-25**

DAY	12 AM NTU ¹	4 AM NTU ¹	8 AM NTU ¹	NOON NTU ¹	4 PM NTU ¹	8 PM NTU ¹	Highest Reading of the Day ¹ NTU ¹
1				0.26			0.26
2				0.25			0.25
3				0.27			0.27
4					0.25		0.25
5					0.26		0.26
6					0.27		0.27
7					0.28		0.28
8					0.27		0.27
9					0.28		0.28
10					0.29		0.29
11					0.30		0.30
12					0.33		0.33
13						0.28	0.28
14					0.31		0.31
15					0.29		0.29
16					0.32		0.32
17				0.34			0.34
18				0.28			0.28
19				0.21			0.21
20					0.23		0.23
21					0.22		0.22
22					0.24		0.24
23					0.23		0.23
24					0.25		0.25
25					0.20		0.20
26					0.20		0.20
27				0.21			0.21
28					0.22		0.22
29					0.23		0.23
30				0.32			0.32
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	Cl ₂ met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/L?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		PRINTED NAME: Leonard A. Fischer	
		SIGNATURE: <i>Leonard A. Fischer</i>	DATE: 12-8-25
		PHONE: (503) 879-5497	CERT: 6302

¹including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

CHA - Drinking Water Program - Surface Water Quality Data Form

ROCK CREEK WATER DISTRICT D# OR419337 WTP: WTP-A Month/Year: 11-25

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
11/1330	0.9	97	87	9	7.4	58	Yes	32
21/100	0.7		68	9	7.4	57		30
31/030	0.7		68	9	7.4	57		28
41/600	0.7		68	9	7.4	57		31
51/530	0.7		68	9	7.4	57		32
61/500	0.6		58	9	7.4	57		28
71/530	0.6		58	9	7.4	57		30
81/515	1.0		97	9	7.5	60		32
91/630	0.9		87	9	7.4	58		31
101/730	0.9		87	9	7.5	58		29
111/430	1.0		97	9	7.5	60		28
121/730	0.7		68	9	7.5	57		30
131/830	0.7		68	9	7.5	57		31
141/600	0.7		68	9	7.4	57		33
151/630	0.7		68	9	7.4	57		34
161/600	0.7		68	9	7.4	57		32
171/830	0.7		68	9	7.5	57		29
181/830	1.0		97	9	7.5	60		30
191/000	0.7		68	9	7.5	57		32
201/600	0.7		68	9	7.4	57		33
211/530	0.7		68	9	7.4	57		29
221/630	0.7		68	9	7.4	57		30
231/500	0.6		58	9	7.4	57		33
241/600	0.6		58	9	7.4	57		31
251/630	0.7		68	9	7.5	57		32
261/630	0.8		78	9	7.5	58		29
271/200	1.2		116	9	7.5	61		32
281/430	1.2		116	9	7.5	61		33
291/630	1.1		107	9	7.4	61		30
301/230	1.1		107	9	7.5	61	✓	29
311.		✓						

*If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/Health/Environment/DrinkingWater/Monitoring/Documents/form-att-unfiltered.pdf