

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine

Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

March, 2025

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
3/1/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/2/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/3/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/4/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/5/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/6/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/7/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/8/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/9/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/10/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/11/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/12/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/13/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/14/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/15/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/16/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/17/2025	---	---	0.04	0.03	0.03	---	0.04 NTU
3/18/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/19/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/20/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/21/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/22/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/23/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/24/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/25/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/26/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/27/2025	---	---	0.03	0.02	0.02	---	0.03 NTU
3/28/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/29/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/30/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
3/31/2025	---	---	0.02	0.02	0.02	---	0.02 NTU

Conventional or Direct Filtration Monthly Summary		Monthly Summary (Answer Yes or No)
95% of Turbidity readings ≤ 0.3 ? Yes	CT's met everyday? Yes	CI Residual at entry point always > 0.2 mg/l Yes
All Turbidity readings < 1 NTU? Yes	(see back of sheet)	
All Turbidity readings < 1 FE triggers? Yes		

Notes:	Printed Name: Adam B Smith
Dashed lines (---) = No Plant Operations	Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP-:WTP-A								March, 2025		Required Log Inactivation: 0.5		
Date Time	Segment 1 CFE			Segment 2 EFF			TOTAL Actual CT	Temp lowest	pH highest	Required CT	CT Met	Peak Hourly Flow
	Min CFE Cl2 Residual (C)	Actual CT	Min.Cl2 Residual At 1st User (C)	Actual CT								
	mg/L	(T)	C X T	mg/L	(T)	C X T						
1 / 1700	0.11	141.0	15.5	1.21	35.1	42.5	58.0	8.1	7.20	24.0	YES	6500
2 / 0800	0.07	161.0	11.3	1.11	43.5	48.3	59.6	8.8	7.20	22.7	YES	5500
3 / 0800	0.07	161.0	11.3	1.17	43.5	50.9	62.2	8.4	7.20	23.4	YES	5500
4 / 1200	0.09	141.0	12.7	1.24	35.1	43.5	56.2	8.2	7.20	23.9	YES	6500
5 / 0800	0.07	161.0	11.3	1.19	43.5	51.8	63.0	8.4	7.20	23.5	YES	5500
6 / 0800	0.05	161.0	8.1	1.14	43.5	49.6	57.6	8.2	7.20	23.7	YES	5500
7 / 0800	0.08	161.0	12.9	1.17	43.5	50.9	63.8	7.6	7.20	24.7	YES	5500
8 / 0800	0.06	161.0	9.7	1.20	43.5	52.2	61.9	7.4	7.20	25.1	YES	5500
9 / 0800	0.07	161.0	11.3	1.17	43.5	50.9	62.2	8.1	7.20	23.9	YES	5500
10 / 0800	0.03	161.0	4.8	1.11	43.5	48.3	53.1	8.5	7.20	23.1	YES	5500
11 / 0800	0.04	161.0	6.4	1.14	43.5	49.6	56.0	8.6	7.20	23.0	YES	5500
12 / 0800	0.07	161.0	11.3	1.19	43.5	51.8	63.0	8.4	7.20	23.5	YES	5500
13 / 0800	0.08	161.0	12.9	1.17	43.5	50.9	63.8	7.8	7.20	24.4	YES	5500
14 / 0800	0.05	161.0	8.1	1.19	43.5	51.8	59.8	7.3	7.20	25.3	YES	5500
15 / 0900	0.13	141.0	18.3	1.23	35.1	43.2	61.5	7.8	7.20	24.6	YES	6500
16 / 0800	0.03	161.0	4.8	1.09	43.5	47.4	52.2	7.9	7.30	24.9	YES	5500
17 / 0800	0.02	161.0	3.2	1.05	43.5	45.7	48.9	8.3	7.20	23.3	YES	5500
18 / 1300	0.05	161.0	8.1	1.16	43.5	50.5	58.5	7.9	7.20	24.2	YES	5500
19 / 0800	0.05	161.0	8.1	1.12	43.5	48.7	56.8	7.8	7.20	24.2	YES	5500
20 / 0800	0.05	161.0	8.1	1.15	43.5	50.0	58.1	8.1	7.20	23.9	YES	5500
21 / 0800	0.02	161.0	3.2	1.16	43.5	50.5	53.7	8.3	7.20	23.6	YES	5500
22 / 1400	0.08	141.0	11.3	1.21	35.1	42.5	53.8	8.8	7.20	22.9	YES	6500
23 / 1300	0.04	141.0	5.6	1.21	35.1	42.5	48.1	8.7	7.20	23.1	YES	6500
24 / 1300	0.04	141.0	5.6	1.24	35.1	43.5	49.2	9.4	7.20	22.1	YES	6500
25 / 0800	0.05	141.0	7.1	1.17	35.1	41.1	48.1	9.7	7.20	21.5	YES	6500
26 / 0800	0.03	161.0	4.8	1.12	43.5	48.7	53.5	10.1	7.20	20.8	YES	5500
27 / 0900	0.03	161.0	4.8	1.16	43.5	50.5	55.3	9.9	7.20	21.2	YES	5500
28 / 0800	0.05	161.0	8.1	1.16	43.5	50.5	58.5	9.2	7.20	22.2	YES	5500
29 / 1500	0.09	141.0	12.7	1.20	35.1	42.1	54.8	8.6	7.20	23.2	YES	6500
30 / 0800	0.03	161.0	4.8	1.16	43.5	50.5	55.3	8.9	7.20	22.6	YES	5500
31 / 0800	0.03	161.0	4.8	1.10	43.5	47.9	52.7	8.8	7.20	22.6	YES	5500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION