

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine
Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

June, 2025

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
6/1/2025	---	---	0.03	0.04	0.02	0.02	0.04 NTU
6/2/2025	---	---	0.02	0.02	0.03	0.04	0.04 NTU
6/3/2025	---	---	0.03	0.03	0.05	0.06	0.08 NTU
6/4/2025	---	---	0.02	0.03	0.02	0.03	0.03 NTU
6/5/2025	---	---	0.02	0.02	0.03	0.04	0.09 NTU
6/6/2025	---	---	0.02	0.03	0.03	0.02	0.04 NTU
6/7/2025	---	---	0.02	0.03	0.03	0.02	0.09 NTU
6/8/2025	---	---	0.04	0.03	0.03	0.03	0.04 NTU
6/9/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.03 NTU
6/10/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/11/2025	0.02	0.02	0.02	0.07	0.04	0.04	0.19 NTU
6/12/2025	0.04	0.03	0.03	0.03	0.02	0.02	0.04 NTU
6/13/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.03 NTU
6/14/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/15/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/16/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/17/2025	0.02	0.02	0.02	0.02	0.03	0.02	0.03 NTU
6/18/2025	0.02	0.02	0.02	0.02	0.02	0.03	0.07 NTU
6/19/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.03 NTU
6/20/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/21/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/22/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/23/2025	0.02	0.03	0.02	0.02	0.02	0.02	0.03 NTU
6/24/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.03 NTU
6/25/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.03 NTU
6/26/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/27/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/28/2025	0.02	0.02	0.02	0.02	0.02	0.02	0.02 NTU
6/29/2025	0.02	0.02	0.02	0.02	0.02	0.03	0.03 NTU
6/30/2025	0.02	0.02	0.02	0.03	0.03	0.02	0.03 NTU

Conventional or Direct Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3 ? Yes	CT's met everyday? Yes (see back of sheet)	CI Residual at entry point always > 0.2 mg/l? Yes	
All Turbidity readings < 1 NTU? Yes			
All Turbidity readings $<$ IFE triggers? Yes			
Notes:		Printed Name: Adam B Smith	
Dashed lines (---) = No Plant Operations		Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430	

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP-:WTP-A					June, 2025		Required Log Inactivation: 0.5	
---	--	--	--	--	------------	--	--------------------------------	--

Date Time	Segment 1 CFE			Segment 2 EFF								
	Min CFE Cl2 Residual (C)	Actual CT		Min.Cl2 Residual At 1st User (C)	Actual CT	TOTAL Actual CT	Temp	pH	Required CT	CT Met	Peak Hourly Flow	
							lowest	highest				
	mg/L	(T)	C X T	mg/L	(T)	C X T	C x T	C		Tables	Yes/No	(GPM)
1 / 0800	0.06	95.0	5.7	1.18	21.2	25.0	30.7	16.2	7.20	13.8	YES	9500
2 / 0800	0.09	83.0	7.5	1.16	19.0	22.0	29.5	15	7.20	14.9	YES	10500
3 / 1000	0.10	83.0	8.3	1.13	19.0	21.5	29.8	15.7	7.20	14.2	YES	10500
4 / 1100	0.08	95.0	7.6	1.17	21.2	24.8	32.4	15.8	7.30	14.7	YES	9500
5 / 1300	0.14	83.0	11.6	1.19	19.0	22.6	34.2	15.9	7.10	13.6	YES	10500
6 / 0800	0.10	95.0	9.5	1.09	21.2	23.1	32.6	16.3	7.10	13.1	YES	9500
7 / 1100	0.14	83.0	11.6	1.21	19.0	23.0	34.6	16.6	7.10	13.0	YES	10500
8 / 0600	0.08	95.0	7.6	1.19	21.2	25.2	32.8	17.4	7.10	12.3	YES	9500
9 / 0000	0.16	95.0	15.2	1.20	21.2	25.4	40.6	17.4	7.10	12.3	YES	9500
10 / 1300	0.06	119.0	7.1	1.17	28.9	33.8	41.0	17.4	7.10	12.3	YES	7500
11 / 1100	0.10	108.0	10.8	1.12	24.4	27.3	38.1	16.4	7.10	13.0	YES	8500
12 / 0000	0.19	108.0	20.5	1.20	24.4	29.3	49.8	16.4	7.10	13.2	YES	8500
13 / 0800	0.18	108.0	19.4	1.23	24.4	30.0	49.5	15.7	7.10	13.8	YES	8500
14 / 1200	0.09	119.0	10.7	1.17	28.9	33.8	44.5	15.4	7.10	14.0	YES	7500
15 / 0800	0.09	119.0	10.7	1.15	28.9	33.2	43.9	15.6	7.20	14.3	YES	7500
16 / 2300	0.24	95.0	22.8	1.18	21.2	25.0	47.8	16.5	7.10	13.0	YES	9500
17 / 0200	0.19	95.0	18.0	1.13	21.2	24.0	42.0	16.4	7.10	13.1	YES	9500
18 / 1300	0.09	119.0	10.7	1.12	28.9	32.4	43.1	16.6	7.20	13.4	YES	7500
19 / 0800	0.15	108.0	16.2	1.15	24.4	28.1	44.3	16.6	7.20	13.4	YES	8500
20 / 0700	0.10	119.0	11.9	1.11	28.9	32.1	44.0	14.7	7.10	14.6	YES	7500
21 / 0200	0.10	141.0	14.1	1.17	35.1	41.1	55.2	14.4	7.10	15.0	YES	6500
22 / 2200	0.21	108.0	22.7	1.17	24.4	28.5	51.2	15.9	7.20	14.1	YES	8500
23 / 0200	0.14	108.0	15.1	1.14	24.4	27.8	42.9	15.8	7.20	14.1	YES	8500
24 / 0100	0.14	108.0	15.1	1.13	24.4	27.6	42.7	16.6	7.10	12.9	YES	8500
25 / 0400	0.08	108.0	8.6	1.15	24.4	28.1	36.7	17.2	7.10	12.4	YES	8500
26 / 2200	0.10	108.0	10.8	1.17	24.4	28.5	39.3	17.1	7.00	12.1	YES	8500
27 / 1500	0.14	95.0	13.3	1.18	21.2	25.0	38.3	17.2	7.10	12.5	YES	9500
28 / 1300	0.10	108.0	10.8	1.20	24.4	29.3	40.1	17.6	7.10	12.1	YES	8500
29 / 0500	0.18	95.0	17.1	1.19	21.2	25.2	42.3	17.9	7.00	11.5	YES	9500
30 / 1200	0.11	108.0	11.9	1.16	24.4	28.3	40.2	17.9	7.10	11.9	YES	8000

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION