

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine

Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

October, 2025

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
10/1/2025	---	---	---	0.02	0.03	0.03	0.03 NTU
10/2/2025	---	---	0.02	0.02	0.02	0.02	0.03 NTU
10/3/2025	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/4/2025	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/5/2025	---	---	0.02	0.02	0.02	0.02	0.03 NTU
10/6/2025	---	---	0.02	0.02	0.02	0.02	0.03 NTU
10/7/2025	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/8/2025	---	---	0.02	0.02	0.03	0.03	0.03 NTU
10/9/2025	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/10/202	---	---	0.02	0.02	0.02	0.02	0.03 NTU
10/11/202	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/12/202	---	---	0.02	0.02	0.02	0.02	0.02 NTU
10/13/202	---	---	---	0.02	0.02	0.02	0.02 NTU
10/14/202	---	---	---	0.02	0.02	0.02	0.02 NTU
10/15/202	---	---	0.02	0.02	0.02	---	0.02 NTU
10/16/202	---	---	0.02	0.02	0.03	---	0.03 NTU
10/17/202	---	---	0.02	0.04	0.02	---	0.04 NTU
10/18/202	---	---	0.02	0.02	0.03	---	0.04 NTU
10/19/202	---	---	0.02	0.02	0.02	---	0.02 NTU
10/20/202	---	---	0.03	0.02	0.02	---	0.03 NTU
10/21/202	---	---	0.02	0.02	0.03	---	0.03 NTU
10/22/202	---	---	0.02	0.02	0.03	---	0.03 NTU
10/23/202	---	---	0.02	0.02	0.02	---	0.03 NTU
10/24/202	---	---	0.02	0.02	0.02	---	0.02 NTU
10/25/202	---	---	0.02	0.02	0.02	---	0.03 NTU
10/26/202	---	---	0.02	0.02	0.02	---	0.02 NTU
10/27/202	---	---	---	0.02	0.02	---	0.02 NTU
10/28/202	---	---	0.02	0.02	0.03	---	0.03 NTU
10/29/202	---	---	0.02	0.02	0.02	---	0.02 NTU
10/30/202	---	---	0.02	0.02	0.02	---	0.03 NTU
10/31/202	---	---	0.02	0.02	0.02	---	0.04 NTU

Conventional or Direct Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3 ? Yes All Turbidity readings < 1 NTU? Yes All Turbidity readings < IFE triggers? Yes	CT's met everyday? Yes (see back of sheet)	CI Residual at entry point always > 0.2 mg/l? Yes	
Notes: Dashed lines (---) = No Plant Operations		Printed Name: Adam B Smith Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430	

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP-:WTP-A	October, 2025	Required Log Inactivation: 0.5
--	----------------------	---

Date Time	Segment 1 CFE			Segment 2 EFF								
	Min CFE Cl2 Residual (C)	Actual CT		Min.Cl2 Residual At 1st User (C)	Actual CT	TOTAL Actual CT	Temp	pH	Required CT	CT Met	Peak Hourly Flow	
							lowest	highest				
	mg/L	(T)	C X T	mg/L	(T)	C X T	C x T	C		Tables	Yes/No	(GPM)
1 / 1800	0.10	108.0	10.8	1.20	24.4	29.3	40.1	14.1	7.30	16.5	YES	8500
2 / 1400	0.06	119.0	7.1	1.19	28.9	34.4	41.5	14.1	7.30	16.5	YES	7500
3 / 0800	0.05	141.0	7.1	1.11	35.1	39.0	46.0	12.6	7.30	18.1	YES	6500
4 / 0900	0.04	161.0	6.4	1.12	43.5	48.7	55.2	12.3	7.30	18.7	YES	5500
5 / 2300	0.19	108.0	20.5	1.26	24.4	30.7	51.3	13.1	7.30	17.8	YES	8500
6 / 2200	0.12	108.0	13.0	1.20	24.4	29.3	42.2	13.5	7.30	17.2	YES	8500
7 / 1700	0.06	141.0	8.5	1.19	35.1	41.8	50.2	12.1	7.30	19.1	YES	6500
8 / 1400	0.16	108.0	17.3	1.20	24.4	29.3	46.6	12.2	7.30	19.0	YES	8500
9 / 1500	0.12	141.0	16.9	1.24	35.1	43.5	60.4	12.1	7.30	19.2	YES	6500
10 / 0800	0.13	141.0	18.3	1.12	35.1	39.3	57.6	11.4	7.30	19.8	YES	6500
11 / 0800	0.05	161.0	8.1	1.16	43.5	50.5	58.5	10.8	7.30	20.7	YES	5500
12 / 0800	0.05	161.0	8.1	1.08	43.5	47.0	55.0	11.4	7.30	19.7	YES	5500
13 / 1200	0.03	161.0	4.8	1.12	43.5	48.7	53.5	10.9	7.30	20.5	YES	5500
14 / 1200	0.01	161.0	1.6	1.10	43.5	47.9	49.5	11.5	7.30	19.6	YES	5500
15 / 1700	0.14	119.0	16.7	1.21	28.9	35.0	51.6	11.8	7.30	19.5	YES	7500
16 / 1400	0.15	108.0	16.2	1.17	24.4	28.5	44.7	10.7	7.20	20.1	YES	8500
17 / 1700	0.15	108.0	16.2	1.25	24.4	30.5	46.7	10.2	7.30	21.7	YES	8500
18 / 0900	0.09	108.0	9.7	1.20	24.4	29.3	39.0	10.2	7.30	21.6	YES	8500
19 / 0800	0.04	119.0	4.8	1.10	28.9	31.8	36.5	10.7	7.30	20.7	YES	7500
20 / 1500	0.16	108.0	17.3	1.18	24.4	28.8	46.1	10.2	7.30	21.6	YES	8500
21 / 1500	0.13	119.0	15.5	1.18	28.9	34.1	49.6	9.2	7.30	23.0	YES	7500
22 / 1600	0.16	108.0	17.3	1.16	24.4	28.3	45.6	9.4	7.30	22.7	YES	8500
23 / 0800	0.05	119.0	6.0	1.09	28.9	31.5	37.5	9.2	7.30	22.8	YES	7500
24 / 1400	0.30	108.0	32.4	1.25	24.4	30.5	62.9	9.9	7.30	22.2	YES	8500
25 / 0800	0.13	119.0	15.5	1.14	28.9	32.9	48.4	9.6	7.30	22.3	YES	7500
26 / 0800	0.06	141.0	8.5	1.12	35.1	39.3	47.8	9.8	7.30	22.0	YES	6500
27 / 1600	0.11	119.0	13.1	1.23	28.9	35.5	48.6	9.2	7.30	23.2	YES	7500
28 / 1400	0.09	108.0	9.7	1.21	24.4	29.5	39.2	9.2	7.20	22.3	YES	8500
29 / 0800	0.08	141.0	11.3	1.08	35.1	37.9	49.2	9.6	7.30	22.2	YES	6500
30 / 1500	0.08	108.0	8.6	1.15	24.4	28.1	36.7	10.3	7.20	20.6	YES	8500
31 / 0800	0.02	119.0	2.4	1.16	28.9	33.5	35.9	9.4	7.20	21.9	YES	7500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION