

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine

Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

November, 2025

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
11/1/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/2/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/3/2025	---	---	0.02	0.02	0.03	---	0.03 NTU
11/4/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/5/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/6/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/7/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
11/8/2025	---	---	---	0.02	0.02	---	0.02 NTU
11/9/2025	---	---	0.02	0.02	0.02	---	0.04 NTU
11/10/202	---	---	0.02	0.02	0.02	---	0.03 NTU
11/11/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/12/202	---	---	0.02	0.02	0.03	---	0.03 NTU
11/13/202	---	---	0.03	0.02	---	---	0.03 NTU
11/14/202	---	---	0.02	0.02	0.02	---	0.03 NTU
11/15/202	---	---	---	0.02	0.02	---	0.03 NTU
11/16/202	---	---	0.02	0.02	0.03	---	0.03 NTU
11/17/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/18/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/19/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/20/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/21/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/22/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/23/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/24/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/25/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/26/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/27/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/28/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/29/202	---	---	0.02	0.02	0.02	---	0.02 NTU
11/30/202	---	---	0.02	0.02	0.02	---	0.02 NTU

Conventional or Direct Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3 ? Yes All Turbidity readings < 1 NTU? Yes All Turbidity readings < IFE triggers? Yes	CT's met everyday? Yes (see back of sheet)	CI Residual at entry point always > 0.2 mg/l? Yes	
Notes: Dashed lines (---) = No Plant Operations		Printed Name: Adam B Smith Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430	

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP-:WTP-A	November, 2025	Required Log Inactivation: 0.5
--	-----------------------	---

Date Time	<i>Segment 1 CFE</i>			<i>Segment 2 EFF</i>			TOTAL Actual CT	Temp lowest highest	pH highest	Required CT Tables	CT Met Yes/No	Peak Hourly Flow (GPM)
	Min CFE Cl2 Residual (C)	Actual CT		Min.Cl2 Residual At 1st User (C)	Actual CT							
	mg/L (T)	C X T		mg/L (T)	C X T							
1 / 0800	0.06	141.0	8.5	1.17	35.1	41.1	49.5	9.3	7.20	22.1	YES	6500
2 / 1400	0.08	141.0	11.3	1.22	35.1	42.8	54.1	9.5	7.20	21.9	YES	6500
3 / 1200	0.10	108.0	10.8	1.17	24.4	28.5	39.3	9.7	7.20	21.5	YES	8500
4 / 0800	0.04	141.0	5.6	1.10	35.1	38.6	44.2	9.2	7.30	22.8	YES	6500
5 / 1400	0.12	119.0	14.3	1.17	28.9	33.8	48.1	9.8	7.20	21.4	YES	7500
6 / 0800	0.02	141.0	2.8	1.06	35.1	37.2	40.0	10.6	7.30	20.7	YES	6500
7 / 0800	0.01	141.0	1.4	1.06	35.1	37.2	38.6	9.9	7.30	21.7	YES	6500
8 / 1300	0.10	108.0	10.8	1.19	24.4	29.0	39.8	10.3	7.30	21.5	YES	8500
9 / 0900	0.06	119.0	7.1	1.16	28.9	33.5	40.7	9.7	7.30	22.2	YES	7500
10 / 0800	0.04	141.0	5.6	1.03	35.1	36.2	41.8	9.2	7.20	21.9	YES	6500
11 / 0800	0.03	141.0	4.2	1.14	35.1	40.0	44.2	9.5	7.20	21.7	YES	6500
12 / 1400	0.04	119.0	4.8	1.16	28.9	33.5	38.3	9.1	7.20	22.3	YES	7500
13 / 0800	0.03	141.0	4.2	1.12	35.1	39.3	43.5	9.8	7.20	21.2	YES	6500
14 / 0800	0.03	141.0	4.2	1.04	35.1	36.5	40.7	10.4	7.30	21.0	YES	6500
15 / 1000	0.04	119.0	4.8	1.15	28.9	33.2	38.0	9.9	7.20	21.2	YES	7500
16 / 0900	0.12	119.0	14.3	1.18	28.9	34.1	48.4	9.6	7.20	21.7	YES	7500
17 / 1300	0.06	141.0	8.5	1.15	35.1	40.4	48.8	9.1	7.20	22.3	YES	6500
18 / 1700	0.19	119.0	22.6	1.13	28.9	32.7	55.3	10.1	7.20	20.9	YES	7500
19 / 1100	0.09	119.0	10.7	1.20	28.9	34.7	45.4	9.3	7.20	22.2	YES	7500
20 / 1600	0.21	119.0	25.0	1.21	28.9	35.0	60.0	9.5	7.20	21.9	YES	7500
21 / 0800	0.16	141.0	22.6	1.13	35.1	39.7	62.2	8.2	7.20	23.6	YES	6500
22 / 0800	0.16	141.0	22.6	1.17	35.1	41.1	63.6	7	7.20	25.7	YES	6500
23 / 0900	0.16	141.0	22.6	1.17	35.1	41.1	63.6	6.8	7.30	27.0	YES	6500
24 / 1300	0.16	141.0	22.6	1.17	35.1	41.1	63.6	7.3	7.20	25.2	YES	6500
25 / 1500	0.09	141.0	12.7	1.14	35.1	40.0	52.7	8.4	7.30	24.2	YES	6500
26 / 0800	0.07	141.0	9.9	1.18	35.1	41.4	51.3	8.2	7.30	24.6	YES	6500
27 / 0800	0.16	141.0	22.6	1.18	35.1	41.4	64.0	8.4	7.20	23.5	YES	6500
28 / 0800	0.15	141.0	21.2	1.14	35.1	40.0	61.2	7.6	7.20	24.6	YES	6500
29 / 1500	0.15	141.0	21.2	1.16	35.1	40.7	61.9	7.7	7.20	24.5	YES	6500
30 / 0900	0.04	161.0	6.4	1.11	43.5	48.3	54.7	7.4	7.30	25.8	YES	5500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION