

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

December, 2025

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
12/1/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/2/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/3/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/4/2025	---	---	0.02	---	0.02	---	0.02 NTU
12/5/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/6/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/7/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/8/2025	---	---	0.02	0.02	---	---	0.02 NTU
12/9/2025	---	---	0.02	0.02	0.02	---	0.02 NTU
12/10/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/11/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/12/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/13/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/14/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/15/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/16/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/17/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/18/202	---	---	0.02	0.04	0.02	---	0.04 NTU
12/19/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/20/202	---	---	---	0.02	0.02	---	0.02 NTU
12/21/202	---	---	---	0.02	0.02	---	0.02 NTU
12/22/202	---	---	0.03	0.02	0.02	0.02	0.05 NTU
12/23/202	---	---	0.02	0.02	---	---	0.02 NTU
12/24/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/25/202	---	---	0.02	0.02	---	---	0.02 NTU
12/26/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/27/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/28/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/29/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/30/202	---	---	0.02	0.02	0.02	---	0.02 NTU
12/31/202	---	---	0.02	0.02	0.02	---	0.02 NTU

Conventional or Direct Filtration Monthly Summary	Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3? Yes All Turbidity readings < 1 NTU? Yes All Turbidity readings < IFE triggers? Yes	CT's met everyday? Yes (see back of sheet)	CI Residual at entry point always > 0.2 mg/l? Yes

Notes: Dashed lines (---) = No Plant Operations	Printed Name: Adam B Smith Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430
--	---

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP--:WTP-A December, 2025 Required Log Inactivation: 0.5

Date Time	<i>Segment 1 CFE</i>			<i>Segment 2 EFF</i>			TOTAL Actual CT	Temp lowest C	pH highest	Required CT Tables	CT Met Yes/No	Peak Hourly Flow (GPM)
	Min CFE Cl2 Residual (C)	Actual CT	Min. Cl2 Residual At 1st User (C)	Actual CT	C x T							
	mg/L	(T)	mg/L	(T)								
	C X T	C X T	C X T									
1 / 1500	0.10	141.0	14.1	1.14	35.1	40.0	54.1	7.3	7.20	25.1	YES	6500
2 / 0800	0.09	141.0	12.7	1.11	35.1	39.0	51.7	7.1	7.30	26.3	YES	6500
3 / 1400	0.16	141.0	22.6	1.17	35.1	41.1	63.6	6.9	7.20	25.9	YES	6500
4 / 0800	0.09	141.0	12.7	1.11	35.1	39.0	51.7	6.5	7.30	27.4	YES	6500
5 / 1500	0.18	141.0	25.4	1.14	35.1	40.0	65.4	8	7.20	24.0	YES	6500
6 / 0800	0.18	141.0	25.4	1.16	35.1	40.7	66.1	8.9	7.20	22.6	YES	6500
7 / 0800	0.08	161.0	12.9	1.20	43.5	52.2	65.1	9.2	7.20	22.3	YES	5500
8 / 1300	0.15	141.0	21.2	1.16	35.1	40.7	61.9	8.9	7.20	22.6	YES	6500
9 / 0800	0.15	141.0	21.2	1.16	35.1	40.7	61.9	9.4	7.20	21.9	YES	6500
10 / 0900	0.17	141.0	24.0	1.15	35.1	40.4	64.3	9.8	7.20	21.3	YES	6500
11 / 0800	0.13	141.0	18.3	1.05	35.1	36.9	55.2	9.8	7.20	21.1	YES	6500
12 / 0900	0.11	141.0	15.5	1.15	35.1	40.4	55.9	9.2	7.20	22.2	YES	6500
13 / 1400	0.23	119.0	27.4	1.20	28.9	34.7	62.1	8.3	7.20	23.7	YES	7500
14 / 0800	0.10	141.0	14.1	1.20	35.1	42.1	56.2	7.6	7.30	25.7	YES	6500
15 / 0800	0.11	141.0	15.5	1.19	35.1	41.8	57.3	7.3	7.30	26.2	YES	6500
16 / 1700	0.13	141.0	18.3	1.17	35.1	41.1	59.4	8.2	7.20	23.7	YES	6500
17 / 0800	0.06	141.0	8.5	1.13	35.1	39.7	48.1	9.4	7.30	22.6	YES	6500
18 / 0800	0.02	161.0	3.2	1.13	43.5	49.2	52.4	9.3	7.30	22.8	YES	5500
19 / 1300	0.10	141.0	14.1	1.28	35.1	44.9	59.0	10.1	7.30	22.0	YES	6500
20 / 1000	0.04	161.0	6.4	1.07	43.5	46.5	53.0	9	7.30	23.1	YES	5500
21 / 1100	0.03	119.0	3.6	1.24	28.9	35.8	39.4	8.2	7.30	24.8	YES	7500
22 / 0800	0.10	141.0	14.1	1.19	35.1	41.8	55.9	8.8	7.30	23.7	YES	6500
23 / 1200	0.05	141.0	7.1	1.25	35.1	43.9	50.9	8.4	7.20	23.6	YES	6500
24 / 0700	0.03	141.0	4.2	1.04	35.1	36.5	40.7	8.4	7.20	23.1	YES	6500
25 / 1300	0.06	141.0	8.5	1.17	35.1	41.1	49.5	8.6	7.20	23.1	YES	6500
26 / 0800	0.03	141.0	4.2	1.09	35.1	38.3	42.5	8.4	7.30	24.1	YES	6500
27 / 0800	0.08	141.0	11.3	1.10	35.1	38.6	49.9	8.1	7.20	23.7	YES	6500
28 / 1300	0.05	161.0	8.1	1.15	43.5	50.0	58.1	7.3	7.20	25.2	YES	5500
29 / 1300	0.02	161.0	3.2	1.07	43.5	46.5	49.8	6.8	7.20	25.8	YES	5500
30 / 1100	0.04	141.0	5.6	1.19	35.1	41.8	47.4	6.9	7.20	26.0	YES	6500
31 / 0900	0.04	141.0	5.6	1.20	35.1	42.1	47.8	6.9	7.20	26.0	YES	6500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION