

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

January, 2026

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
1/1/2026	---	---	---	0.02	0.02	---	0.02 NTU
1/2/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/3/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/4/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/5/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/6/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/7/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/8/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/9/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/10/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/11/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/12/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/13/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/14/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/15/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/16/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/17/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/18/2026	---	---	---	0.02	0.02	---	0.02 NTU
1/19/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/20/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/21/2026	---	---	---	0.02	0.02	---	0.02 NTU
1/22/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/23/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/24/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/25/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/26/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/27/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/28/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
1/29/2026	---	---	0.02	0.02	---	---	0.02 NTU
1/30/2026	---	---	0.02	0.02	---	---	0.02 NTU
1/31/2026	---	---	---	0.02	0.02	---	0.02 NTU

Conventional or Direct Filtration Monthly Summary	Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3? (Yes)	CT's met everyday? (Yes)	CI Residual at entry point always > 0.2 mg/l? (Yes)
All Turbidity readings < 1 NTU? (Yes)	(see back of sheet)	
All Turbidity readings < IFE triggers? (Yes)		

Notes:	Printed Name: Adam B Smith
Dashed lines (---) = No Plant Operations	Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP--:WTP-A **January, 2026** **Required Log Inactivation: 0.5**

Date Time	<i>Segment 1 CFE</i>			<i>Segment 2 EFF</i>			TOTAL Actual CT C x T	Temp lowest highest C	pH highest	Required CT Tables	CT Met Yes/No	Peak Hourly Flow (GPM)
	Min CFE Cl2 Residual (C) mg/L	Actual CT (T)	C X T	Min.Cl2 Residual At 1st User (C) mg/L	Actual CT (T)	C X T						
1 / 1000	0.05	141.0	7.1	1.12	35.1	39.3	46.4	7.9	7.20	24.1	YES	6500
2 / 1100	0.04	141.0	5.6	1.12	35.1	39.3	45.0	8.6	7.20	23.0	YES	6500
3 / 0800	0.08	141.0	11.3	1.13	35.1	39.7	50.9	8.6	7.20	23.0	YES	6500
4 / 0800	0.11	161.0	17.7	1.12	43.5	48.7	66.4	8.6	7.20	23.0	YES	5500
5 / 0800	0.03	161.0	4.8	1.04	43.5	45.2	50.1	8.6	7.30	23.6	YES	5500
6 / 0800	0.04	161.0	6.4	1.19	43.5	51.8	58.2	8.3	7.20	23.6	YES	5500
7 / 1200	0.03	141.0	4.2	1.19	35.1	41.8	46.0	8.3	7.20	23.6	YES	6500
8 / 1200	0.02	141.0	2.8	1.13	35.1	39.7	42.5	7.7	7.20	24.4	YES	6500
9 / 0800	0.02	141.0	2.8	1.06	35.1	37.2	40.0	7	7.20	25.4	YES	6500
10 / 0800	0.08	161.0	12.9	1.16	43.5	50.5	63.3	6.8	7.20	26.0	YES	5500
11 / 0800	0.09	161.0	14.5	1.13	43.5	49.2	63.6	6.8	7.30	26.9	YES	5500
12 / 0800	0.09	141.0	12.7	1.14	35.1	40.0	52.7	6.5	7.20	26.5	YES	6500
13 / 0800	0.07	161.0	11.3	1.15	43.5	50.0	61.3	6.3	7.20	26.9	YES	5500
14 / 0800	0.09	161.0	14.5	1.16	43.5	50.5	65.0	6.2	7.20	27.1	YES	5500
15 / 0900	0.14	141.0	19.7	1.19	35.1	41.8	61.5	6.1	7.20	27.4	YES	6500
16 / 0800	0.08	161.0	12.9	1.17	43.5	50.9	63.8	5.9	7.20	27.7	YES	5500
17 / 1500	0.15	141.0	21.2	1.22	35.1	42.8	64.0	6.2	7.20	27.3	YES	6500
18 / 1100	0.11	119.0	13.1	1.22	28.9	35.3	48.3	6.3	7.20	27.1	YES	7500
19 / 1500	0.11	141.0	15.5	1.20	35.1	42.1	57.6	6.3	7.20	27.1	YES	6500
20 / 0800	0.08	141.0	11.3	1.16	35.1	40.7	52.0	6.2	7.20	27.1	YES	6500
21 / 1700	0.11	141.0	15.5	1.15	35.1	40.4	55.9	6.1	7.20	27.3	YES	6500
22 / 1600	0.17	141.0	24.0	1.22	35.1	42.8	66.8	6.3	7.20	27.1	YES	6500
23 / 1600	0.14	141.0	19.7	1.17	35.1	41.1	60.8	6.2	7.20	27.1	YES	6500
24 / 0800	0.11	141.0	15.5	1.08	35.1	37.9	53.4	6.3	7.20	26.7	YES	6500
25 / 0900	0.10	161.0	16.1	1.13	43.5	49.2	65.3	5	7.30	30.4	YES	5500
26 / 0800	0.18	161.0	29.0	1.15	43.5	50.0	79.0	5.1	7.30	30.2	YES	5500
27 / 0900	0.18	141.0	25.4	1.17	35.1	41.1	66.4	5.5	7.20	28.5	YES	6500
28 / 0800	0.13	161.0	20.9	1.19	43.5	51.8	72.7	6.1	7.20	27.4	YES	5500
29 / 0900	0.20	141.0	28.2	1.16	35.1	40.7	68.9	7.1	7.30	26.5	YES	6500
30 / 0900	0.10	141.0	14.1	1.14	35.1	40.0	54.1	7.1	7.30	26.4	YES	6500
31 / 1100	0.09	119.0	10.7	1.17	28.9	33.8	44.5	7.1	7.20	25.6	YES	7500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION