

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

February, 2026

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
2/1/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/2/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/3/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/4/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/5/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/6/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/7/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/8/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/9/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/10/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/11/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/12/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/13/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/14/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/15/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/16/2026	---	---	0.02	0.01	0.02	---	0.02 NTU
2/17/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/18/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/19/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/20/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/21/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/22/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/23/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/24/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/25/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/26/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
2/27/2026	---	---	0.02	0.03	0.02	---	0.03 NTU
2/28/2026	---	---	0.02	0.02	0.02	---	0.02 NTU

Conventional or Direct Filtration Monthly Summary	Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3? <input checked="" type="checkbox"/> Yes All Turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes All Turbidity readings < IFE triggers? <input checked="" type="checkbox"/> Yes	CT's met everyday? <input checked="" type="checkbox"/> Yes (see back of sheet)	CI Residual at entry point always > 0.2 mg/l? <input checked="" type="checkbox"/> Yes
Notes: Dashed lines (---) = No Plant Operations	Printed Name: Adam B Smith Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430	

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP-:WTP-A February, 2026 Required Log Inactivation: 0.5

Date Time	<i>Segment 1 CFE</i>			<i>Segment 2 EFF</i>			TOTAL Actual CT C x T	Temp lowest highest C	pH highest	Required CT Tables	CT Met Yes/No	Peak Hourly Flow (GPM)
	Min CFE Cl2 Residual (C) mg/L	Actual CT (T) C X T	Actual CT (T) C X T	Min.Cl2 Residual At 1st User (C) mg/L	Actual CT (T) C X T	Actual CT (T) C X T						
1 / 1600	0.15	119.0	17.9	1.18	28.9	34.1	52.0	7.1	7.20	25.6	YES	7500
2 / 1700	0.20	119.0	23.8	1.21	28.9	35.0	58.8	7.6	7.20	24.8	YES	7500
3 / 0800	0.12	141.0	16.9	1.10	35.1	38.6	55.5	6.9	7.30	26.6	YES	6500
4 / 0800	0.09	141.0	12.7	1.07	35.1	37.6	50.2	6.8	7.20	25.8	YES	6500
5 / 0800	0.10	161.0	16.1	1.15	43.5	50.0	66.1	6.8	7.20	26.0	YES	5500
6 / 0900	0.10	141.0	14.1	1.14	35.1	40.0	54.1	6.9	7.20	25.8	YES	6500
7 / 0800	0.08	141.0	11.3	1.09	35.1	38.3	49.5	7.1	7.20	25.3	YES	6500
8 / 1600	0.17	141.0	24.0	1.24	35.1	43.5	67.5	8	7.20	24.3	YES	6500
9 / 1200	0.02	161.0	3.2	0.99	43.5	43.1	46.3	8	7.20	23.6	YES	5500
10 / 0800	0.03	161.0	4.8	0.96	43.5	41.8	46.6	7.8	7.20	23.8	YES	5500
11 / 0800	0.09	161.0	14.5	1.02	43.5	44.4	58.9	7.2	7.20	25.0	YES	5500
12 / 0800	0.04	161.0	6.4	0.90	43.5	39.2	45.6	8.5	7.30	23.4	YES	5500
13 / 0800	0.11	161.0	17.7	1.05	43.5	45.7	63.4	8.7	7.30	23.5	YES	5500
14 / 0800	0.19	141.0	26.8	1.07	35.1	37.6	64.3	8.2	7.30	24.3	YES	6500
15 / 1600	0.17	141.0	24.0	1.21	35.1	42.5	66.4	8.4	7.30	24.4	YES	6500
16 / 1300	0.06	161.0	9.7	1.11	43.5	48.3	57.9	8.1	7.30	24.6	YES	5500
17 / 1700	0.07	141.0	9.9	1.14	35.1	40.0	49.9	7.2	7.30	26.2	YES	6500
18 / 0800	0.10	141.0	14.1	1.16	35.1	40.7	54.8	6.2	7.30	28.1	YES	6500
19 / 0800	0.03	161.0	4.8	1.10	43.5	47.9	52.7	6.8	7.30	26.8	YES	5500
20 / 0800	0.07	161.0	11.3	1.12	43.5	48.7	60.0	6.8	7.30	26.9	YES	5500
21 / 0800	0.09	161.0	14.5	1.10	43.5	47.9	62.3	7.8	7.30	25.1	YES	5500
22 / 0800	0.14	141.0	19.7	1.14	35.1	40.0	59.8	7.7	7.30	25.4	YES	6500
23 / 0800	0.09	161.0	14.5	1.05	43.5	45.7	60.2	9.2	7.30	22.7	YES	5500
24 / 0800	0.06	161.0	9.7	1.11	43.5	48.3	57.9	9.3	7.30	22.7	YES	5500
25 / 0800	0.04	161.0	6.4	0.98	43.5	42.6	49.1	9.7	7.30	21.8	YES	5500
26 / 0800	0.03	161.0	4.8	1.00	43.5	43.5	48.3	9.7	7.20	21.1	YES	5500
27 / 0800	0.05	161.0	8.1	1.02	43.5	44.4	52.4	9.6	7.20	21.3	YES	5500
28 / 0800	0.08	161.0	12.9	1.04	43.5	45.2	58.1	9.6	7.20	21.3	YES	5500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION