

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Conventional or Direct Filtration

System Name: Grants Pass, City of ID #: OR4100342 WTP-:WTP-A

March, 2026

Date	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest Reading (NTU)
3/1/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/2/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/3/2026	---	---	0.02	0.02	0.02	---	0.03 NTU
3/4/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/5/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/6/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/7/2026	---	---	0.02	0.02	0.02	---	0.03 NTU
3/8/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/9/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/10/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/11/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/12/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/13/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/14/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/15/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/16/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/17/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/18/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/19/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/20/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/21/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/22/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/23/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/24/2026	---	---	0.03	0.02	0.03	---	0.03 NTU
3/25/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/26/2026	---	---	0.03	0.02	0.02	---	0.03 NTU
3/27/2026	---	---	0.02	0.02	0.02	---	0.02 NTU
3/28/2026	---	---	0.03	0.02	0.02	---	0.03 NTU
3/29/2026	---	---	0.03	0.02	0.02	---	0.03 NTU
3/30/2026	---	---	0.03	0.02	0.03	---	0.03 NTU
3/31/2026	---	---	0.02	0.02	0.03	0.03	0.03 NTU

Conventional or Direct Filtration Monthly Summary	Monthly Summary (Answer Yes or No)	
95% of Turbidity readings ≤ 0.3? Yes	CT's met everyday? Yes	CI Residual at entry point always > 0.2 mg/l Yes
All Turbidity readings < 1 NTU? Yes	(see back of sheet)	
All Turbidity readings < IFE triggers? Yes		

Notes: Dashed lines (---) = No Plant Operations	Printed Name: Adam B Smith Signature: _____ Phone#: (541)450-6118 Cert.# : T-09430
--	---

OHA - Drinking Water Program - Surface Water Quality Data Form

Grants Pass, City of ID #: OR4100342 WTP--:WTP-A **March, 2026** **Required Log Inactivation: 0.5**

Date Time	<i>Segment 1 CFE</i>			<i>Segment 2 EFF</i>			TOTAL Actual CT C x T	Temp lowest highest C	pH highest	Required CT Tables	CT Met Yes/No	Peak Hourly Flow (GPM)
	Min CFE Cl2 Residual (C) mg/L	Actual CT (T)	C X T	Min.Cl2 Residual At 1st User (C) mg/L	Actual CT (T)	C X T						
1 / 0900	0.17	141.0	24.0	1.22	35.1	42.8	66.8	9.7	7.30	22.4	YES	6500
2 / 0800	0.03	161.0	4.8	1.01	43.5	43.9	48.8	10.3	7.30	21.0	YES	5500
3 / 0800	0.02	161.0	3.2	0.86	43.5	37.4	40.6	10.3	7.30	20.7	YES	5500
4 / 0800	0.03	161.0	4.8	1.01	43.5	43.9	48.8	10.5	7.30	20.8	YES	5500
5 / 1600	0.09	141.0	12.7	1.17	35.1	41.1	53.8	9.6	7.30	22.4	YES	6500
6 / 1100	0.05	141.0	7.1	1.10	35.1	38.6	45.7	8.8	7.30	23.5	YES	6500
7 / 0800	0.09	141.0	12.7	1.06	35.1	37.2	49.9	9.6	7.30	22.1	YES	6500
8 / 1000	0.11	141.0	15.5	1.21	35.1	42.5	58.0	10.6	7.30	21.1	YES	6500
9 / 1700	0.06	141.0	8.5	1.20	35.1	42.1	50.6	11.1	7.30	20.4	YES	6500
10 / 0800	0.02	161.0	3.2	1.09	43.5	47.4	50.6	10	7.30	21.6	YES	5500
11 / 0800	0.11	141.0	15.5	1.16	35.1	40.7	56.2	9.3	7.30	22.8	YES	6500
12 / 0800	0.07	141.0	9.9	1.07	35.1	37.6	47.4	9.4	7.20	21.7	YES	6500
13 / 0800	0.05	141.0	7.1	1.05	35.1	36.9	43.9	10.3	7.20	20.4	YES	6500
14 / 0800	0.02	161.0	3.2	1.07	43.5	46.5	49.8	11.2	7.30	20.0	YES	5500
15 / 1600	0.06	141.0	8.5	1.20	35.1	42.1	50.6	10.8	7.30	20.8	YES	6500
16 / 0800	0.03	161.0	4.8	1.10	43.5	47.9	52.7	10.3	7.30	21.2	YES	5500
17 / 1500	0.05	108.0	5.4	1.17	24.4	28.5	33.9	11.1	7.30	20.3	YES	8500
18 / 0900	0.03	108.0	3.2	1.14	24.4	27.8	31.1	11.3	7.30	20.0	YES	8500
19 / 0800	0.02	161.0	3.2	1.02	43.5	44.4	47.6	11.6	7.30	19.3	YES	5500
20 / 1500	0.05	119.0	6.0	1.15	28.9	33.2	39.2	12.1	7.40	19.7	YES	7500
21 / 0900	0.04	119.0	4.8	1.18	28.9	34.1	38.9	12.6	7.30	18.2	YES	7500
22 / 1600	0.04	119.0	4.8	1.15	28.9	33.2	38.0	11.7	7.30	19.5	YES	7500
23 / 0800	0.02	141.0	2.8	0.99	35.1	34.7	37.6	11.1	7.60	22.1	YES	6500
24 / 1400	0.17	95.0	16.1	1.20	21.2	25.4	41.6	13	7.20	17.1	YES	9500
25 / 0800	0.02	119.0	2.4	1.06	28.9	30.6	33.0	12.3	7.30	18.6	YES	7500
26 / 0800	0.02	119.0	2.4	1.06	28.9	30.6	33.0	11.7	7.30	19.3	YES	7500
27 / 0800	0.02	119.0	2.4	1.13	28.9	32.7	35.0	11	7.40	21.1	YES	7500
28 / 0800	0.02	119.0	2.4	1.07	28.9	30.9	33.3	11.6	7.30	19.4	YES	7500
29 / 1700	0.03	119.0	3.6	1.16	28.9	33.5	37.1	12	7.40	19.8	YES	7500
30 / 1600	0.04	108.0	4.3	1.15	24.4	28.1	32.4	12.8	7.30	17.9	YES	8500
31 / 1800	0.04	108.0	4.3	1.15	24.4	28.1	32.4	11.7	7.40	20.2	YES	8500

1 - Dashed line (---) = No Plant Operations or No Data

2 - Disinfection Segment 1 CFE T10 values taken from MWH Tracer Study - September, 2012. - PRE-FILTRATION

3 - Disinfection Segment 2 EFF T10 Values (T) taken from Black and Veatch Tracer Study - June, 2003. - POST FILTRATION