

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems **County:** **Multnomah**

System Name:		Corbett Water District		ID#: 41		00359		WTP - : A		Month/Year:		April-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]						
4/1/25	0.035	0.035	0.034	0.034	0.035	0.035	0.0350						
4/2/25	0.034	0.034	0.034	0.034	0.035	0.036	0.0360						
4/3/25	0.036	0.036	0.036	0.036	0.036	0.037	0.0370						
4/4/25	0.036	0.036	0.035	0.035	0.035	0.036	0.0360						
4/5/25	0.035	0.035	0.034	0.035	0.035	0.036	0.0360						
4/6/25	0.035	0.036	0.035	0.035	0.035	0.035	0.0360						
4/7/25	0.035	0.035	0.035	0.035	0.036	0.035	0.0360						
4/8/25	0.035	0.035	0.035	0.035	0.034	0.034	0.0350						
4/9/25	0.035	0.035	0.035	0.035	0.036	0.038	0.0380						
4/10/25	0.038	0.036	0.035	0.035	0.036	0.036	0.0380						
4/11/25	0.036	0.036	0.036	0.036	0.037	0.038	0.0380						
4/12/25	0.038	0.037	0.036	0.035	0.036	0.037	0.0380						
4/13/25	0.038	0.037	0.036	0.035	0.036	0.037	0.0380						
4/14/25	0.036	0.035	0.034	0.034	0.034	0.035	0.0360						
4/15/25	0.035	0.034	0.034	0.034	0.035	0.036	0.0360						
4/16/25	0.035	0.034	0.034	0.034	0.039	0.036	0.0390						
4/17/25	0.036	0.036	0.035	0.034	0.034	0.035	0.0360						
4/18/25	0.035	0.035	0.034	0.033	0.033	0.034	0.0350						
4/19/25	0.034	0.034	0.033	0.033	0.033	0.034	0.0340						
4/20/25	0.034	0.034	0.033	0.032	0.033	0.033	0.0340						
4/21/25	0.033	0.032	0.032	0.031	0.032	0.033	0.0330						
4/22/25	0.033	0.033	0.032	0.03	0.031	0.032	0.0330						
4/23/25	0.032	0.032	0.032	0.031	0.031	0.031	0.0320						
4/24/25	0.032	0.031	0.031	0.031	0.03	0.031	0.0320						
4/25/25	0.031	0.031	0.03	0.029	0.03	0.031	0.0310						
4/26/25	0.034	0.033	0.032	0.032	0.032	0.033	0.0340						
4/27/25	0.033	0.032	0.032	0.031	0.032	0.032	0.0330						
4/28/25	0.032	0.031	0.031	0.031	0.031	0.031	0.0320						
4/29/25	0.031	0.031	0.03	0.03	0.031	0.032	0.0320						
4/30/25	0.032	0.031	0.031	0.031	0.032	0.032	0.0320						
							0.0000						
Slow Sand/					Monthly Summary (Answer Yes or No)								
95% of daily turbidity readings ≤ 1 NTU? ² Yes					CT's met everyday? (see back)				All Cl2 residual at entry point ≥ 0.2 mg/l?				
All daily turbidity readings ≤ 5 NTU? Yes					Yes				Yes				
					SIGNATURE: <i>Alivia Pence</i>								
					Printed Name: Alivia Pence						5/2/25		
					PHONE #: (360)513-1405						CERT #: 937415		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form										WTP- : A
System Name:	Corbett Water District	ID#: 41	00359	Month/Year:	Apr-25	Disinfection <i>Giardia</i> Log Inactiv:	1			

Date / Time	Clearwell Segment				Reservoir Segment							Combined Segment		
	Cl ₂ Residual after Clearwell (C) ^{3,4}	Peak Hourly Demand Flow -Cwell	Contact Time - CWell (T) ⁴	Actual CT - Cwell	Cl ₂ Residual after Reservoir (C) ^{3,4}	Peak Hourly Demand Flow - Reserv.	Contact Time - Reserv. (T) ⁴	Actual CT - Reserv.	lowest Temp after Res	highest pH after Res	Required CT	Actual CT Cwell + Actual CT Res	(Act CT Cwell + Act CT Res) / Req CT	CT Met? (Act CT Cwell & Res / Req CT > 1.0?) ³
	[ppm or mg/L]	15.2	[minutes]	C X T	[ppm or mg/L]	[GPM]	[minutes]	C X T	[° C]		formula			Yes / No
4/1/25	1.11	500.7	139.15	154.46	Not used				8.2	7.91	60.83	154.46	2.54	YES
4/2/25	1.05	437.7	149.00	156.45					8.09	8.07	64.50	156.45	2.43	YES
4/3/25	1.1	462.9	145.06	159.56					8.01	8.02	64.05	159.56	2.49	YES
4/4/25	1.11	541.3	132.80	147.41					7.93	7.93	62.41	147.41	2.36	YES
4/5/25	1.15	507.6	138.07	158.78					8.19	7.95	62.05	158.78	2.56	YES
4/6/25	1.16	458	145.82	169.16					8.54	8	61.77	169.16	2.74	YES
4/7/25	1.17	474	143.32	167.69					8.78	8.01	61.06	167.69	2.75	YES
4/8/25	1.1	479.6	142.45	156.69					8.86	8.06	61.34	156.69	2.55	YES
4/9/25	1.06	474.3	143.28	151.87					8.85	7.96	58.92	151.87	2.58	YES
4/10/25	1.04	530.2	134.54	139.92					8.99	7.97	58.44	139.92	2.39	YES
4/11/25	1.11	463.6	144.95	160.89					9.13	8.01	59.21	160.89	2.72	YES
4/12/25	1.09	474	143.32	156.22					9.1	8.02	59.41	156.22	2.63	YES
4/13/25	1.07	462.4	145.14	155.30					8.94	8.04	60.35	155.30	2.57	YES
4/14/25	1.09	489	140.98	153.67					8.99	8.01	59.64	153.67	2.58	YES
4/15/25	1.13	530.3	134.52	152.01					9.3	7.94	57.21	152.01	2.66	YES
4/16/25	1.09	553.6	130.88	142.66					9.61	7.83	53.61	142.66	2.66	YES
4/17/25	1.16	495.6	139.95	162.34					9.93	7.78	51.95	162.34	3.12	YES
4/18/25	1.18	567.7	128.68	151.84					10.38	7.79	50.71	151.84	2.99	YES
4/19/25	1.17	490.1	140.81	164.74					10.67	7.85	50.75	164.74	3.25	YES
4/20/25	1.17	589.2	125.32	146.62					10.62	7.95	52.77	146.62	2.78	YES
4/21/25	1.16	475.7	143.06	165.95					10.33	7.94	53.56	165.95	3.10	YES
4/22/25	1.13	579.5	126.83	143.32					10.13	7.98	54.88	143.32	2.61	YES
4/23/25	1.26	529.2	134.70	169.72					10.04	7.97	55.84	169.72	3.04	YES
4/24/25	1.22	566.8	128.82	157.16					10.19	8.01	55.82	157.16	2.82	YES
4/25/25	1.15	571.4	128.10	147.32					10.49	8.05	55.05	147.32	2.68	YES
4/26/25	1.17	555.3	130.62	152.82					10.56	8.12	56.32	152.82	2.71	YES
4/27/25	1.17	587.5	125.58	146.93					10.27	8.12	57.43	146.93	2.56	YES
4/28/25	1.18	491.7	140.56	165.86					9.99	8.08	57.76	165.86	2.87	YES
4/29/25	1.23	573.1	127.83	157.24					9.86	8.11	59.25	157.24	2.65	YES
4/30/25	1.23	550.7	131.34	161.54					9.76	8.02	57.74	161.54	2.80	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS to be notified within 24 hours. ⁴ Chlorine residual and contact time to be determined during peak hourly demand flow of clearwell and reservoir.