

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems **County:** **Multnomah**

System Name:		Corbett Water District		ID#: 41		00359		WTP - : A		Month/Year:		October-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]						
10/1/25	0.029	0.029	0.029	0.029	0.029	0.03	0.0300						
10/2/25	0.03	0.03	0.03	0.03	0.03	0.03	0.0300						
10/3/25	0.031	0.03	0.03	0.03	0.03	0.03	0.0310						
10/4/25	0.031	0.03	0.03	0.03	0.03	0.031	0.0310						
10/5/25	0.031	0.03	0.03	0.03	0.03	0.031	0.0310						
10/6/25	0.031	0.03	0.031	0.03	0.03	0.031	0.0310						
10/7/25	0.03	0.03	0.03	0.03	0.03	0.031	0.0310						
10/8/25	0.031	0.03	0.03	0.03	0.031	0.031	0.0310						
10/9/25	0.031	0.031	0.031	0.031	0.031	0.032	0.0320						
10/10/25	0.031	0.031	0.031	0.031	0.031	0.031	0.0310						
10/11/25	0.032	0.031	0.031	0.031	0.031	0.032	0.0320						
10/12/25	0.032	0.032	0.032	0.032	0.033	0.033	0.0330						
10/13/25	0.033	0.033	0.034	0.034	0.034	0.034	0.0340						
10/14/25	0.034	0.034	0.033	0.033	0.033	0.033	0.0340						
10/15/25	0.032	0.033	0.032	0.032	0.032	0.032	0.0330						
10/16/25	0.033	0.032	0.032	0.032	0.032	0.032	0.0330						
10/17/25	0.032	0.032	0.032	0.032	0.032	0.032	0.0320						
10/18/25	0.033	0.032	0.032	0.032	0.032	0.032	0.0330						
10/19/25	0.033	0.032	0.032	0.032	0.032	0.033	0.0330						
10/20/25	0.034	0.034	0.034	0.035	0.036	0.036	0.0360						
10/21/25	0.036	0.035	0.035	0.035	0.034	0.034	0.0360						
10/22/25	0.034	0.034	0.034	0.034	0.034	0.034	0.0340						
10/23/25	0.034	0.034	0.033	0.033	0.033	0.033	0.0340						
10/24/25	0.033	0.033	0.032	0.032	0.032	0.032	0.0330						
10/25/25	0.032	0.032	0.032	0.032	0.032	0.032	0.0320						
10/26/25	0.032	0.032	0.032	0.032	0.033	0.033	0.0330						
10/27/25	0.033	0.033	0.033	0.033	0.033	0.034	0.0340						
10/28/25	0.034	0.034	0.034	0.033	0.034	0.035	0.0350						
10/29/25	0.037	0.035	0.034	0.028	0.031	0.024	0.0370						
10/30/25	0.024	0.022	0.023	0.025	0.028	0.028	0.0280						
10/31/25	0.039	0.025	0.025	0.025	0.024	0.027	0.0390						
Slow Sand/					Monthly Summary (Answer Yes or No)								
95% of daily turbidity readings $\leq$ 1 NTU? ² Yes					CT's met everyday? (see back)				All Cl2 residual at entry point $\geq$ 0.2 mg/l?				
All daily turbidity readings $\leq$ 5 NTU? Yes					Yes				Yes				
					SIGNATURE: <i>Alivia Pence</i>								
					Printed Name: Alivia Pence						11/3/25		
					PHONE #: (360)513-1405						CERT #: 937415		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

System Name:

Corbett Water District

ID#: 41 00359

Month/Year:

Oct-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Clearwell Segment				Reservoir Segment						Combined Segment			
	Cl ₂ Residual after Clearwell (C) ^{3,4}	Peak Hourly Demand Flow -Cwell	Contact Time - CWell (T) ⁴	Actual CT - Cwell	Cl ₂ Residual after Reservoir (C) ^{3,4}	Peak Hourly Demand Flow - Reserv.	Contact Time - Reserv. (T) ⁴	Actual CT - Reserv.	lowest Temp after Res	highest pH after Res	Required CT	Actual CT Cwell + Actual CT Res	(Act CT Cwell + Act CT Res) / Req CT	CT Met? (Act CT Cwell & Res / Req CT > 1.0?) ³
	[ppm or mg/L]	15.2	[minutes]	C X T	[ppm or mg/L]	[GPM]	[minutes]	C X T	[° C]		formula			Yes / No
10/1/25	0.92	380.5	157.94	145.30	Not used				12.07	7.76	43.54	145.30	3.34	YES
10/2/25	0.95	355.1	161.91	153.81					11.95	7.84	45.29	153.81	3.40	YES
10/3/25	0.97	360.5	161.06	156.23					11.86	7.91	46.81	156.23	3.34	YES
10/4/25	0.92	362.2	160.80	147.93					11.86	8.03	48.57	147.93	3.05	YES
10/5/25	0.89	363.9	160.53	142.87					11.76	8.06	49.25	142.87	2.90	YES
10/6/25	0.86	414.5	152.62	131.26					11.66	8.03	48.88	131.26	2.69	YES
10/7/25	0.8	422.2	151.42	121.14					11.57	7.92	46.97	121.14	2.58	YES
10/8/25	0.78	438.3	148.90	116.14					11.44	7.84	45.95	116.14	2.53	YES
10/9/25	0.76	418.3	152.03	115.54					11.36	7.83	45.93	115.54	2.52	YES
10/10/25	0.72	407.7	153.69	110.65					11.29	7.87	46.59	110.65	2.38	YES
10/11/25	0.76	383.3	157.50	119.70					11.17	7.9	47.68	119.70	2.51	YES
10/12/25	0.81	372.2	159.24	128.98					10.95	7.92	49.01	128.98	2.63	YES
10/13/25	0.71	364.7	160.41	113.89					10.74	7.89	48.61	113.89	2.34	YES
10/14/25	0.66	355.3	161.88	106.84					10.43	7.94	50.23	106.84	2.13	YES
10/15/25	0.65	357.2	161.58	105.03					10.16	7.98	51.82	105.03	2.03	YES
10/16/25	0.68	364.5	160.44	109.10					9.9	7.98	52.92	109.10	2.06	YES
10/17/25	0.75	365.3	160.31	120.24					9.8	7.95	53.13	120.24	2.26	YES
10/18/25	0.78	371.3	159.38	124.31					9.68	7.91	52.98	124.31	2.35	YES
10/19/25	0.84	359.9	161.16	135.37					9.79	7.86	52.02	135.37	2.60	YES
10/20/25	0.79	358.3	161.41	127.51					9.8	7.85	51.50	127.51	2.48	YES
10/21/25	0.73	363.6	160.58	117.22					9.84	7.87	51.38	117.22	2.28	YES
10/22/25	0.75	375.1	158.78	119.09					9.92	7.88	51.40	119.09	2.32	YES
10/23/25	0.8	370.9	159.44	127.55					9.92	7.91	52.25	127.55	2.44	YES
10/24/25	0.84	352.7	162.28	136.32					9.92	7.54	46.03	136.32	2.96	YES
10/25/25	0.86	314.8	168.21	144.66					9.97	7.92	52.63	144.66	2.75	YES
10/26/25	0.8	313.8	168.36	134.69					9.89	7.86	51.43	134.69	2.62	YES
10/27/25	0.72	296.9	171.00	123.12					9.75	7.81	50.53	123.12	2.44	YES
10/28/25	0.64	310.2	168.93	108.11					9.69	7.82	50.45	108.11	2.14	YES
10/29/25	0.61	351.8	162.42	99.08					9.75	7.86	50.80	99.08	1.95	YES
10/30/25	0.62	366.8	160.08	99.25					9.73	7.94	52.40	99.25	1.89	YES
10/31/25	0.61	314.9	168.19	102.60					9.77	7.99	53.14	102.60	1.93	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS to be notified within 24 hours. ⁴ Chlorine residual and contact time to be determined

6.0

7.37

Revised February 2012