

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems **County:** **Multnomah**

System Name: Corbett Water District		ID#: 41		00359		WTP - : A		Month/Year: December-25			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]				
12/1/25	0.029	0.027	0.026	0.026	0.029	0.032	0.0320				
12/2/25	0.029	0.027	0.026	0.026	0.028	0.03	0.0300				
12/3/25	0.029	0.028	0.027	0.027	0.028	0.033	0.0330				
12/4/25	0.034	0.03	0.029	0.028	0.029	0.03	0.0340				
12/5/25	0.029	0.028	0.028	0.028	0.027	0.027	0.0290				
12/6/25	0.028	0.028	0.028	0.028	0.028	0.03	0.0300				
12/7/25	0.03	0.029	0.029	0.028	0.03	0.034	0.0340				
12/8/25	0.033	0.031	0.031	0.03	0.031	0.03	0.0330				
12/9/25	0.029	0.023	0.029	0.028	0.03	0.031	0.0310				
12/10/25	0.03	0.026	0.025	0.028	0.028	0.031	0.0310				
12/11/25	0.031	0.03	0.03	0.029	0.03	0.035	0.0350				
12/12/25	0.034	0.031	0.031	0.03	0.034	0.039	0.0390				
12/13/25	0.035	0.032	0.031	0.031	0.033	0.035	0.0350				
12/14/25	0.032	0.03	0.03	0.03	0.035	0.044	0.0440				
12/15/25	0.038	0.033	0.032	0.031	0.032	0.033	0.0380				
12/16/25	0.032	0.032	0.032	0.033	0.035	0.036	0.0360				
12/17/25	0.034	0.032	0.032	0.032	0.036	0.036	0.0360				
12/18/25	0.033	0.032	0.031	0.032	0.032	0.031	0.0330				
12/19/25	0.03	0.03	0.031	0.031	0.032	0.035	0.0350				
12/20/25	0.034	0.032	0.031	0.03	0.032	0.033	0.0340				
12/21/25	0.033	0.031	0.03	0.031	0.037	0.038	0.0380				
12/22/25	0.033	0.032	0.031	0.031	0.036	0.041	0.0410				
12/23/25	0.035	0.032	0.031	0.031	0.035	0.034	0.0350				
12/24/25	0.036	0.033	0.032	0.031	0.033	0.034	0.0360				
12/25/25	0.03	0.032	0.031	0.031	0.031	0.036	0.0360				
12/26/25	0.036	0.033	0.033	0.032	0.035	0.037	0.0370				
12/27/25	0.034	0.032	0.032	0.031	0.033	0.035	0.0350				
12/28/25	0.033	0.032	0.031	0.031	0.032	0.035	0.0350				
12/29/25	0.034	0.032	0.031	0.031	0.032	0.036	0.0360				
12/30/25	0.034	0.031	0.03	0.03	0.03	0.032	0.0340				
12/31/25	0.031	0.03	0.029	0.029	0.03	0.032	0.0320				
Slow Sand/				Monthly Summary (Answer Yes or No)							
95% of daily turbidity readings ≤ 1 NTU? ²				Yes		CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?			
All daily turbidity readings ≤ 5 NTU?				Yes		Yes		Yes			
						SIGNATURE: <i>Alivia Pence</i>					
						Printed Name: Alivia Pence			1/8/26		
						PHONE #: (360)513-1405			CERT #:937415		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

System Name:

Corbett Water District

ID#: 41 00359

Month/Year:

Dec-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Clearwell Segment				Reservoir Segment						Combined Segment			
	Cl ₂ Residual after Clearwell (C) ^{3,4}	Peak Hourly Demand Flow -Cwell	Contact Time - CWell (T) ⁴	Actual CT - Cwell	Cl ₂ Residual after Reservoir (C) ^{3,4}	Peak Hourly Demand Flow - Reserv.	Contact Time - Reserv. (T) ⁴	Actual CT - Reserv.	lowest Temp after Res	highest pH after Res	Required CT	Actual CT Cwell + Actual CT Res	(Act CT Cwell + Act CT Res) / Req CT	CT Met? (Act CT Cwell & Res / Req CT > 1.0?) ³
	[ppm or mg/L]	15.2	[minutes]	C X T	[ppm or mg/L]	[GPM]	[minutes]	C X T	[° C]		formula			Yes / No
12/1/25	0.8	473.5	143.40	114.72					9.11	7.41	46.18	114.72	2.48	YES
12/2/25	0.78	451.6	146.82	114.52					8.86	7.44	47.34	114.52	2.42	YES
12/3/25	0.83	411.2	153.14	127.11					8.66	7.52	49.64	127.11	2.56	YES
12/4/25	0.81	309.7	169.00	136.89					8.62	7.64	51.83	136.89	2.64	YES
12/5/25	0.81	295.7	171.19	138.67					8.64	7.76	54.03	138.67	2.57	YES
12/6/25	0.82	221.3	182.82	149.91					8.67	7.79	54.57	149.91	2.75	YES
12/7/25	0.86	380.1	158.00	135.88					8.79	7.82	54.97	135.88	2.47	YES
12/8/25	0.78	380.6	157.92	123.18					9.09	7.77	52.43	123.18	2.35	YES
12/9/25	0.72	318	167.71	120.75					9.39	7.64	48.73	120.75	2.48	YES
12/10/25	0.77	310.7	168.85	130.01					9.6	7.63	48.15	130.01	2.70	YES
12/11/25	0.69	419.8	151.80	104.74					9.99	7.57	45.52	104.74	2.30	YES
12/12/25	0.69	432.4	149.83	103.38					10.28	7.57	44.66	103.38	2.32	YES
12/13/25	0.81	321.6	167.14	135.39					10.26	7.6	45.81	135.39	2.96	YES
12/14/25	0.81	311.9	168.66	136.61					10.14	7.61	46.34	136.61	2.95	YES
12/15/25	0.76	310	168.96	128.41					10.13	7.62	46.27	128.41	2.78	YES
12/16/25	0.86	275.8	174.30	149.90		not used			10.12	7.67	47.67	149.90	3.14	YES
12/17/25	0.81	276.5	174.19	141.10					10.18	7.6	46.05	141.10	3.06	YES
12/18/25	0.89	356.3	161.72	143.93					10.02	7.58	46.31	143.93	3.11	YES
12/19/25	0.85	329.3	165.94	141.05					9.71	7.39	44.32	141.05	3.18	YES
12/20/25	0.86	376.9	158.50	136.31					9.6	7.47	45.97	136.31	2.97	YES
12/21/25	0.82	440.6	148.54	121.81					9.4	7.49	46.70	121.81	2.61	YES
12/22/25	0.81	425.4	150.92	122.25					9.24	7.48	46.98	122.25	2.60	YES
12/23/25	0.88	316.8	167.89	147.75					9.17	7.56	48.95	147.75	3.02	YES
12/24/25	0.86	309.4	169.05	145.38					9.09	7.62	50.15	145.38	2.90	YES
12/25/25	0.88	279.3	173.76	152.90					8.99	7.65	51.15	152.90	2.99	YES
12/26/25	0.89	343.3	163.75	145.74					8.91	7.65	51.48	145.74	2.83	YES
12/27/25	0.89	401	154.73	137.71					8.76	7.53	49.83	137.71	2.76	YES
12/28/25	0.88	389.4	156.55	137.76					8.49	7.44	49.08	137.76	2.81	YES
12/29/25	0.83	327.7	166.19	137.94					8.21	7.45	49.90	137.94	2.76	YES
12/30/25	0.87	286.1	172.69	150.24					7.96	7.5	51.89	150.24	2.90	YES
12/31/25	0.91	279.9	173.66	158.03					7.8	7.51	52.88	158.03	2.99	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS to be notified within 24 hours. ⁴ Chlorine residual and contact time to be determined during peak hourly demand flow of clearwell and reservoir.