

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**      **County:**                      **Multnomah**

**System Name:**      **Corbett Water District**                      **ID#: 41**                      **00359**      **WTP - : A**      **Month/Year:**                      **January-26**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1/1/26	0.031	0.03	0.029	0.029	0.03	0.032	0.0320
1/2/26	0.03	0.029	0.027	0.027	0.028	0.031	0.0310
1/3/26	0.03	0.029	0.031	0.031	0.033	0.037	0.0370
1/4/26	0.034	0.032	0.032	0.031	0.032	0.036	0.0360
1/5/26	0.034	0.033	0.032	0.032	0.033	0.039	0.0390
1/6/26	0.037	0.029	0.034	0.033	0.033	0.035	0.0370
1/7/26	0.036	0.035	0.034	0.034	0.035	0.036	0.0360
1/8/26	0.036	0.035	0.035	0.034	0.036	0.04	0.0400
1/9/26	0.038	0.036	0.035	0.034	0.036	0.043	0.0430
1/10/26	0.042	0.038	0.036	0.035	0.037	0.045	0.0450
1/11/26	0.043	0.038	0.036	0.035	0.037	0.045	0.0450
1/12/26	0.044	0.039	0.036	0.035	0.036	0.041	0.0440
1/13/26	0.043	0.039	0.036	0.035	0.035	0.038	0.0430
1/14/26	0.039	0.037	0.035	0.035	0.035	0.038	0.0390
1/15/26	0.039	0.037	0.035	0.035	0.035	0.038	0.0390
1/16/26	0.038	0.036	0.035	0.035	0.035	0.038	0.0380
1/17/26	0.039	0.037	0.036	0.035	0.035	0.038	0.0390
1/18/26	0.038	0.036	0.035	0.034	0.035	0.037	0.0380
1/19/26	0.038	0.036	0.035	0.034	0.034	0.033	0.0380
1/20/26	0.034	0.033	0.032	0.031	0.032	0.033	0.0340
1/21/26	0.033	0.031	0.031	0.031	0.032	0.033	0.0330
1/22/26	0.035	0.035	0.034	0.034	0.036	0.041	0.0410
1/23/26	0.04	0.037	0.035	0.034	0.035	0.037	0.0400
1/24/26	0.037	0.036	0.035	0.035	0.035	0.036	0.0370
1/25/26	0.037	0.036	0.036	0.035	0.035	0.038	0.0380
1/26/26	0.039	0.038	0.036	0.035	0.036	0.039	0.0390
1/27/26	0.039	0.038	0.036	0.035	0.037	0.04	0.0400
1/28/26	0.04	0.038	0.035	0.035	0.036	0.038	0.0400
1/29/26	0.039	0.038	0.036	0.036	0.036	0.038	0.0390
1/30/26	0.039	0.038	0.037	0.036	0.037	0.038	0.0390
1/31/26	0.039	0.038	0.037	0.036	0.038	0.04	0.0400

<b>Slow Sand/</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>Yes</b>	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>SIGNATURE:</b> <i>Alivia Pence</i>	
<b>Printed Name:</b> Alivia Pence	<b>2/2/26</b>
<b>PHONE #:</b> ( 360 )513-1405	<b>CERT #:937415</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Corbett Water District ID#: 41 00359

Month/Year: Jan-26

Disinfection  
Giardia Log  
Inactiv: 1

Date / Time	Clearwell Segment				Reservoir Segment							Combined Segment		
	Cl <sub>2</sub> Residual after Clearwell (C) <sup>3,4</sup>	Peak Hourly Demand Flow -Cwell	Contact Time - CWell (T) <sup>4</sup>	Actual CT - Cwell	Cl <sub>2</sub> Residual after Reservoir (C) <sup>3,4</sup>	Peak Hourly Demand Flow - Reserv.	Contact Time - Reserv. (T) <sup>4</sup>	Actual CT - Reserv.	lowest Temp after Res	highest pH after Res	Required CT	Actual CT Cwell + Actual CT Res	(Act CT Cwell + Act CT Res) / Req CT	CT Met? (Act CT Cwell & Res / Req CT > 1.0?) <sup>3</sup>
	[ppm or mg/L]	[GPM]	[minutes]	C X T	[ppm or mg/L]	[GPM]	[minutes]	C X T	[° C]		formula			Yes / No
1/1/26	0.95	339.6	164.33052	156.11					7.74	7.49	52.96	156.11	2.95	YES
1/2/26	0.93	342.7	163.84599	152.38					7.8	7.43	51.51	152.38	2.96	YES
1/3/26	0.87	332.1	165.50277	143.99					7.94	7.44	50.86	143.99	2.83	YES
1/4/26	0.83	334.2	165.17454	137.09					8.21	7.43	49.54	137.09	2.77	YES
1/5/26	0.79	323.9	166.78443	131.76					8.37	7.42	48.62	131.76	2.71	YES
1/6/26	0.76	289.7	172.12989	130.82					8.44	7.48	49.27	130.82	2.66	YES
1/7/26	0.75	335.7	164.94009	123.71					8.23	7.48	50.08	123.71	2.47	YES
1/8/26	0.77	344.2	163.61154	125.98					7.95	7.45	50.42	125.98	2.50	YES
1/9/26	0.74	331.9	165.53403	122.50					7.77	7.47	51.22	122.50	2.39	YES
1/10/26	0.78	338.5	164.50245	128.31					7.66	7.53	52.96	128.31	2.42	YES
1/11/26	0.77	343.3	163.75221	126.09					7.61	7.57	53.85	126.09	2.34	YES
1/12/26	0.77	337.6	164.64312	126.78					7.66	7.6	54.25	126.78	2.34	YES
1/13/26	0.79	334.2	165.17454	130.49					7.66	7.6	54.37	130.49	2.40	YES
1/14/26	0.82	345.5	163.40835	133.99					7.61	7.59	54.55	133.99	2.46	YES
1/15/26	0.86	336.6	164.79942	141.73					7.53	7.57	54.70	141.73	2.59	YES
1/16/26	0.88	329	165.9873	146.07		not used			7.55	7.53	53.97	146.07	2.71	YES
1/17/26	0.9	335.2	165.01824	148.52					7.5	7.48	53.51	148.52	2.78	YES
1/18/26	0.9	329.4	165.92478	149.33					7.39	7.44	52.95	149.33	2.82	YES
1/19/26	0.93	315.8	168.05046	156.29					7.27	7.46	53.95	156.29	2.90	YES
1/20/26	0.92	493	140.3541	129.13					6.98	7.44	54.55	129.13	2.37	YES
1/21/26	0.94	480.2	142.35474	133.81					6.73	7.37	54.23	133.81	2.47	YES
1/22/26	0.94	488.3	141.08871	132.62					6.61	7.33	53.89	132.62	2.46	YES
1/23/26	0.97	412.6	152.92062	148.33					6.38	7.35	55.32	148.33	2.68	YES
1/24/26	1	353.2	162.20484	162.20					6.21	7.37	56.55	162.20	2.87	YES
1/25/26	1.02	265.7	175.88109	179.40					6.08	7.43	58.44	179.40	3.07	YES
1/26/26	1.06	326.4	166.39368	176.38					6.03	7.48	59.98	176.38	2.94	YES
1/27/26	1	374.5	158.87565	158.88					6.16	7.5	59.47	158.88	2.67	YES
1/28/26	0.95	370.5	159.50085	151.53					6.27	7.42	57.02	151.53	2.66	YES
1/29/26	0.89	317.1	167.84727	149.38					6.58	7.39	54.86	149.38	2.72	YES
1/30/26	0.87	273	174.7401	152.02					6.96	7.38	53.16	152.02	2.86	YES
1/31/26	0.83	332.7	165.40899	137.29					7.05	7.38	52.60	137.29	2.61	YES

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS to be notified within 24 hours. <sup>4</sup> Chlorine residual and contact time to be determined during peak hourly demand flow of clearwell and reservoir.