

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**      **County:**                      **Multnomah**

**System Name:**      **Corbett Water District**                      **ID#: 41**                      **00359**      **WTP - : A**      **Month/Year:**                      **February-26**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
2/1/26	0.041	0.039	0.037	0.036	0.037	0.039	0.0410
2/2/26	0.039	0.038	0.037	0.036	0.036	0.037	0.0390
2/3/26	0.037	0.037	0.036	0.035	0.036	0.041	0.0410
2/4/26	0.041	0.038	0.037	0.036	0.037	0.04	0.0410
2/5/26	0.041	0.039	0.037	0.036	0.037	0.039	0.0410
2/6/26	0.039	0.038	0.036	0.035	0.034	0.041	0.0410
2/7/26	0.041	0.039	0.037	0.036	0.036	0.037	0.0410
2/8/26	0.037	0.036	0.036	0.036	0.036	0.037	0.0370
2/9/26	0.038	0.035	0.034	0.034	0.03	0.042	0.0420
2/10/26	0.045	0.04	0.033	0.036	0.036	0.039	0.0450
2/11/26	0.041	0.039	0.037	0.036	0.036	0.039	0.0410
2/12/26	0.04	0.038	0.036	0.036	0.037	0.044	0.0440
2/13/26	0.046	0.042	0.038	0.036	0.038	0.046	0.0460
2/14/26	0.045	0.041	0.037	0.036	0.037	0.05	0.0500
2/15/26	0.049	0.042	0.038	0.036	0.037	0.041	0.0490
2/16/26	0.042	0.036	0.034	0.033	0.033	0.037	0.0420
2/17/26	0.035	0.034	0.032	0.032	0.032	0.039	0.0390
2/18/26	0.042	0.038	0.036	0.031	0.031	0.035	0.0420
2/19/26	0.039	0.035	0.033	0.031	0.032	0.036	0.0390
2/20/26	0.037	0.033	0.031	0.03	0.032	0.043	0.0430
2/21/26	0.042	0.035	0.032	0.031	0.03	0.034	0.0420
2/22/26	0.042	0.033	0.034	0.035	0.035	0.036	0.0420
2/23/26	0.039	0.038	0.036	0.035	0.035	0.039	0.0390
2/24/26	0.04	0.038	0.036	0.037	0.037	0.048	0.0480
2/25/26	0.049	0.043	0.039	0.031	0.036	0.043	0.0490
2/26/26	0.048	0.036	0.036	0.033	0.034	0.048	0.0480
2/27/26	0.049	0.036	0.038	0.036	0.036	0.039	0.0490
2/28/26	0.044	0.034	0.035	0.03	0.03	0.039	0.0440

<b>Slow Sand/</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>SIGNATURE:</b> <i>Alivia Pence</i>	
<b>Printed Name: Alivia Pence</b>	<b>3/6/26</b>
<b>PHONE #: ( 360 )513-1405</b>	<b>CERT #:937415</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

