

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**      **County:**                      **Multnomah**

| <b>System Name:</b> <b>Corbett Water District</b>     |                    | <b>ID#: 41</b>    |                   | <b>00359</b>                              |                               | <b>WTP - : A</b>  |  | <b>Month/Year:</b> <b>March-26</b> |  |
|---|--------------------|-------------------|-------------------|---|-------------------------------|-------------------|--|------------------------------------|--|
| <b>Day</b>  | <b>12 AM [NTU]</b> | <b>4 AM [NTU]</b> | <b>8 AM [NTU]</b> | <b>NOON [NTU]</b>                         | <b>4 PM [NTU]</b>             | <b>8 PM [NTU]</b> | <b>Highest Reading of the day <sup>1</sup> [NTU]</b> |                                    |  |
| 3/1/26  | 0.054              | 0.031             | 0.035             | 0.033                                     | 0.033                         | 0.047             | 0.0540   |                                    |  |
| 3/2/26  | 0.051              | 0.041             | 0.036             | 0.033                                     | 0.033                         | 0.041             | 0.0510   |                                    |  |
| 3/3/26  | 0.043              | 0.035             | 0.032             | 0.031                                     | 0.032                         | 0.037             | 0.0430   |                                    |  |
| 3/4/26  | 0.037              | 0.034             | 0.032             | 0.032                                     | 0.033                         | 0.04              | 0.0400   |                                    |  |
| 3/5/26  | 0.044              | 0.036             | 0.033             | 0.033                                     | 0.034                         | 0.046             | 0.0460   |                                    |  |
| 3/6/26  | 0.046              | 0.038             | 0.034             | 0.033                                     | 0.034                         | 0.043             | 0.0460   |                                    |  |
| 3/7/26  | 0.041              | 0.036             | 0.033             | 0.032                                     | 0.035                         | 0.051             | 0.0510   |                                    |  |
| 3/8/26  | 0.053              | 0.032             | 0.028             | 0.027                                     | 0.026                         | 0.038             | 0.0530   |                                    |  |
| 3/9/26  | 0.044              | 0.038             | 0.032             | 0.036                                     | 0.037                         | 0.054             | 0.0540   |                                    |  |
| 3/10/26   | 0.059              | 0.045             | 0.038             | 0.035                                     | 0.036                         | 0.052             | 0.0590   |                                    |  |
| 3/11/26   | 0.057              | 0.043             | 0.036             | 0.035                                     | 0.034                         | 0.036             | 0.0570   |                                    |  |
| 3/12/26   | 0.036              | 0.035             | 0.034             | 0.034                                     | 0.034                         | 0.035             | 0.0360   |                                    |  |
| 3/13/26   | 0.038              | 0.041             | 0.041             | 0.039                                     | 0.034                         | 0.034             | 0.0410   |                                    |  |
| 3/14/26   | 0.041              | 0.05              | 0.041             | 0.038                                     | 0.038                         | 0.042             | 0.0500   |                                    |  |
| 3/15/26   | 0.051              | 0.051             | 0.042             | 0.038                                     | 0.051                         | 0.041             | 0.0510   |                                    |  |
| 3/16/26   | 0.066              | 0.044             | 0.04              | 0.035                                     | 0.047                         | 0.041             | 0.0660   |                                    |  |
| 3/17/26   | 0.076              | 0.052             | 0.04              | 0.036                                     | 0.044                         | 0.044             | 0.0760   |                                    |  |
| 3/18/26   | 0.073              | 0.052             | 0.043             | 0.039                                     | 0.044                         | 0.044             | 0.0730   |                                    |  |
| 3/19/26   | 0.07               | 0.051             | 0.042             | 0.039                                     | 0.044                         | 0.044             | 0.0700   |                                    |  |
| 3/20/26   | 0.058              | 0.046             | 0.041             | 0.038                                     | 0.044                         | 0.043             | 0.0580   |                                    |  |
| 3/21/26   | 0.05               | 0.044             | 0.039             | 0.038                                     | 0.044                         | 0.041             | 0.0500   |                                    |  |
| 3/22/26   | 0.07               | 0.049             | 0.041             | 0.039                                     | 0.044                         | 0.04              | 0.0700   |                                    |  |
| 3/23/26   | 0.07               | 0.051             | 0.041             | 0.037                                     | 0.038                         | 0.038             | 0.0700   |                                    |  |
| 3/24/26   | 0.037              | 0.036             | 0.036             | 0.036                                     | 0.036                         | 0.036             | 0.0370   |                                    |  |
| 3/25/26   | 0.036              | 0.036             | 0.036             | 0.037                                     | 0.038                         | 0.038             | 0.0380   |                                    |  |
| 3/26/26   | 0.037              | 0.036             | 0.036             | 0.038                                     | 0.038                         | 0.038             | 0.0380   |                                    |  |
| 3/27/26   | 0.036              | 0.036             | 0.036             | 0.035                                     | 0.037                         | 0.038             | 0.0380   |                                    |  |
| 3/28/26   | 0.036              | 0.036             | 0.035             | 0.036                                     | 0.037                         | 0.037             | 0.0370   |                                    |  |
| 3/29/26   | 0.036              | 0.035             | 0.035             | 0.035                                     | 0.036                         | 0.036             | 0.0360   |                                    |  |
| 3/30/26   | 0.035              | 0.035             | 0.035             | 0.035                                     | 0.036                         | 0.036             | 0.0360   |                                    |  |
| 3/31/26   | 0.036              | 0.035             | 0.035             | 0.035                                     | 0.036                         | 0.036             | 0.0360   |                                    |  |
| <b>Slow Sand/</b>                                     |                    |                   |                   | <b>Monthly Summary (Answer Yes or No)</b> |                               |                   |  |                                    |  |
| 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> |                    |                   |                   | <b>Yes</b>                                | CT's met everyday? (see back) |                   | All Cl2 residual at entry point ≥ 0.2 mg/l?          |                                    |  |
| All daily turbidity readings ≤ 5 NTU?                 |                    |                   |                   | <b>Yes</b>                                | <b>Yes</b>                    | Yes               |  |                                    |  |
|   |                    |                   |                   | <b>SIGNATURE:</b> <i>Alivia Pence</i>     |                               |                   |  |                                    |  |
|   |                    |                   |                   | <b>Printed Name: Alivia Pence</b>         |                               |                   | <b>4/2/26</b>  |                                    |  |
|   |                    |                   |                   | <b>PHONE #: ( 360 )513-1405</b>           |                               |                   | <b>CERT #:937415</b>                                 |                                    |  |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Corbett Water District ID#: 41 00359

Month/Year:

Mar-26

Disinfection  
Giardia Log  
Inactiv:

1

| Date / Time | Clearwell Segment   |                                |                                       |                   | Reservoir Segment   |                                   |   |                     |                       |                      |             | Combined Segment                |                                      |   |
|-------------|---|--------------------------------|---------------------------------------|-------------------|---|-----------------------------------|---|---------------------|-----------------------|----------------------|-------------|---------------------------------|--------------------------------------|---|
|             | Cl <sub>2</sub> Residual after Clearwell (C) <sup>3,4</sup> | Peak Hourly Demand Flow -Cwell | Contact Time - CWell (T) <sup>4</sup> | Actual CT - Cwell | Cl <sub>2</sub> Residual after Reservoir (C) <sup>3,4</sup> | Peak Hourly Demand Flow - Reserv. | Contact Time - Reserv. (T) <sup>4</sup> | Actual CT - Reserv. | lowest Temp after Res | highest pH after Res | Required CT | Actual CT Cwell + Actual CT Res | (Act CT Cwell + Act CT Res) / Req CT | CT Met? (Act CT Cwell & Res / Req CT > 1.0?) <sup>3</sup> |
|             | [ppm or mg/L]   |                                | [minutes]                             | C X T             | [ppm or mg/L]   | [GPM]                             | [minutes]                               | C X T               | [° C]                 |                      | formula     |                                 |                                      | Yes / No  |
| 3/1/26      | 0.89  | 271.6                          | 174.96                                | 155.71            |   |                                   |   |                     | 7.06                  | 8.34                 | 74.97       | 155.71                          | 2.08                                 | YES   |
| 3/2/26      | 0.97  | 379.7                          | 158.06                                | 153.32            |   |                                   |   |                     | 7.23                  | 8.28                 | 73.17       | 153.32                          | 2.10                                 | YES   |
| 3/3/26      | 1.02  | 376.9                          | 158.50                                | 161.67            |   |                                   |   |                     | 7.46                  | 8.04                 | 66.37       | 161.67                          | 2.44                                 | YES   |
| 3/4/26      | 0.96  | 374.1                          | 158.94                                | 152.58            |   |                                   |   |                     | 7.93                  | 7.91                 | 60.88       | 152.58                          | 2.51                                 | YES   |
| 3/5/26      | 0.93  | 369.6                          | 159.64                                | 148.47            |   |                                   |   |                     | 8.06                  | 8.13                 | 65.13       | 148.47                          | 2.28                                 | YES   |
| 3/6/26      | 0.88  | 321.4                          | 167.18                                | 147.11            |   |                                   |   |                     | 8.11                  | 8.09                 | 63.60       | 147.11                          | 2.31                                 | YES   |
| 3/7/26      | 0.84  | 320.7                          | 167.28                                | 140.52            |   |                                   |   |                     | 8.18                  | 7.94                 | 59.67       | 140.52                          | 2.35                                 | YES   |
| 3/8/26      | 0.82  | 314.3                          | 168.28                                | 137.99            |   |                                   |   |                     | 8.32                  | 7.78                 | 55.67       | 137.99                          | 2.48                                 | YES   |
| 3/9/26      | 0.89  | 317.1                          | 167.85                                | 149.38            |   |                                   |   |                     | 8.19                  | 8.03                 | 61.97       | 149.38                          | 2.41                                 | YES   |
| 3/10/26     | 0.77  | 377.8                          | 158.36                                | 121.94            |   |                                   |   |                     | 8.07                  | 8.07                 | 62.51       | 121.94                          | 1.95                                 | YES   |
| 3/11/26     | 0.73  | 380.3                          | 157.97                                | 115.32            |   |                                   |   |                     | 8.07                  | 7.96                 | 59.79       | 115.32                          | 1.93                                 | YES   |
| 3/12/26     | 0.44  | 347.3                          | 163.13                                | 71.78             |   |                                   |   |                     | 7.88                  | 7.77                 | 54.69       | 71.78                           | 1.31                                 | YES   |
| 3/13/26     | 0.71  | 225.3                          | 182.20                                | 129.36            |   |                                   |   |                     | 7.82                  | 7.75                 | 56.24       | 129.36                          | 2.30                                 | YES   |
| 3/14/26     | 0.88  | 367                            | 160.05                                | 140.84            |   |                                   |   |                     | 7.89                  | 8.08                 | 64.33       | 140.84                          | 2.19                                 | YES   |
| 3/15/26     | 0.78  | 456.7                          | 146.03                                | 113.90            |   |                                   |   |                     | 8.01                  | 8.21                 | 66.12       | 113.90                          | 1.72                                 | YES   |
| 3/16/26     | 0.71  | 425.6                          | 150.89                                | 107.13            |   | Not used                          |   |                     | 8.1                   | 8.2                  | 64.94       | 107.13                          | 1.65                                 | YES   |
| 3/17/26     | 0.75  | 321.3                          | 167.19                                | 125.39            |   |                                   |   |                     | 8.31                  | 8.18                 | 63.85       | 125.39                          | 1.96                                 | YES   |
| 3/18/26     | 0.75  | 322                            | 167.08                                | 125.31            |   |                                   |   |                     | 8.6                   | 8.12                 | 61.25       | 125.31                          | 2.05                                 | YES   |
| 3/19/26     | 0.77  | 321.7                          | 167.13                                | 128.69            |   |                                   |   |                     | 8.77                  | 8.06                 | 59.39       | 128.69                          | 2.17                                 | YES   |
| 3/20/26     | 0.82  | 331.1                          | 165.66                                | 135.84            |   |                                   |   |                     | 9.07                  | 8.02                 | 57.70       | 135.84                          | 2.35                                 | YES   |
| 3/21/26     | 0.95  | 319.9                          | 167.41                                | 159.04            |   |                                   |   |                     | 9.23                  | 7.99                 | 57.32       | 159.04                          | 2.77                                 | YES   |
| 3/22/26     | 0.82  | 328                            | 166.14                                | 136.24            |   |                                   |   |                     | 9.13                  | 8.19                 | 61.10       | 136.24                          | 2.23                                 | YES   |
| 3/23/26     | 0.99  | 313.7                          | 168.38                                | 166.69            |   |                                   |   |                     | 9.11                  | 8.15                 | 61.51       | 166.69                          | 2.71                                 | YES   |
| 3/24/26     | 0.84  | 263.3                          | 176.26                                | 148.06            |   |                                   |   |                     | 9.16                  | 7.64                 | 50.16       | 148.06                          | 2.95                                 | YES   |
| 3/25/26     | 1.02  | 303.3                          | 170.00                                | 173.40            |   |                                   |   |                     | 9.04                  | 7.33                 | 46.24       | 173.40                          | 3.75                                 | YES   |
| 3/26/26     | 0.77  | 317.1                          | 167.85                                | 129.24            |   |                                   |   |                     | 8.86                  | 7.52                 | 48.65       | 129.24                          | 2.66                                 | YES   |
| 3/27/26     | 0.96  | 343                            | 163.80                                | 157.25            |   |                                   |   |                     | 8.84                  | 7.64                 | 51.96       | 157.25                          | 3.03                                 | YES   |
| 3/28/26     | 0.71  | 351.9                          | 162.41                                | 115.31            |   |                                   |   |                     | 8.9                   | 7.3                  | 44.58       | 115.31                          | 2.59                                 | YES   |
| 3/29/26     | 0.95  | 337.6                          | 164.64                                | 156.41            |   |                                   |   |                     | 8.93                  | 7.33                 | 46.21       | 156.41                          | 3.38                                 | YES   |
| 3/30/26     | 0.7   | 330.6                          | 165.74                                | 116.02            |   |                                   |   |                     | 8.71                  | 7.64                 | 50.87       | 116.02                          | 2.28                                 | YES   |
| 3/31/26     | 0.98  | 334                            | 165.21                                | 161.90            |   |                                   |   |                     | 8.6                   | 7.7                  | 54.07       | 161.90                          | 2.99                                 | YES   |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS to be notified within 24 hours. <sup>4</sup> Chlorine residual and contact time 45384