

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Washington

Conventional

Month/Year: January 2026

System Name:	Joint Water Commission			ID#: 41 00379	WTP : TP - WTP-A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.04	0.04
3	0.03	0.02	0.02	0.02	0.02	0.02	0.03
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.03	0.03	shut down	0.03	0.02	0.04
7	0.02	0.02	0.02	0.03	0.03	0.03	0.03
8	0.02	0.02	0.02	0.04	0.04	0.03	0.04
9	0.03	0.02	0.02	0.02	0.02	0.02	0.03
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.04
12	0.03	0.03	0.02	0.03	0.02	0.02	29.19
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.03	0.03
15	0.09	0.03	0.03	0.02	0.02	0.02	0.09
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.03	0.02	0.02	0.03
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.06	0.04	0.06
22	0.03	0.02	0.02	0.02	0.02	0.02	0.03
23	0.02	0.02	0.02	0.04	0.03	0.02	0.04
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.05	0.03	0.03	0.05
26	0.02	0.02	0.03	0.02	0.02	0.02	0.03
27	0.02	0.02	0.02	0.02	0.02	0.05	0.05
28	0.03	0.02	0.02	0.02	0.02	0.00	0.03
29	0.02	0.02	0.02	0.02	0.02	0.04	0.04
30	0.03	0.03	0.03	0.03	0.02	0.02	0.03
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers	No		

Notes:	PRINTED NAME: Todd Evers	
	SIGNATURE: 	Date: 02-04-2026
	PHONE #: 541-497-3945	CERT #: 6149

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

Date		CT # 1 (Clearwell Segment)											CT # 2 (Ops Building Pipeline Segment)								Combined CT		
DATE	TIME	FWPS 1 (CT) Cl2 Residual (mg/L) "C"	FWPS 1 (CT) Temp (Celsius)	FWPS 1 (CT) pH	Clearwell Level (ft)	FWPS 1 Flow (gpm)	FWPS 2 Flow (gpm)	Combined FWPS Flow (gpm)	Clearwell Detention Time (T10) (minutes) "T"	Clearwell CT Achieved (min*mg/L) C x T	Clearwell Segment Giardia Log Inactivation (CTa*0.5Log)/CTr	Clearwell Required CT (min*mg/L) (equation)	Ops Building Chlorine (mg/L) "C"	Ops Building Temp (Celsius)	Ops Building pH	Ops Building Potable Flow (gpm)	Ops Building Pipe Detention Time (1,344 gal) (minutes) "T"	Ops Bldg CT Achieved (min*mg/L) C x T	Ops Bldg Giardia Log Inactivation (CTa*0.5Log)/CTr	Ops Bldg Required CT (min*mg/L) (equation)	Total Log Inactivation Provided	Total Inactivation Ratio SCTa/CTr	Required CT Achieved? Y/N
1/1	23:00	1.37	7.2	7.75	13.66	14,434	9,263	23,697	70.2	96.2	1.52	31.7	1.24	11.0	7.49	39	34.5	42.7	0.97	22.0	2.5	5.0	Y
1/2	23:00	1.32	8.2	7.80	14.35	15,495	9,197	24,692	69.6	91.9	1.53	30.0	1.22	11.8	7.54	40	33.6	41.0	0.97	21.2	2.5	5.0	Y
1/3	1:00	1.31	8.3	7.81	14.00	15,431	9,178	24,609	68.2	89.3	1.50	29.8	1.23	11.8	7.54	40	33.6	41.3	0.97	21.2	2.5	4.9	Y
1/4	0:00	1.28	9.0	7.94	13.64	14,617	9,091	23,708	69.6	89.1	1.50	29.7	1.20	12.3	7.61	40	33.6	40.3	0.96	21.0	2.5	4.9	Y
1/5	12:00	1.27	9.0	7.73	13.79	13,154	9,104	22,258	76.8	97.5	1.77	27.5	1.19	10.9	7.88	40	33.6	40.0	0.79	25.3	2.6	5.1	Y
1/6	0:00	1.40	8.7	7.82	13.85	12,905	9,102	22,007	78.3	109.7	1.86	29.4	1.29	12.2	7.80	40	33.6	43.3	0.95	22.8	2.8	5.6	Y
1/7	2:00	1.34	8.1	7.74	13.30	9,573	9,200	18,773	95.7	128.3	2.17	29.6	1.27	11.9	7.64	40	33.6	42.7	0.97	22.0	3.1	6.3	Y
1/8	20:00	1.44	7.6	7.76	12.99	14,015	9,281	23,296	68.4	98.5	1.58	31.2	1.26	11.2	7.40	40	33.6	42.3	1.00	21.1	2.6	5.2	Y
1/9	1:00	1.35	7.7	7.89	13.19	14,438	9,268	23,706	67.8	91.5	1.42	32.1	1.25	10.7	7.46	40	33.6	42.0	0.94	22.3	2.4	4.7	Y
1/10	19:00	1.27	8.0	7.83	13.57	10,524	9,268	19,792	90.3	114.7	1.88	30.5	1.20	11.6	7.47	40	33.6	40.3	0.96	20.9	2.8	5.7	Y
1/11	15:00	1.23	8.1	8.14	13.45	12,137	9,298	21,435	79.7	98.0	1.45	33.8	1.22	11.7	7.69	40	33.6	41.0	0.91	22.5	2.4	4.7	Y
1/12	2:00	1.28	8.4	7.99	13.07	13,081	9,279	22,360	72.8	93.2	1.48	31.5	1.24	12.0	7.56	40	33.6	41.7	0.99	21.1	2.5	4.9	Y
1/13	17:00	1.28	8.7	8.00	13.39	13,118	9,299	22,417	74.4	95.3	1.54	31.0	1.22	11.9	7.66	40	33.6	41.0	0.93	22.0	2.5	4.9	Y
1/14	10:00	1.31	8.6	7.77	13.85	12,650	9,705	22,355	78.7	103.1	1.79	28.8	1.25	11.9	7.56	40	33.6	42.0	0.99	21.3	2.8	5.6	Y
1/15	21:00	1.30	8.3	7.77	13.59	12,733	9,348	22,081	77.3	100.5	1.71	29.4	1.22	12.1	7.43	39	34.5	42.0	1.05	20.0	2.8	5.5	Y
1/16	1:00	1.21	8.2	7.79	13.55	12,982	9,337	22,319	75.9	91.8	1.56	29.5	1.17	12.0	7.46	39	34.5	40.3	1.00	20.3	2.6	5.1	Y
1/17	9:00	1.26	7.7	7.78	13.87	12,973	9,298	22,271	77.8	98.0	1.60	30.5	1.18	13.4	7.49	39	34.5	40.7	1.10	18.5	2.7	5.4	Y
1/18	23:00	1.33	6.8	7.84	13.83	14,991	9,236	24,227	68.9	91.7	1.37	33.5	1.24	12.1	7.57	39	34.5	42.7	1.01	21.1	2.4	4.8	Y
1/19	1:00	1.36	6.7	7.87	13.96	15,422	9,229	24,651	68.0	92.4	1.35	34.2	1.28	12.9	7.58	39	34.5	44.1	1.10	20.0	2.5	4.9	Y
1/20	1:00	1.31	6.3	7.81	13.82	14,887	9,149	24,036	69.4	90.9	1.33	34.2	1.28	12.3	7.64	39	34.5	44.1	1.03	21.4	2.4	4.7	Y
1/21	9:00	1.46	5.4	7.89	13.54	10,962	9,255	20,217	87.2	127.4	1.67	38.1	1.27	9.1	7.59	39	34.5	43.8	0.84	26.0	2.5	5.0	Y
1/22	21:00	1.36	4.8	8.01	13.26	13,087	9,368	22,455	73.7	100.3	1.22	41.0	1.23	9.5	7.54	39	34.5	42.4	0.86	24.7	2.1	4.2	Y
1/23	10:00	1.27	5.2	8.03	13.41	14,159	9,356	23,515	69.9	88.8	1.12	39.8	1.23	10.6	7.66	39	34.5	42.4	0.88	24.0	2.0	4.0	Y
1/24	20:00	1.30	5.0	7.95	13.10	12,537	9,295	21,832	75.6	98.3	1.25	39.3	1.20	11.5	7.59	39	34.5	41.4	0.94	22.0	2.2	4.4	Y
1/25	16:00	1.30	4.3	8.13	13.65	9,464	9,313	18,777	98.9	128.6	1.46	44.1	1.23	10.6	7.62	39	34.5	42.4	0.90	23.7	2.4	4.7	Y
1/26	7:00	1.33	3.9	7.99	12.99	10,503	9,332	19,835	86.5	115.1	1.33	43.2	1.23	10.7	7.74	39	34.5	42.4	0.86	24.5	2.2	4.4	Y
1/27	21:00	1.30	5.2	8.07	13.03	14,089	9,308	23,397	68.3	88.8	1.10	40.5	1.20	12.1	7.70	39	34.5	41.4	0.94	22.0	2.0	4.1	Y
1/28	2:00	1.34	5.4	8.14	13.16	14,187	9,276	23,463	68.6	91.9	1.12	41.2	1.25	12.1	7.74	41	32.8	41.0	0.91	22.4	2.0	4.1	Y
1/29	23:00	1.33	7.8	7.99	13.82	12,990	9,286	22,276	77.5	103.0	1.56	33.0	1.11	13.9	7.58	39	34.5	38.3	1.04	18.4	2.6	5.2	Y
1/30	8:00	1.35	8.0	7.92	13.88	13,543	9,288	22,831	75.2	101.5	1.59	31.8	1.18	13.4	7.55	39	34.5	40.7	1.07	19.0	2.7	5.3	Y
1/31	19:00	1.34	8.7	7.84	13.61	9,510	9,290	18,800	98.3	131.7	2.24	29.4	1.16	14.5	7.52	39	34.5	40.0	1.15	17.4	3.4	6.8	Y

Reviewed By: Todd Evers

Date: 02-04-2026