

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Washington

Conventional

Month/Year: February 2026

System Name: Joint Water Commission		ID#: 41 00379					WTP : TP - WTP-A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
2	0.03	0.03	0.03	0.03	0.02	0.03	0.04	
3	0.03	0.03	0.03	0.03	0.02	0.02	0.03	
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.02	0.02	0.02	0.03	0.02	0.03	0.03	
6	0.02	0.02	0.02	0.03	0.02	0.02	0.03	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.03	0.02	0.03	0.04	0.04	
9	0.04	0.05	0.06	0.05	0.04	0.04	0.06	
10	0.04	0.04	0.04	shutdown	0.05	0.04	0.05	
11	0.04	0.03	0.03	0.03	0.03	0.03	0.05	
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
19	0.03	0.03	0.03	0.04	0.04	0.03	0.04	
20	0.03	0.03	0.04	0.04	0.04	0.03	0.04	
21	0.03	0.03	0.04	0.03	0.04	0.03	0.04	
22	0.03	0.03	0.03	0.03	0.04	0.04	0.04	
23	0.04	0.03	0.04	0.04	0.05	0.05	0.05	
24	0.05	0.04	0.04	0.05	0.04	0.04	0.06	
25	0.04	0.04	0.04	0.04	0.04	0.04	0.05	
26	0.04	0.05	0.04	0.04	0.04	0.04	0.05	
27	0.05	0.05	0.04	0.05	0.04	0.04	0.05	
28	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
29								
30								
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers	Yes		

Notes:	PRINTED NAME: Todd Evers	
	SIGNATURE: 	Date: 03-03-2026
	PHONE #: 541-497-3945	CERT #: 6149

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

Date		CT # 1 (Clearwell Segment)											CT # 2 (Ops Building Pipeline Segment)								Combined CT		
DATE	TIME	FWPS 1 (CT) Cl2 Residual (mg/L) "C"	FWPS 1 (CT) Temp (Celsius)	FWPS 1 (CT) pH	Clearwell Level (ft)	FWPS 1 Flow (gpm)	FWPS 2 Flow (gpm)	Combined FWPS Flow (gpm)	Clearwell Detention Time (T10) (minutes) "T"	Clearwell CT Achieved (min*mg/L) C x T	Clearwell Segment Giardia Log Inactivation (CTa*0.5Log)/CTr	Clearwell Required CT (min*mg/L) (equation)	Ops Building Chlorine (mg/L) "C"	Ops Building Temp (Celsius)	Ops Building pH	Ops Building Potable Flow (gpm)	Ops Building Pipe Detention Time (1,344 gal) (minutes) "T"	Ops Bldg CT Achieved (min*mg/L) C x T	Ops Bldg Giardia Log Inactivation (CTa*0.5Log)/CTr	Ops Bldg Required CT (min*mg/L) (equation)	Total Log Inactivation Provided	Total Inactivation Ratio SCTa/CTr	Required CT Achieved? Y/N
2/1	9:00	1.34	8.7	8.09	13.69	9,568	9,302	18,870	98.4	131.8	2.04	32.2	1.17	14.0	7.62	39	34.5	40.3	1.08	18.7	3.1	6.2	Y
2/2	23:00	1.38	8.9	7.91	13.75	12,555	9,352	21,907	79.1	109.2	1.82	29.9	1.20	14.1	7.50	39	34.5	41.4	1.16	17.8	3.0	6.0	Y
2/3	23:00	1.38	8.9	8.05	13.67	14,330	9,355	23,685	70.6	97.4	1.55	31.5	1.22	15.0	7.60	39	34.5	42.0	1.21	17.4	2.8	5.5	Y
2/4	3:00	1.37	8.9	7.99	13.94	14,794	9,336	24,130	70.1	96.0	1.56	30.8	1.22	14.8	7.65	39	34.5	42.0	1.17	18.0	2.7	5.5	Y
2/5	20:00	1.29	8.6	8.11	13.70	14,868	9,341	24,209	68.6	88.5	1.36	32.5	1.12	14.8	7.90	39	34.5	38.6	0.99	19.5	2.4	4.7	Y
2/6	7:00	1.31	8.0	7.76	13.13	14,378	9,302	23,680	67.7	88.6	1.48	29.9	1.16	14.3	7.84	39	34.5	40.0	1.01	19.8	2.5	5.0	Y
2/7	20:00	1.19	8.1	7.89	13.66	13,695	9,304	22,999	73.3	87.2	1.42	30.7	1.08	13.5	7.76	39	34.5	37.2	0.92	20.1	2.3	4.7	Y
2/8	7:00	1.28	8.2	7.82	13.05	12,315	9,282	21,597	76.4	97.8	1.63	30.0	1.13	13.6	7.67	39	34.5	38.9	1.00	19.4	2.6	5.3	Y
2/9	16:00	1.16	9.4	7.66	13.41	19,643	9,178	28,821	53.3	61.8	1.20	25.8	1.06	12.6	7.58	39	34.5	36.5	0.92	19.9	2.1	4.2	Y
2/10	0:00	1.24	9.2	7.66	11.84	13,073	9,096	22,169	66.3	82.2	1.56	26.4	1.05	15.0	7.56	39	34.5	36.2	1.07	16.9	2.6	5.3	Y
2/11	23:00	1.16	8.4	7.74	13.62	12,183	9,365	21,548	80.3	93.2	1.64	28.4	1.03	14.8	7.69	40	33.6	34.6	0.97	17.9	2.6	5.2	Y
2/12	0:00	1.20	8.3	7.74	13.58	12,425	9,355	21,780	78.8	94.6	1.65	28.7	1.05	14.4	7.66	39	34.5	36.2	0.99	18.2	2.6	5.3	Y
2/13	20:00	1.27	8.4	7.92	14.02	16,131	9,288	25,419	65.7	83.4	1.36	30.7	1.29	14.0	7.71	39	34.5	44.5	1.14	19.6	2.5	5.0	Y
2/14	1:00	1.27	8.4	7.78	13.93	15,382	9,271	24,653	67.9	86.2	1.48	29.2	1.23	14.2	7.77	39	34.5	42.4	1.08	19.6	2.6	5.1	Y
2/15	23:00	1.25	8.8	7.84	13.49	12,253	9,272	21,525	79.3	99.2	1.71	28.9	1.16	14.7	7.76	39	34.5	40.0	1.07	18.7	2.8	5.6	Y
2/16	7:00	1.29	8.8	7.68	13.73	12,594	9,256	21,850	79.0	101.9	1.86	27.4	1.20	14.7	7.67	39	34.5	41.4	1.13	18.2	3.0	6.0	Y
2/17	6:28	1.27	8.6	7.83	13.38	11,950	9,238	21,188	80.4	102.1	1.74	29.3	1.24	14.5	7.80	39	34.5	42.7	1.10	19.5	2.8	5.7	Y
2/18	23:00	1.27	6.7	7.78	13.52	13,699	9,305	23,004	72.5	92.1	1.41	32.7	1.21	12.5	7.76	39	34.5	41.7	0.96	21.8	2.4	4.7	Y
2/19	16:00	1.23	6.3	7.81	13.76	16,616	9,254	25,870	62.9	77.4	1.14	33.9	1.22	11.3	7.78	39	34.5	42.0	0.88	23.9	2.0	4.0	Y
2/20	22:00	1.24	7.1	7.85	13.12	18,355	9,184	27,539	55.2	68.5	1.05	32.6	1.21	12.6	7.71	39	34.5	41.7	0.98	21.3	2.0	4.1	Y
2/21	1:00	1.25	7.1	7.71	13.04	18,199	9,160	27,359	55.3	69.1	1.12	31.0	1.22	13.2	7.73	39	34.5	42.0	1.02	20.6	2.1	4.3	Y
2/22	20:00	1.21	7.5	7.78	13.10	14,443	9,149	23,592	67.4	81.6	1.33	30.8	1.18	10.7	7.64	41	32.8	38.7	0.82	23.5	2.1	4.3	Y
2/23	21:00	1.20	8.0	7.76	13.40	16,248	9,138	25,386	62.5	75.1	1.27	29.5	1.22	14.1	7.78	39	34.5	42.0	1.06	19.8	2.3	4.7	Y
2/24	0:00	1.25	8.0	7.75	13.01	15,813	9,119	24,932	62.1	77.7	1.31	29.6	1.21	14.3	7.70	39	34.5	41.7	1.10	18.9	2.4	4.8	Y
2/25	12:00	1.23	8.4	7.64	13.31	14,440	9,132	23,572	68.6	84.3	1.53	27.6	1.26	12.2	7.65	39	34.5	43.4	1.01	21.6	2.5	5.1	Y
2/26	8:00	1.20	8.6	7.62	13.87	15,126	9,134	24,260	68.7	82.5	1.53	26.9	1.17	14.0	7.55	39	34.5	40.3	1.11	18.2	2.6	5.3	Y
2/27	13:00	1.14	8.6	7.77	13.65	14,412	9,116	23,528	70.4	80.3	1.42	28.2	1.15	13.3	7.79	39	34.5	39.6	0.95	20.8	2.4	4.8	Y
2/28	17:00	1.16	8.5	7.70	13.69	12,578	9,129	21,707	79.0	91.7	1.65	27.8	1.16	14.6	7.65	39	34.5	40.0	1.10	18.1	2.8	5.5	Y

Reviewed By: Todd Evers

Date: 03-03-2026