

OHA - Drinking Water Services – Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: City of Parma ID # 00394 WTP-: A Month/Year: Dec 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.01						0.01
2			0.01				0.01
3			0.01				0.01
4	0.01						0.01
5							0.01
6		0.01					0.01
7							
8							
9							
10	0.01	0.01					0.01
11			0.01	0.01			0.01
12						0.01	0.01
13							
14			0.01			0.01	0.01
15					0.01	0.01	0.01
16							
17	0.01					0.01	0.01
18							
19	0.01						0.01
20						0.01	0.01
21							
22							
23		0.01					0.01
24							
25							
26	0.01			0.01			0.01
27	0.01						0.01
28							
29				0.01	0.01		0.01
30	0.01	0.01	0.01	0.01			0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
	Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: <u>Robert Bruce</u>	
	SIGNATURE: <u>Robert Bruce</u>	DATE: <u>1-9-23</u>
	PHONE #: <u>(503) 829-3313</u>	CERT #: <u>7136</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: CITY OF IDAHO ID #: 20394 WTP: A Month/Year: Dec 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1000/11	1.05	187	196.3	4.0	7.1	43	yes	90
0800/21	1.03	187	192.6	4.0	7.1	43	yes	80
0945/31	1.02	187	190.7	4.0	7.1	43	yes	75
1000/41	1.00	187	374	4.0	7.1	48	yes	90
1000/51	1.86	187	347	4.0	7.1	48	yes	90
1000/61	1.80	187	336	4.0	7.1	47	yes	95
1000/71	1.86	187	347	4.0	7.1	48	yes	85
1100/81	1.91	187	357	4.0	7.1	48	yes	95
1500/91	1.82	187	340	4.0	7.1	48	yes	80
1600/101	1.09	187	203	4.0	7.1	43	yes	85
1600/111	1.11	187	207	4.0	7.1	43	yes	95
1800/121	1.11	187	207	4.0	7.1	43	yes	95
1730/131	1.00	187	187	4.0	7.1	42	yes	100
1840/141	1.03	187	192	4.0	7.1	43	yes	85
2000/151	1.05	187	196	4.0	7.1	43	yes	80
1900/161	1.10	187	205	4.0	7.1	43	yes	80
2000/171	1.13	187	211	4.0	7.1	43	yes	90
1800/181	1.0	187	187	4.0	7.1	42	yes	80
2000/191	1.13	187	211	4.0	7.1	43	yes	85
1900/201	0.83	187	155	4.0	7.1	42	yes	85
2000/211	0.83	187	155	4.0	7.1	42	yes	95
1900/221	0.83	187	155	4.0	7.1	42	yes	100
1100/231	1.10	187	205	3.7	7.0	36	yes	95
1600/241	1.30	187	240	3.8	7.0	37	yes	95
2000/251	1.06	187	180	3.8	7.0	36	yes	90
1000/261	1.42	187	265	3.7	7.0	38	yes	85
2000/271	1.40	187	261	4.9	7.0	37	yes	85
1900/281	1.36	187	254	4.9	7.0	37	yes	95
1800/291	1.33	187	248	4.9	7.0	37	yes	80
1900/301	1.39	187	259	4.8	7.0	37	yes	85
1900/311	0.93	187	173	4.8	7.0	35	yes	90

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised November 2022
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR
 97293-0350
 PAGE 2 of 2