

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Tolanha water plant ID #: 10394 WTP: A Month/Year: July 23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2							
3							
4		0.01				0.01	0.01
5						0.01	0.01
6						0.01	0.01
7					0.01		0.01
8		0.01				0.01	0.01
9				0.01			0.01
10							
11							
12		0.01				0.01	0.01
13	0.01						0.01
14							0.01
15	0.01					0.01	0.01
16		0.01	0.01	0.01	0.01	0.01	0.01
17							
18							
19							
20	0.01		0.01		0.01		0.01
21							
22						0.01	0.01
23		0.01					0.01
24		0.01					0.01
25						0.01	0.01
26							
27			0.01				0.01
28		0.01	0.01	0.01			0.01
29						0.01	0.01
30						0.01	0.01
31				0.01	0.01	0.01	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No		CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
Notes:		PRINTED NAME: <u>Robert Bruce</u> SIGNATURE: <u>Robert Bruce</u> DATE: <u>8/8/23</u> PHONE #: <u>503 881-3313</u> CERT # <u>7134</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.



OHA - Drinking Water Services - Surface Water Quality Data Form

Received Time Aug. 8, 2023 12:47PM No. 9708

System Name: Idanha

ID #: 00394

WTP: A

Month/Year: July 2023

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]	
1900	1/	1.13	187	211	16.00	7.5	15	Yes	80
1700	2/	1.20	187	224	16.00	7.5	15	Yes	75
1900	3/	1.08	187	202	16.1	7.5	15	Yes	95
2000	4/	1.09	187	204	16.1	7.5	15	Yes	100
1900	5/	1.89	187	166	16.1	7.5	15	Yes	85
1900	6/	1.14	187	213	16.0	7.5	15	Yes	70
1900	7/	1.13	187	211	16.0	7.5	15	Yes	75
1800	8/	1.59	187	297	16.0	7.5	15	Yes	95
1600	9/	1.64	187	306	16.0	7.5	15	Yes	80
1600	10/	1.67	187	312	16.1	7.5	15	Yes	80
1200	11/	1.56	187	291	16.1	7.5	15	Yes	90
1700	12/	1.49	187	291	16.0	7.5	15	Yes	75
1800	13/	1.62	187	302	16.0	7.5	15	Yes	100
1800	14/	1.75	187	327	16.0	7.5	15	Yes	75
1600	15/	1.71	187	319	16.0	7.5	15	Yes	100
1900	16/	1.44	187	269	16.0	7.5	15	Yes	75
1900	17/	1.32	187	246	16.0	7.5	15	Yes	80
1900	18/	1.21	187	226	16.0	7.5	15	Yes	75
1800	19/	1.20	187	224	16.0	7.5	15	Yes	80
1900	20/	1.86	187	160	16.0	7.5	15	Yes	75
1700	21/	1.76	187	162	16.0	7.5	15	Yes	100
1800	22/	1.88	187	164	16.1	7.5	15	Yes	90
2000	23/	1.89	187	166	16.0	7.5	15	Yes	95
1600	24/	1.76	187	160	16.1	7.5	15	Yes	75
2200	25/	1.86	187	160	16.0	7.5	15	Yes	80
2100	26/	1.86	187	164	16.1	7.5	15	Yes	90
1800	27/	1.88	187	166	16.1	7.5	15	Yes	90
1900	28/	1.89	187	164	16.1	7.5	15	Yes	80
1900	29/	1.87	187	164	16.1	7.5	15	Yes	100
1600	30/	1.23	187	230	16.1	7.5	15	Yes	75
1900	31/	1.21	187	226	16.0	7.5	15	Yes	95

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised November 2022
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350