

Membrane Filter Monthly Operating Report

County: **Marion**System Name: **City of Jefferson WTP**Month/Year: **Mar-2025**PWS ID#: 41 - **00408**

Minimum test pressure applied || req'd:

25 psi || 15 psiPlant ID: WTP - **A** (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [^{psi}/_{min}]**0.140**

LRC [log removal]

4.00DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [^{psi} / _{min}]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.012	0.03	0.014	0.04	4.63	Y
2	0.012	0.024	0.014	0.04	4.72	Y
3	0.013	1	0.018	0.04	4.64	Y
4	0.012	1	0.022	0.04	4.72	Y
5	0.013	0.541	0.014	0.03	4.79	Y
6	0.013	0.093	0.014	0.03	4.79	Y
7	0.012	0.093	0.015	0.04	4.68	Y
8	0.012	0.033	0.019	0.03	4.69	Y
9	0.013	0.037	0.015	0.04	4.69	Y
10	0.013	0.036	0.014	0.04	4.68	Y
11	0.013	0.023	0.014	0.04	4.67	Y
12	0.014	0.021	0.014	0.04	4.65	Y
13	0.013	0.134	0.014	0.04	4.62	Y
14	0.013	0.044	0.014	0.05	4.59	Y
15	0.015	0.247	0.016	0.04	4.74	Y
16	0.014	0.055	0.014	0.04	4.63	Y
17	0.014	0.03	0.015	0.04	4.65	Y
18	0.013	0.019	0.014	0.04	4.68	Y
19	0.013	0.028	0.014	0.04	4.65	Y
20	0.014	0.017	0.014	0.04	4.68	Y
21	0.014	0.026	0.015	0.04	4.69	Y
22	0.014	0.018	0.014	0.04	4.65	Y
23	0.014	0.023	0.014	0.04	4.66	Y
24	0.014	0.02	0.014	0.04	4.68	Y
25	0.017	0.296	0.015	0.04	4.64	Y
26	0.018	0.186	0.015	0.05	4.60	Y
27	0.017	0.038	0.015	0.04	4.64	Y
28	0.017	0.034	0.015	0.04	4.67	Y
29	0.017	0.04	0.015	0.04	4.65	Y
30	0.017	0.028	0.015	0.04	4.66	Y
31	0.017	0.029	0.015	0.04	4.65	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N] Y	All turbidity readings ≤ 5 NTU? [Y/N] Y	All IFE turbidity readings ≤ 0.15 NTU? [Y/N] Y	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC) Y	DIT Daily? Yes
CT's met daily? (p. 2) Y	All Cl ₂ residual at EP ≥ 0.2 mg/L? Y	PDR ≤ PDR _{Max} ? Y	LRV _{ambient} ≥ LRC? Y	

PRINTED NAME:

Alex Kemmer

SIGNATURE:



DATE:

4/1/2025

WT CERT #:

T-478768

PHONE #:

541-327-1135

Notes: High CFE due to air intrapment after Start Up, CIP, EFM, Back Wash, IT's

p. 1 of 2

Disinfection Monthly Operating ReportSystem Name: **City of Jefferson WTP**PWS ID#: 41 - **00408**Month/Year: **Mar-25****0.5**Log
Inactivation
Required via
DisinfectionPlant ID : WTP - **A**

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.990	35.1	34.7	8.7	7.01	21.1	YES	700	
2	1.030	35.1	36.2	8.5	7.09	22.0	YES	700	
3	0.990	35.1	34.7	8.5	7.03	21.5	YES	700	
4	0.950	35.1	33.3	8.5	7.01	21.2	YES	700	
5	0.960	35.1	33.7	8.0	7.02	22.1	YES	700	
6	0.960	35.1	33.7	7.4	7.15	24.0	YES	700	
7	0.980	35.1	34.4	7.7	7.09	23.1	YES	700	
8	0.910	35.1	31.9	8.0	7.14	22.9	YES	700	
9	0.980	35.1	34.4	8.2	7.17	23.0	YES	700	
10	0.950	35.1	33.3	8.2	7.18	23.0	YES	700	
11	0.970	35.1	34.0	8.5	7.19	22.7	YES	700	
12	0.930	35.1	32.6	8.8	7.18	22.1	YES	700	
13	0.880	35.1	30.9	8.3	7.22	23.0	YES	700	
14	1.070	35.1	37.6	7.6	7.08	23.4	YES	700	
15	0.950	35.1	33.3	7.3	7.15	24.2	YES	700	
16	0.910	35.1	31.9	7.4	7.06	23.1	YES	700	
17	0.950	35.1	33.3	7.6	7.02	22.6	YES	700	
18	0.930	35.1	32.6	7.7	6.93	21.7	YES	700	
19	0.920	35.1	32.3	7.9	7.04	22.3	YES	700	
20	1.110	35.1	39.0	7.8	6.95	22.2	YES	700	
21	0.960	35.1	33.7	7.9	7.01	22.1	YES	700	
22	0.930	35.1	32.6	8.2	7.03	21.8	YES	700	
23	0.920	35.1	32.3	8.5	6.97	20.9	YES	700	
24	0.980	35.1	34.4	9.1	7.01	20.5	YES	700	
25	0.990	35.1	34.7	9.8	6.95	19.2	YES	700	
26	0.990	35.1	34.7	10.6	6.85	17.6	YES	700	
27	0.980	35.1	34.4	9.0	6.91	19.9	YES	700	
28	0.850	35.1	29.8	8.6	6.89	20.0	YES	700	
29	1.000	35.1	35.1	8.6	6.88	20.3	YES	700	
30	1.030	35.1	36.2	7.9	6.88	21.3	YES	700	
31	0.960	35.1	33.7	7.7	6.90	21.6	YES	700	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2