

Membrane Filter Monthly Operating Report

County: **Marion**System Name: **City of Jefferson WTP**Month/Year: **May-2025**PWS ID#: 41 - **00408**

Minimum test pressure applied || req'd:

25 psi || 15 psiPlant ID: WTP - **A** (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [^{psi}/min]

LRC [log removal]

0.140**4.00**DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [^{psi} /min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.014	0.281	0.016	0.04	4.70	Y
2	0.014	0.634	0.017	0.04	4.59	Y
3	0.018	0.221	0.018	0.04	4.72	Y
4	0.015	0.038	0.020	0.04	4.73	Y
5	0.016	0.025	0.016	0.04	4.74	Y
6	0.017	0.031	0.016	0.03	4.77	Y
7	0.018	0.052	0.016	0.03	4.79	Y
8	0.018	0.022	0.016	0.04	4.72	Y
9	0.019	0.054	0.016	0.04	4.73	Y
10	0.019	0.049	0.016	0.04	4.71	Y
11	0.018	0.035	0.016	0.04	4.75	Y
12	0.018	0.037	0.016	0.04	4.73	Y
13	0.018	0.029	0.016	0.04	4.68	Y
14	0.019	0.039	0.017	0.04	4.65	Y
15	0.015	0.028	0.013	0.04	4.76	Y
16	0.016	0.04	0.013	0.04	4.66	Y
17	0.016	0.032	0.013	0.04	4.72	Y
18	0.016	0.04	0.013	0.04	4.69	Y
19	0.016	0.025	0.013	0.04	4.63	Y
20	0.013	0.148	0.013	0.04	4.65	Y
21	0.013	0.032	0.013	0.04	4.70	Y
22	0.013	0.035	0.013	0.04	4.67	Y
23	0.013	0.025	0.013	0.03	4.74	Y
24	0.013	0.038	0.013	0.03	4.77	Y
25	0.013	0.027	0.013	0.04	4.67	Y
26	0.013	0.027	0.013	0.03	4.74	Y
27	0.013	0.023	0.014	0.03	4.71	Y
28	0.014	0.041	0.014	0.04	4.74	Y
29	0.013	0.021	0.014	0.04	4.67	Y
30	0.014	0.034	0.014	0.03	4.74	Y
31	0.014	0.028	0.014	0.03	4.78	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Y	Y	Y	Y	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Y	Y	Y	Y	

PRINTED NAME:

Alex Kemmer

DATE:

6/1/2025

SIGNATURE:



WT CERT #:

T-478768

Notes: High CFE due to air intrapment after Start Up, CIP, EFM, Back Wash, IT's

PHONE #:

541-327-1135

p. 1 of 2

Disinfection Monthly Operating ReportSystem Name: **City of Jefferson WTP**PWS ID#: 41 - **00408**Month/Year: **May-25****0.5**Log
Inactivation
Required via
DisinfectionPlant ID : WTP - **A**

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.960	35.1	33.7	12.4	7.08	16.9	YES	700	CIP
2	0.950	35.1	33.3	13.6	7.12	15.5	YES	700	CIP
3	0.940	35.1	33.0	13.7	7.27	16.3	YES	700	
4	0.940	35.1	33.0	12.6	7.27	17.5	YES	700	
5	0.960	35.1	33.7	12.7	7.20	17.0	YES	700	
6	0.960	35.1	33.7	13.5	7.11	15.6	YES	700	
7	0.950	35.1	33.3	14.3	7.15	15.0	YES	700	
8	1.010	35.1	35.5	13.6	7.16	15.9	YES	700	
9	0.980	35.1	34.4	14.2	7.22	15.6	YES	700	EFM
10	0.970	35.1	34.0	14.8	7.26	15.1	YES	700	EFM
11	0.970	35.1	34.0	13.9	7.12	15.3	YES	700	
12	0.990	35.1	34.7	12.8	7.01	15.8	YES	700	
13	0.950	35.1	33.3	12.8	7.13	16.5	YES	700	
14	0.950	35.1	33.3	12.4	7.06	16.8	YES	700	
15	0.960	35.1	33.7	12.8	7.11	16.4	YES	700	
16	0.970	35.1	34.0	12.4	7.12	17.2	YES	700	
17	0.950	35.1	33.3	13.1	7.07	15.8	YES	700	
18	0.970	35.1	34.0	12.1	7.01	16.9	YES	700	
19	0.960	35.1	33.7	11.8	7.05	17.4	YES	700	EFM
20	0.940	35.1	33.0	12.4	7.13	17.2	YES	700	EFM
21	0.950	35.1	33.3	12.5	7.08	16.5	YES	700	
22	0.960	35.1	33.7	13.4	7.17	16.1	YES	700	
23	0.970	35.1	34.0	13.4	7.10	15.7	YES	700	
24	0.970	35.1	34.0	13.6	7.12	15.6	YES	700	
25	0.960	35.1	33.7	14.3	7.13	14.9	YES	700	
26	0.970	35.1	34.0	13.5	7.10	15.6	YES	700	
27	0.940	35.1	33.0	13.7	7.11	15.4	YES	700	EFM
28	0.940	35.1	33.0	15.3	7.11	13.8	YES	700	EFM
29	0.970	35.1	34.0	15.5	7.09	13.6	YES	700	
30	0.940	35.1	33.0	14.4	7.10	14.6	YES	700	
31	0.930	35.1	32.6	15.7	7.06	13.2	YES	700	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month bymail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2