

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa  
 Month/Year: Mar-21


System Name: City of Joseph ID#: 41 00414 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1							offline
2							offline
3							offline
4							offline
5							offline
6							offline
7							offline
8							offline
9							offline
10							offline
11			0.11				0.11
12			0.13				0.13
13			0.11				0.11
14			0.12				0.12
15			0.12				0.12
16			0.15				0.15
17			0.15				0.15
18			0.13				0.13
19			0.11				0.11
20			0.15				0.15
21			0.17				0.17
22			0.17				0.17
23			0.14				0.14
24			0.15				0.15
25			0.14				0.14
26			0.16				0.16
27			0.11				0.11
28			0.14				0.14
29			0.11				0.11
30			0.14				0.14
31			0.12				0.12

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes: Received negative Bac sample and turned plant online 4/11/2021

PRINTED NAME: Levi Tickner

SIGNATURE:  DATE: 4/8/2021

PHONE #: ( 541 ) 398-1804 CERT #: T-008780

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :  
 Disinfection *Giardia* Log  
 Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: Mar-21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1								offline
2								offline
3								offline
4								offline
5								offline
6								offline
7								offline
8								offline
9								offline
10								offline
11	0.48	1273	611.0	8.9	8.03	56.3	YES	400
12	0.48	2175	1044.0	9.4	7.89	51.8	YES	235
13	0.46	1363	627.0	9.6	7.81	49.5	YES	375
14	0.5	1345	672.5	8.1	7.73	53.5	YES	380
15	0.48	2086	1001.3	7.3	7.90	59.9	YES	245
16	0.46	2114	972.4	7.3	7.71	55.8	YES	245
17	0.48	2219	1065.1	7.2	7.85	59.2	YES	235
18	0.47	2267	1065.5	7.5	7.81	57.1	YES	230
19	0.46	2165	995.9	7.9	7.77	54.7	YES	242
20	0.48	2201	1056.5	7.4	7.88	59.0	YES	237
21	0.43	2329	1001.5	7.5	7.82	57.1	YES	225
22	0.47	2337	1098.4	7.4	7.78	56.9	YES	225
23	0.5	2183	1091.5	7.5	7.86	58.4	YES	240
24	0.5	2183	1091.5	7.1	7.84	59.5	YES	240
25	0.49	2165	1060.9	7.4	7.85	58.5	YES	242
26	0.49	1040	509.6	7.5	7.88	58.7	YES	485
27	0.47	2333	1096.5	7.1	8.03	63.6	YES	225
28	0.5	2241	1120.5	7.9	7.91	57.8	YES	234
29	0.5	2371	1185.5	7.3	7.84	58.7	YES	221
30	0.49	2231	1093.2	7.8	7.84	56.7	YES	235
31	0.51	2390	1218.9	7.6	7.86	58.0	YES	220

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350