


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
 Month/Year: Apr-21

System Name: City fo Joseph ID#: 41 00414 WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.16				0.16
2			0.14				0.14
3			0.12				0.12
4			0.11				0.11
5			0.08				0.08
6			0.13				0.13
7			0.15				0.15
8			0.14				0.14
9			0.15				0.15
10			0.13				0.13
11			0.13				0.13
12			0.14				0.14
13			0.11				0.11
14			0.13				0.13
15			0.11				0.11
16			0.16				0.16
17			0.12				0.12
18			0.14				0.14
19			0.11				0.11
20			0.12				0.12
21			0.16				0.16
22			0.11				0.11
23			0.13				0.13
24			0.10				0.10
25			0.11				0.11
26			0.13				0.13
27			0.15				0.15
28			0.11				0.11
29			0.13				0.13
30			0.15				0.15
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
		PRINTED NAME: Levi Tickner	
		SIGNATURE: 	DATE: 5/7/21
		PHONE #: (541)398-1804	T:008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP :
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: Apr-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.49	2286	1120.1	7.6	7.87	58.1	YES	230
2	0.5	2183	1091.5	8.1	7.77	54.3	YES	240
3	0.49	2151	1054.0	7.7	7.86	57.5	YES	240
4	0.5	2189	1094.5	8.2	7.79	54.3	YES	240
5	0.53	2283	1210.0	8.6	7.76	52.5	YES	230
6	0.5	2282	1141.0	8.4	7.82	54.1	YES	230
7	0.51	2143	1092.9	8.1	7.79	54.7	YES	245
8	0.5	2183	1091.5	8.3	7.77	53.5	YES	240
9	0.5	2017	1008.5	8.5	7.81	53.6	YES	260
10	0.5	2012	1006.0	8.2	7.79	54.3	YES	260
11	0.5	1974	987.0	8.0	7.61	51.6	YES	265
12	0.51	2053	1047.0	7.6	7.75	55.8	YES	255
13	0.51	2178	1110.8	7.7	7.72	54.8	YES	240
14	0.5	1895	947.5	7.5	7.76	56.3	YES	275
15	0.52	1836	954.7	7.9	7.81	55.9	YES	285
16	0.52	1637	851.2	8.4	7.69	51.8	YES	320
17	0.52	1629	847.1	8.6	7.74	52.0	YES	320
18	0.54	1657	894.8	8.9	7.58	48.3	YES	315
19	0.55	1901	1045.6	9.3	7.65	48.2	YES	275
20	0.46	1783	820.2	9.2	7.61	47.4	YES	290
21	0.52	1727	898.0	9.4	7.66	47.9	YES	300
22	0.54	1939	1047.1	9.3	7.59	47.2	YES	270
23	0.53	1827	968.3	9.4	7.62	47.3	YES	285
24	0.55	2038	1120.9	9.1	7.65	48.9	YES	255
25	0.55	2002	1101.1	8.9	7.68	50.1	YES	260
26	0.55	1865	1025.8	9.5	7.50	45.2	YES	280
27	0.53	2014	1067.4	9.5	7.70	48.4	YES	260
28	0.51	1900	969.0	9.5	7.67	47.7	YES	275
29	0.51	1772	903.7	10.0	7.50	43.5	YES	295
30	0.51	1896	967.0	9.8	7.62	46.0	YES	275
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
wdp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350