

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa  
 Month/Year: December 2021


System Name: City of Joseph ID#: 41 00414 WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.12				0.12
2			0.26				0.26
3			0.08				0.08
4			0.22				0.22
5			0.14				0.14
6			0.27				0.27
7			0.36				0.36
8			0.23				0.23
9			0.26				0.26
10			0.13				0.13
11			0.13				0.13
12			0.35				0.35
13			0.16				0.16
14			0.19				0.19
15			0.16				0.16
16			0.24				0.25
17			0.10				0.10
18			0.17				0.17
19			0.14				0.14
20			0.25				0.25
21			0.14				0.14
22			0.20				0.20
23			0.09				0.09
24			0.17				0.17
25			0.24				0.24
26			0.16				0.16
27			0.11				0.11
28			0.12				0.12
29			0.15				0.15
30			0.15				0.15
31			0.16				0.16

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:

PRINTED NAME: Levi Tickner

SIGNATURE: 

PHONE #: ( 541 )398-1804

CERT #: T008780

01/10/22

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :  
 Disinfection *Giardia* Log  
 Inactiv: 1.0

System Name: City of Joseph ID#: 41 00414 Month/Year: Dec 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.62		0.0	10.3	8.40	59.5	NO	Well running
2	0.52		0.0	10.7	8.11	51.5	NO	"
3	0.57		0.0	10.7	7.78	46.1	NO	"
4	0.52		0.0	11.0	7.97	48.1	NO	"
5	0.49		0.0	11.3	8.07	48.7	NO	"
6	0.52		0.0	11.3	7.76	43.8	NO	"
7	0.46		0.0	11.1	7.84	45.3	NO	"
8	0.49		0.0	11.1	7.92	46.8	NO	"
9	0.52		0.0	10.6	7.08	36.2	NO	"
10	0.5		0.0	10.8	7.74	44.8	NO	"
11	0.46	1857	854.2	9.9	7.80	48.4	YES	280
12	0.47	1865	876.6	9.8	7.96	51.6	YES	280
13	0.58	1951	1131.6	9.5	7.70	48.6	YES	267
14	0.62	1956	1212.7	9.3	8.06	56.3	YES	266
15	0.66	1929	1273.1	9.0	7.68	50.4	YES	270
16	0.7	1942	1359.4	8.6	7.93	56.9	YES	268
17	0.73	2005	1463.7	8.8	8.13	60.5	YES	260
18	0.7	1714	1199.8	8.3	8.02	59.9	YES	304
19	0.69	2006	1384.1	8.3	7.71	53.6	YES	260
20	0.66	1989	1312.7	8.4	7.90	56.8	YES	262
21	0.69	1926	1328.9	8.4	7.64	51.9	YES	270
22	0.7	1926	1348.2	8.5	7.73	53.3	YES	270
23	0.72	1890	1360.8	8.5	8.66	74.8	YES	275
24	0.7	2003	1402.1	8.5	7.76	53.9	YES	260
25	0.71	1889	1341.2	8.3	7.63	52.2	YES	275
26	0.66	1926	1271.2	8.1	7.65	52.9	YES	270
27	0.62	1889	1171.2	7.9	8.20	65.1	YES	275
28	0.46	1820	837.2	7.2	8.25	68.3	YES	285
29	0.43	1805	776.2	7.3	8.31	69.1	YES	287
30	0.62	1954	1211.5	7.3	8.66	80.3	YES	266
31	0.52	1792	931.8	7.2	8.67	80.2	YES	289

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350