


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Wallowa
 Month/Year: Jan-22

System Name: City of Joseph ID#: 41 00414 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.22				0.22
2			0.11				0.11
3			0.16				0.16
4			0.15				0.15
5			0.17				0.17
6			0.14				0.14
7			0.17				0.17
8			0.14				0.14
9			0.16				0.16
10			0.13				0.13
11			0.16				0.16
12			0.14				0.14
13			0.14				0.14
14			0.12				0.12
15			0.09				0.09
16			0.17				0.17
17			0.14				0.14
18			0.15				0.15
19			0.17				0.17
20			0.11				0.11
21			0.18				0.18
22			0.15				0.15
23			0.17				0.17
24			0.22				0.22
25			0.21				0.21
26			0.17				0.17
27			0.16				0.16
28			0.17				0.17
29			0.13				0.13
30			0.15				0.15
31			0.12				0.12

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² Yes All daily turbidity readings ≤ 5 NTU? Yes		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point ≥ 0.2 mg/l? Yes	
Notes:		PRINTED NAME: Levi Tickner SIGNATURE:  PHONE #: (541)398-1804 DATE: 2/8/2022 T 008780	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: City of Joseph ID#: 41 00414 Month/Year: January

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.58	1590	922.2	7.4	8.21	67.3	YES	293
2	0.65	1637	1064.1	6.5	8.15	70.6	YES	284
3	0.54	1625	877.5	6.8	8.06	66.1	YES	280
4	0.66	2220	1465.2	6.7	7.79	61.2	YES	218
5	0.72	2149	1547.3	6.8	8.18	70.5	YES	218
6	0.63	2142	1349.5	6.9	8.11	67.6	YES	218
7	0.77	2139	1647.0	6.5	7.84	64.0	YES	218
8	0.62	2282	1414.8	6.5	7.84	62.9	YES	218
9	0.78	2167	1690.3	6.5	7.84	64.1	YES	217
10	0.76	2436	1851.4	6.5	7.90	65.3	YES	200
11	0.78	2452	1912.6	6.5	7.89	65.2	YES	198
12	0.9	2479	2231.1	6.4	7.80	64.5	YES	197
13	0.94	2478	2329.3	6.3	7.74	63.8	YES	198
14	0.98	2338	2291.2	6.4	8.23	76.2	YES	196
15	1.02	2353	2400.1	6.9	7.99	67.7	YES	197
16	1	2355	2355.0	6.8	7.95	67.0	YES	196
17	0.98	2463	2413.7	6.7	8.34	77.7	YES	193
18	1.05	2507	2632.4	6.7	7.61	60.0	YES	194
19	1.07	2504	2679.3	6.5	7.93	68.5	YES	196
20	0.99	2485	2460.2	6.8	7.46	56.1	YES	198
21	0.94	2527	2375.4	6.8	7.53	57.2	YES	194
22	0.88	2566	2258.1	6.8	7.44	55.0	YES	193
23	0.66	2498	1648.7	6.6	7.57	56.9	YES	194
24	0.68	2488	1691.8	6.4	7.91	65.4	YES	193
25	0.61	2283	1392.6	6.9	8.03	65.5	YES	208
26	0.59	2273	1341.1	6.7	8.01	65.8	YES	208
27	0.57	2289	1304.7	6.5	7.74	60.3	YES	206
28	0.56	2419	1354.6	6.3	8.13	70.4	YES	193
29	0.54	2401	1296.5	6.1	8.25	74.4	YES	193
30	0.5	2311	1155.5	6.6	8.05	66.5	YES	193
31	0.5	2294	1147.0	5.9	7.71	61.6	YES	193

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350